# VILLAGE OF HASTINGS-ON-HUDSON MUNICIPAL GREENHOUSE GAS (GHG) ANALYSIS AND ACTION PLAN ENERGY AUDIT REPORT

DRAFT REPORT FOR REVIEW AND COMMENT	MARCH 15, 2019
REVISED DRAFT REPORT	AUGUST 29, 2019
FINAL REPORT	SEPTEMBER 20, 2019



Prepared by

OLA CONSULTING ENGINEERS, PC Hawthorne, NY

OLA Project No. NVOH0001.00



# TABLE OF CONTENTS

1.0	Exec	utive Summary	5
2.0	Proje	ect Site Overview	6
3.0	Proje	ect Energy Analysis Approach	7
	3.01	Energy Star and Benchmarking	7
4.0	Villa	as Holl (Municipal Building) and Bublic Library	0
4.0	4.01	ge Hall (Municipal Building) and Public Library	
	4.01	4.01.1 Existing Heating Systems	
		4.01.2 Existing Cooling Systems	
		4.01.2 Existing Cooling Systems	
		4.01.4 Existing Control Systems	
		4.01.5 Existing Domestic Water System	
		4.01.6 Existing Lighting System	
		4.01.7 Existing Lighting Controls	
	4.02	Village Hall and Library Analysis of Present Energy Use	
	4.02	4.02.1 Electrical Usage	
		4.02.2 Natural Gas Usage	
		4.02.3 #2 Fuel Oil Usage	
		4.02.4 Utility Rates and Costs	
		4.02.5 Energy Utilization	
	4.03	Energy Efficiency Measures (EEMs)	
		4.03.1 EEM 1 – Village Hall LED Lighting Retrofit and Lighting Controls Upgrade	
		4.03.2 EEM 2 – Library Lighting Controls / Daylighting Upgrades	
		4.03.3 EEM 3 – Village Hall Upgraded Windows	
		4.03.4 EEM 4 – Village Hall Upgraded Wall Insulation	
		4.03.5 EEM 5 – Steam Boiler Replacement and Radiator Valves for Village Hall	
		4.03.6 EEM 5A – Condensing Gas-Fired Hot Water Boilers	
		4.03.7 EEM 5B – Geothermal Heat Pumps for Village Hall	
		4.03.8 EEM 5C – Air Source VRF Heat Pumps for Village Hall	
		4.03.9 EEM 5D – Air Source VRF Heat Pumps for Village Hall and Condensing Gas-F	
		Hot Water Boiler for Library	
		4.03.10 EEM 6 – Roof-Mounted Solar Photovoltaic (PV) System for Library	
		4.03.11 EEM 7 – Library AHU Replacement	
		4.03.12 EEM 8 - Village Hall / Library Plug Load Management and Reduction	
	_		
5.0	••••••	es Harmon Community Center	30
	5.01	Existing Conditions	
		5.01.1 Existing Heating Systems	
		5.01.2 Existing Cooling Systems	
		5.01.3 Existing Ventilation Systems	
		5.01.4 Existing Control Systems	
		5.01.5 Existing Domestic Water Systems	
		5.01.6 Existing Lighting System	
		5.01.7 Existing Lighting Controls	
	5.02	Community Center Analysis of Present Energy Use	
		5.02.1 Electrical Usage	
		5.02.2 Natural Gas Usage	
		5.02.3 Utility Rates and Costs	
	_	5.02.4 Energy Utilization	
	5.03	Energy Efficiency Measures (EEMs)	
		5.03.1 EEM 1 – LED Lighting Retrofits	43

		5.03.3 5.03.4	EEM 2 – Rescheduling of RTU's EEM 3 – Variable Frequency Drives (VFD's) on RT-3 and RT-4 EEM 4 – Heating Plant Upgrades: High Efficiency Gas-Fired Hot Water Boiler EEM 5 – Supplemental Domestic Hot Water Heat Pump	43 43
6.0			adder Fire Company	
	6.01	-	Conditions	
		6.01.1	Existing Heating Systems	
		6.01.2	Existing Cooling Systems	
		6.01.3	Existing Ventilation Systems	
		6.01.4	Existing Domestic Water Systems	
		6.01.5	Existing Lighting System	
	0.00	6.01.6	Existing Lighting Controls	
	6.02		nd Ladder Fire Company Analysis of Present Energy Use	
		6.02.1	Electrical Usage	
		6.02.2	Natural Gas Usage	
		6.02.3 6.02.4	Utility Rates and Costs	
	6.03		Energy Utilization Efficiency Measures (EEMs)	
	0.03	6.03.1	EEM 1 – LED Lighting Retrofits	
			EEM 1 – LED Lighting Retrons EEM 2 – Lighting Controls Upgrades	
			EEM 2 – Lighting Controls Opgrades EEM 3 – Hot Water Piping Insulation	
		6.03.4 6.03.5	EEM 5 – Heating Plant Upgrades: High Efficiency Gas-Fired Hot Water Boiler	
7 0	A .eea la			FC
7.0			Corps Garage	
	7.01		Conditions	
		7.01.1 7.01.2	Existing Heating Systems	
		7.01.2	Existing Cooling Systems	
		7.01.3	Existing Domestic Water Systems	
		7.01.5	Existing Lighting System	
		7.01.6	Existing Lighting Controls	
	7.02		nce Corps Garage Analysis of Present Energy Use	
	1.02	7.02.1	Electrical Usage	
		7.02.1	Natural Gas Usage	
		7.02.3	Utility Rates and Costs	
		7.02.4		
	7.03		Efficiency Measures (EEMs)	
		7.03.1	EEM 1 – LED Lighting Retrofits	
			EEM 2 – Night Setback Heating	
8.0	Cher	nka Poo	ol Building	66
0.0	8.01		Conditions	
	0.01	8.01.1	Existing Pool Filtration Systems	
		8.01.2	Existing Heating Systems	
		8.01.3	Existing Cooling Systems	
		8.01.4	Existing Ventilation Systems	
		8.01.5	Existing Domestic Water Systems	
		8.01.6	Existing Lighting System	
		8.01.7	Existing Lighting Controls	
	8.02		a Pool Building Analysis of Present Energy Use	
	0.02	8.02.1	Electrical Usage	
		8.02.2	Utility Rates and Costs	
		8.02.3	Energy Utilization	
	8.03		Efficiency Measures (EEMs)	
		- 37		

		8.03.1	EEM 1 – Complete LED Lighting Retrofit	
		8.03.1	EEM 2 – Variable Speed Pumps and High Efficiency Motors	72
		8.03.2	EEM 3 – Air Source VRF Heat Pump for Pool Equipment Room	72
		8.03.3	EEM 4 – Domestic Hot Water Heat Pumps	73
		8.03.4	EEM 5 – Solar Tube Skylight	73
9.0	Depa	rtment	of Public Works (DPW) Garage	74
	9.01		g Conditions	
		9.01.1		
		9.01.2	<b>o o i</b>	
		9.01.3	Existing Ventilation Systems	
		9.01.4	Existing Domestic Water Systems	
		9.01.5	Existing Lighting System	
		9.01.6	Existing Lighting Controls	
	9.02	DPW G	Sarage Analysis of Present Energy Use	
		9.02.1	Electrical Usage	80
		9.02.2	Natural Gas Usage	81
		9.02.3	Utility Rates and Costs	81
		9.02.4	Energy Utilization	82
	9.03	Energy	Efficiency Measures (EEMs)	83
		9.03.1	EEM 1 – LED Lighting Retrofits	83
		9.03.2	EEM 2 – Air Source VRF Heat Pump for Repair Shop	83
10.0	Ener	gy Effic	eiency Measure (EEM) Summary	84
11.0	Reco	mmenc	dations for Strategic Implementation	86
12.0	Appe	endices		89
	A. Er	nergy Stai	r Target Finder Results	

- B. Utility History/Electric and Fuel Bills
  C. Equipment Cut Sheets
  D. Energy Audit Forms

## 1.0 Executive Summary

The Village of Hastings-on-Hudson, NY retained OLA Consulting Engineers to develop an action plan to enable the selection of effective projects the Village can take to reduce green house gas (GHG) emissions. The Village received a grant from NYSERDA for the funding of this effort. The focus of the action plan was to concentrate on seven (7) of the Village's buildings and their impact. This assessment was accomplished by first conducting energy audits of the municipal buildings to assess their current energy use,

## Village of Hastings GHG Action Plan Summary

#### **Findings from Study**

- Energy Savings Potential: 165.2 kBtu/year
- Cost Savings Potential: \$20,042
- CO<sub>2</sub> Savings Potential: 267,844 lb/year

#### Summary of Recommendations **Geothermal Heat Pumps**

- LED Lighting Retrofits
- **Building Envelope**
- Upgrades Steam Boiler Replacement
- Condensing Hot Water
  - DHW Heat Pumps

Air Source Heat Pumps

Heating Night Setback

Solar PV System

Boilers

GHG emissions, and then to develop specific actions and projects the Village can consider to reduce energy use.

The approach was to review the building's operations and utility consumption, and perform multiple site visits to review the existing energy using system, and identify the most inefficient systems. As part of this energy audit process, potential energy saving opportunities were developed, cost and emissions savings potential were analyzed, order of magnitude costing developed, and a draft proposed implementation plan presented for the Village to consider. This study is not intended to be used as a design document, but to recommend options to consider in order to improve the operations, energy performance, and GHG emissions of the buildings from an operational/sustainability perspective.

This report discusses a variety of methods that can be used to reduce the energy consumption, while potentially improving performance of the systems. Further detail including short term and long term recommendations is included in the body of this report and the appendices that follow. The insert above provides a brief summary of the types of measures recommended or considered in this report and a savings potential of all the buildings surveyed. Several measures, including EEM's for the Community Center, Hook and Ladder Company, the Ambulance Corps Garage, and the Chemka Pool building have been identified as having a high potential for energy savings and CO2 reduction, as well as low implementation costs and relatively short payback periods. Other remaining EEM's have been separated into short-term and long-term measures. Short-term measures were determined primarily from the savings potential of the project and cost of implementation. Long-term measures were determined to have a high potential for energy and CO<sub>2</sub> reduction, but likely have high implementation costs and are considered to be significant capital projects. The energy efficiency measure (EEM) summary are summarized in Section 10 of this report and the recommendations for strategic implementation are outlined in Section 11 of this report.

A centralized utility cost and energy usage spreadsheet was developed for the seven (7) buildings and is included as part of this study for the Village's use. This spreadsheet was created in order for the Village to easily access past energy and utility data, as well as to document future usage for benchmarking purposes. Continuing to track building energy usage is recommended for effective energy management. This study elaborates on the proposed energy savings measures, rough costs to implement them, and the payback associated with implementation. OLA anticipates that a final review of the measures with the Village of Hastings will determine a selected approach for implementation and further inform the draft strategic implementation plan.

# 2.0 **Project Site Overview**

Table 1 below shows a summary of the seven (7) buildings included in the scope of this energy audit. Figure 1 shows an aerial view of the locations of each building in the Village of Hastings-on-Hudson. The following sections in this report provide a breakdown of the existing conditions and energy usage for each building.

Tab	le 1. Hastings-on-Hudson Ener	gy Audit Building Information
Building	Estimated Floor Area (ft <sup>2</sup> )	Building Space Usage
Village Hall	10,595	Mixed Use (Offices, Courtroom, Police Dept.)
Public Library	13,225	Library
James Harmon Community Center	17,000	Mixed Use (Public Assembly, Recreational, Offices)
Hook and Ladder Fire Company	9,000	Fire Station
Ambulance Corps	2,400	Ambulance Garage
Chemka Pool Building	4,200	Mixed Use (Lifeguard station, Locker rooms, Storage)
DPW Garage	12,000	Maintenance / Storage Facility
TOTAL	68,420	



Figure 1. Hastings-on-Hudson site overview

# 3.0 Project Energy Analysis Approach

## 3.01 Energy Star and Benchmarking

The EPA's Energy Star Target Finder determines energy performance goals for design projects or existing buildings and provides a method for benchmarking a building's energy use. A rating for actual energy use is determined relative to similar building's average energy consumption on a scale from 0 through 100, with a score of 75 achieving Energy Star status.

Energy Star ratings are based on annual energy use intensity (EUI) measured in terms of kBtu/ft<sup>2</sup>. While reducing fuel consumption may not drastically decrease utility costs (relative to higher priced electricity), it will help improve overall energy usage and reduce carbon dioxide emissions. To make a useful comparison for the seven (7) buildings surveyed as part of the energy audit, the energy usage and costs for the building were entered in the Energy Star Target Finder. Unfortunately, most of the buildings are not eligible for an Energy Usage and costs for each of these buildings be consistently updated by the Village of Hastings using Portfolio Manager. Continuous tracking of the annual site and source EUI will help inform which buildings are poor performing and where improvements can be made. The results of this benchmark are provided in Table 2 below (see Appendix A for Energy Star Target Finder Input).

Table	2. Energy Star Target Finder F	Results Summary	
Metric	Existing Building Results	Median Property	Energy Star Design Score (0-100)
	Village Hall / Librar	у	
Site EUI (kBtu/ft <sup>2</sup> )	102.4	86	
Greenhouse Gas Emissions (CO2, lb/year)	363,431	304,238	N/A
· · · ·	James Harmon Community	y Center	
Site EUI (kBtu/ft <sup>2</sup> )	107.9	67	
Greenhouse Gas Emissions (CO2, lb/year)	264,683	163,142	N/A
	Hook and Ladder Fire Co	mpany	•
Site EUI (kBtu/ft <sup>2</sup> )	71.1	110	
Greenhouse Gas Emissions (CO2, lb/year)	76,984	119,050	N/A
· · · ·	Ambulance Corps Gar	age	
Site EUI (kBtu/ft <sup>2</sup> )	68.3	83	
Greenhouse Gas Emissions (CO2, lb/year)	22,062	26,456	N/A
	Chemka Pool Buildir	ng	
Site EUI (kBtu/ft <sup>2</sup> )	89.1	40	
Greenhouse Gas Emissions (CO2, lb/year)	69,872	30,865	N/A
	Department of Public Work	s Garage	
Site EUI (kBtu/ft <sup>2</sup> )	66.3	64	
Greenhouse Gas Emissions (CO2, lb/year)	101,647	99,208	48

From the above benchmarking analysis, it can be seen that the Village Hall, Library, and Community Center are the most energy intensive buildings. The other buildings are essentially at or below the median EUI, with the exception of the pool building.

# 4.0 Village Hall (Municipal Building) and Public Library

## 4.01 Existing Conditions

The Village Hall and Library are located on the same site at 7 Maple Avenue in Hastings-on-Hudson, NY. The Village Hall is a 2-story, 8,700 square foot municipal building and was built in approximately 1930. Typical spaces on the two (2) above grade floors in the building include a courtroom, offices, conference rooms, and the Village Police Department, which occupies part of the first floor. There is also a cellar level, which contains the boiler room, police department locker rooms, and staff lounge.

The public library is a 2-story, 13,225 square foot building and was built in 1965. An addition was added to the building in 2001. The lower level of the library contains the Orr Community room, Barnes Room, staff lounge, as well as mechanical/electrical rooms and storage spaces. The main floor features the adult library, Picture Book Room, and various offices. Photos 1, 2, and 3 below show an aerial and exterior view of the buildings.



Photo 1. Aerial view of Village Hall and Library



Photo 2. Village Hall exterior



Photo 3. Public Library exterior

Typical building hours for the Village Hall range from 8:30am – 4:00pm Monday through Friday. The building is closed on weekends. However, due to the Police Department presence in the building, the building is occupied 24/7. A breakdown of the building operating hours is shown

below in Table 3.

	Table 3. Village Hall Operating Hours								
Time	Monday	Tuesday	Wednesday	Thursday	Friday	Weekend			
8:30am	Building	Building opens	Building opens	Building	Building				
0.30am	opens	Building opens	building opens	opens	opens	Building			
4:00pm	Building	Puilding closes	Puilding along	Building	Building	Closed			
4:00pm	closes	Building closes	Building closes	closes	closes				

\*Note building is continuously occupied due to Police Department

Normal building hours for the Library range from 9:30am - 8:30pm on Mondays, Tuesdays, and Thursdays, 9:30am - 6:00pm on Wednesdays, 9:30am - 5:00pm on Fridays and Saturdays, and 1:00pm - 5:00pm on Sundays. A breakdown of the building operating hours is shown below in Table 4.

	Table 4. Library Operating Hours								
Time	Monday	Tuesday	Wednesday	Thursday	Friday	Weekend			
9:30am	Building opens	Building opens	Building opens	Building opens	Building opens	Saturday:			
5:00pm	-	-	-	-	Building closes	9:30am – 5:00pm			
6:00pm	-	-	Building closes	-	-	Sunday: 1:00pm –			
8:30pm	Building Closes	Building Closes		Building Closes		5:00pm			

#### 4.01.1 Existing Heating Systems

Heating for the Village Hall and Library is provided by one (1) dual-fuel fired (natural gas and #2 oil) low-pressure steam boiler. The boiler has a total capacity of 2,452 MBH and is manufactured by Weil McLain (Photo 4). The boiler burner appears to be original to the boiler and has a maximum capacity of 3,103 MBH on natural gas, and 21.5 GPH on oil. It was noted that the boiler is typically run on gas, was installed during a building renovation in 1998, and appears to be in fair condition. Building staff indicated that the boiler is enabled during all hours of the day during the heating season, due to the Hastings Police Department occupying part of the building. A summary of the heating plant is shown below in Table 5.

	Table 5. Village Hall Heating Plant Summary							
					Typical Boiler Start/Shutdown Time			
Weil McLain	Steam	2,452	Natural Gas / #2 Oil	1	1998	Always active		



Photo 4. Steam boiler serving Village Hall



Photo 5. Steam condensate pumps

Low-pressure steam generated by the heating plant serves three (3) different heating zones between the two buildings. The steam system is a two-pipe, pumped return system. Steam condensate is returned to the boilers via a duplex condensate pump (Photo 5), which collects and pumps the condensate back into the boiler. Two of the zones serve the northern and southern halves of the Village Hall, while the third zone supplies hot water to the library via a steam-to-hot water heat exchanger. A description of the heating system for the library is provided below. Steam for the Village Hall is distributed to cast iron steams radiators throughout the building perimeter (Photo 6). Each zone is controlled by its own programmable Honeywell thermostat (Photo 7), which is located on the first floor. The thermostat controlling the southern half is located in the Building Department, while the thermostats have the ability to automatically adjust temperature setpoint based on a programmed occupancy schedule.





Photo 6. Typical steam radiator

Photo 7. Typical Honeywell thermostat

It was noted that there is a fourth heating zone, which supplies hot water to finned tube radiation in the Police Department locker rooms in the basement of the building by means of a separate heat exchanger and two (2) dedicated hot water pumps (Photos 8 and 9). However officers expressed their desire to keep the space cool, so this zone is no longer in use.



Photo 8. Heat exchanger serving Police locker rooms



Photo 9. Hot water pumps serving Police locker rooms

Heating for the library is provided by a steam-to-hot water heat exchanger and two (2) dedicated hot water pumps (Photo 10), served by the steam boiler plant at the Village Hall. Hot water generated by the heat exchanger is distributed to perimeter finned tube radiation (Photo 11) and to hot water heating coils located in two (2) AC units and one (1) HV unit serving the building. Each finned tube zone is equipped with an electric control valve and controlled by the Library's building management system (BMS). Heat provided by the AC/HV units and finned tube radiation is controlled by local space temperature sensors, which are all monitored by the BMS. Temperature setpoints for these spaces can be adjusted at the BMS workstation located in the basement electrical room. A full description of the BMS can be found in section 4.01.4.



Photo 10. Hot water pumps serving Library



Photo 11. Typical finned tube radiation



Photo 12. Typical wall mounted temperature sensor

## 4.01.2 Existing Cooling Systems

Cooling for the Village Hall is provided by a combination of window AC units and packaged terminal AC units (PTAC's) serving offices in the building (Photo 13), a Trane packaged rooftop unit (RTU) serving the second floor courtroom (Photo 14), and two (2) Mitsubishi split AC units serving the Police Department (Photo 15). The RTU and split AC units are all controlled locally by programmable thermostats located in the spaces they serve. It was noted that the packaged RTU serving the courtroom appears to be in poor condition. There are approximately 11 Friedrich window AC units and 2 PTAC's serving the building. Each window AC unit has an approximate capacity of 1.5 tons (18 MBH) of cooling. A summary of the cooling systems at the Village Hall is shown below in Table 6.

Table 6. Village Hall Cooling Plant Summary							
Type Manufacturer Total Capacity Estimated (Tons) Total Quantity							
Window AC unit	Friedrich	1.5	11				
PTAC		1 – 1.5	2				
Packaged RTU	Trane	8*	1				
Split AC unit	Mitsubishi	1 – 2	2				

\* Per Village Hall design drawings



Photo 13. Typical window AC unit



Photo 14. Packaged Trane RTU serving courtroom



Photo 15. Split AC unit serving Police Department

Cooling for the Library is provided by a combination of one (1) 40-ton air-cooled Trane chiller (Photo 16), which serves the main floor, Picture Book Room, and Barnes Room via chilled water coils located in AC and HV units, and one (1) City-Multi split AC unit which serves the Orr Community Room on the lower level (Photo 17). A summary of the chiller plant at the Library is shown below in Table 7.

Table 7. Library Chiller Plant Summary					
Manufacturer	Туре	Total Capacity (Tons)	CHWS Temperature (°F)	Typical Chiller Start Time	Typical Chiller Shutdown Time
Trane	Air-cooled	40	44	8:00am	7:00pm – 9:00pm



Photo 16. Trane air-cooled chiller



Photo 17. City-Multi condensing unit

Chilled water is supplied to spaces via two (2) chilled water pumps located in the penthouse mechanical room. The chiller itself is located on the roof of the building, adjacent to the penthouse. The chiller is automatically controlled by the BMS (Photo 18) and is set to maintain 44°F chilled water supply temperature (CHWS) during occupied hours (determined based on Library hours). The chiller was installed in the 1990's and appears to be in fair condition, while the chilled water pumps appear to be original to the building (1965). The pumps also appear to be in fair condition.

Cooling for the Orr Community Room is provided by a City-Multi split heat pump and is supplied via ductwork in the space. This unit is locally controlled by a wall-mounted

thermostat, and cannot be controlled by the BMS (Photo 19). It was noted that this unit was recently installed during expansion of the community room.






Photo 18. Chiller plant BMS graphic

Photo 19. Thermostat for City-Multi heat pump

### 4.01.3 Existing Ventilation Systems

Mechanical ventilation for the Village Hall consists of one (1) RTU, which serves the courtroom only. Ventilation for the remainder of the building is provided by opening windows, and through various toilet exhaust fans. Table 8 below shows a summary of the systems serving the Village Hall.

Table 8. Village Hall Mechanical Ventilation System Summary								
Unit Tag	Area Served	Motor HP	Max. CFM	100% OA Unit (Y/N)				
AC-1	Second Floor Courtroom	2	3,000	No				

Mechanical ventilation for the Library consists of two (2) AC units and one (1) Heating and Ventilation (HV) unit that serve all spaces in the building except for the Community Room. HV-1, serving the main floor of the library, is located in the penthouse mechanical room and appears to be original to the building (1965). AC-2, serving the Barnes Room, is located in the ceiling adjacent to the space, and AC-3, serving the Picture Book Room and Director's Office, is located in a mechanical closet within the space. Both of these units were installed during construction of the new addition. All three (3) of these units are controlled by the BMS. Table 9 below shows a summary of the systems serving the library.

	Table 9. Library Mechanical Ventilation System Summary								
Unit Tag	Area Served	Motor HP	Max. CFM	100% OA Unit (Y/N)					
HV-1	Library Main Floor	10	15,400	No					
AC-2	Barnes Room	1	1,925	No					
AC-3	Picture Book Room and Director's Office	3⁄4	1,300	No					

### 4.01.4 Existing Control Systems

Heating at the Village Hall is controlled by two (2) Honeywell wall-mounted programmable thermostats, which control zone valves on the main steam header. The thermostats are set to maintain an occupied and unoccupied heating setpoint, based on a schedule programmed into the thermostats by the building staff. Cooling at the building is all controlled locally via manual switches for window AC units, and thermostats for the split AC units and packaged RTU serving the courtroom.

The library contains a central BMS, which automatically monitors and controls the heating and cooling systems at the building. Heating via the steam-to-hot water heat exchanger is set to maintain 172°F hot water supply temperature (HWST) during occupied hours, while the central chiller plant is set to maintain 44°F chilled water supply temperature (CHWS). The AC / HV units serving the building each have their own BMS graphic (Photo 20), and appear to be controlled based on space temperature setpoint. If the space temperature is above / below setpoint, the BMS will open the associated chilled / hot water valve on the unit until space setpoint is achieved. It was noted that HV-1 appears to have multiple zone dampers, which are also controlled by the BMS and modulate the amount of airflow supplied to each space in order to help meet space setpoint.




Photo 20. Typical AC unit graphic



Photo 21. HV-1 BMS graphic

#### 4.01.5 Existing Domestic Water System

Domestic hot water (DHW) at the Village Hall is generated by a combination electric A.O. Smith water heater and storage tank (Photo 22). The DHW heater has a total capacity of 6 kW and a storage capacity of 80 gallons. The age of the DHW heater could not be verified but it appears to be in good condition.

Domestic hot water at the Library is generated by a combination electric American water heater and storage tank (Photo 23). The DHW heater has a total capacity of 4.5kW and a storage capacity of 40 gallons. The DHW heater was installed in 2017 and appears to be in good condition. A summary of the DHW systems serving the two buildings is shown below in Table 10.

Table 10. DHW System Summary								
Area Served	Manufacturer	Manufacturer Fuel Heating Storage Quantity Source Capacity (kW) Capacity (Gal) In						
Village Hall	A.O. Smith	Electric	6	80	1	Unknown		
Library	American	Electric	4.5	40	1	2017		



Photo 22. Electric DHW heater serving Village Hall



Photo 23. Electric DHW heater serving Library

## 4.01.6 Existing Lighting System

Interior lighting at the Village Hall primarily consists 3-bulb ceiling pendants which contain 13W Fluorescent bulbs, and 2-bulb ceiling pendants containing 28W Fluorescent bulbs. These fixtures are found in all spaces throughout the building (Photos 24 and 25).

Interior lighting fixtures at the Library primarily consists of 12W and 18W LED lamps, which are found on the main floor, Orr Community Room, Barnes Room, Picture Book Room, and offices (Photos 26 and 27). There are additional wall-mounted lighting fixtures on the lower level of the Library that contain 22W Fluorescent lamps (Photo 28).



Photo 24. Typical Village Hall corridor lighting



Photo 26. Typical Library LED lighting



Photo 28. Typical Library Fluorescent lighting



Photo 25. Typical Village Hall office lighting



Photo 27. Typical Library LED lighting

## 4.01.7 Existing Lighting Controls

All interior lighting at the Village Hall and Library is controlled manually by toggle switches. Lighting is turned on at the beginning of each day by building staff and typically remains on until the end of the day. It was noted that both buildings have occupancy sensors installed, however building staff indicated that they were intended to be used for security measures and are no longer in use (Photo 29).

Exterior lighting control at the Village Hall could not be verified during the site visit. Exterior lighting at the Library is controlled by timers (Photo 30).



Photo 29. Typical occupancy sensor




Photo 30. Typical timer for exterior lighting

## 4.02 Village Hall and Library Analysis of Present Energy Use

A historical energy use analysis was performed for the energy sources at the Village Hall and Library. The following data was analyzed based on 2017-2018 energy consumption and costs. Historical utility bills detailing usage earlier than 2017 were provided, however they were not complete and therefore not included in this analysis. Based on the utility bills provided, OLA was able to calculate a combined site EUI for the two (2) buildings. The Village Hall and Library used approximately 102.4 kBtu/ft<sup>2</sup> site energy and had a combined total energy cost of \$58,494 based on 2017-2018 data. OLA could not calculate an average EUI over multiple years due to the limited amount of utility bills provided. Table 11 below provides a summary of the annual energy usage and costs for 2017-2018. Note that all fuel usage, costs, and areas are combined values from both buildings.

	Table 11. 2017-2018 Annual Overall Site Energy								
Energy Source	Energy Usage	kBtu	Cost (\$)	Cost (\$) per ft <sup>2</sup>	Site EUI (kBtu/ft <sup>2</sup> )	CO <sub>2</sub> Emissions (lb/year)			
Village Hall Electric (kWh)	125,640	428,684	\$16,865	\$1.59	40.5	80,410			
Library Electric (kWh)	126,720	432,369	\$21,847	\$1.65	32.7	81,101			
Natural Gas (therm)	12,107	1,210,700	\$13,515	\$0.57	50.8	141,758			
#2 Fuel Oil (gal)	2,621	366,940	\$6,268	\$0.26	15.4	60,907			
Total		2,438,692	\$58,494	\$2.46	102.4	363,431			
Gross Area (ft <sup>2</sup> )			23,820						

Figure 1 provides the annual site EUI per energy type based on analysis of the utility bills for 2017-2018. Figure 2 provides the annual energy cost summary by energy type from the same average year. Natural gas for heating is the dominant energy source for these two buildings, and is projected to account for 50% of the overall energy consumption of the building. However, natural gas only accounts for 23% of the cost, due to the higher cost of electricity. Figure 3 provides the annual CO2 emissions breakdown by energy type.






Figure 1. Existing Annual Fuel Type Site EUI Breakdown in kBtu/ft.<sup>2</sup>

Figure 2. Existing Annual Energy Cost Breakdown




Figure 3. Existing Annual CO<sub>2</sub> Emissions Breakdown in Ib/year

## 4.02.1 Electrical Usage

The historical electric usage for the Village Hall is shown in Figure 4. Peak electricity usage typically occurs during the summer months (May – September), likely due to the need to run the window AC units in order to cool the building. The highest monthly usage recorded during this time was 12,880 kWh during September 2016. It was noted that the usage remains relatively constant throughout the year, likely to the limited amount of window AC units at the building.




Figure 4. 2016 – 2018 Village Hall Historical Electricity Use

The historical electric usage for the Library is shown in Figure 5. Peak electricity usage typically occurs during the summer months (May – September), likely due to the need to run the air-cooled chiller in order to cool the building. The highest monthly usage recorded during this time was 18,640 kWh during September 2016.




Figure 5. 2016 – 2018 Library Historical Electricity Use

The historical electric demand for the Village Hall is shown in Figure 6. Similar to the historical electricity usage above, the building's peak demand typically occurs between May and September. The highest recorded demand of 38.4 kW occurred in August 2016.




Figure 6. 2016 – 2018 Village Hall Historical Electric Demand

The historical electric demand for the Library is shown in Figure 7. Similar to the historical electricity usage above, the building's peak demand typically occurs between May and September. The highest recorded demand of 64.0 kW occurred in September 2016.




Figure 7. 2016 – 2018 Library Historical Electric Demand

### 4.02.2 Natural Gas Usage

Figure 8 below shows the historical 2017-2018 natural gas usage for the Village Hall and Library. Since these two buildings share a heating plant, and because gas is used for heating only, usage is found to be highest during the winter months. A peak usage of 3,715 therms was recorded in January 2018.




Figure 8. 2017 – 2018 Historical Natural Gas Usage

OLA was provided with complete utility bills for this analysis and determined a natural gas of 1.12 \$/therm based on the bills provided. For the purposes of this study, this calculated rate was used to estimate energy cost savings.

## 4.02.3 #2 Fuel Oil Usage

The historical monthly oil usage for the Village Hall and Library is shown in Figure 9. It was noted that these two buildings stopped using oil for heating in 2017, and only two months of bills from that year were provided. Note that the figure below is a reflection of gallons delivered to the building per month, and not an actual trend of the usage.




Figure 9. 2017 - 2018 Historical Oil Usage

For the purposes of this study, the provided oil rate of 2.39 \$/gallon based on 2017 utility bills was used to estimate energy cost savings.

### 4.02.4 Utility Rates and Costs

The Village Hall and Library are each served by one (1) electric meter and one (1) common gas meter located at the Village Hall. An estimated demand, energy, and blended electric rate for each of the two buildings and a common gas rate were determined based on monthly usage and monthly charges. For the purposes of this study, all energy cost savings were based on 2017/18 utility rates. Electricity energy cost savings were based on 2017/18 demand and energy charges. Table 12 below shows a breakdown of the utility rates for each fuel source.

Table 12. Utility Rates							
Utility	Unit	2016/17	2017/18				
Electric (Village Hall)	\$/kW	\$25.09	\$27.28				
	\$/kWh	\$0.060	\$0.064				
	\$/kWh (Blended)	\$0.125	\$0.134				
	\$/kW	\$25.11	\$27.18				
Electric (Librany)	\$/kWh	\$0.063	\$0.067				
Electric (Library)	\$/kWh (Blended)	\$0.150	\$0.172				
Natural Gas (common)	\$/therm	-	\$1.12				
Fuel Oil #2 (common)	\$/Gallon	-	\$2.39				

## 4.02.5 Energy Utilization

Figure 10 below shows the breakdown of energy intensity (kBtu/ft<sup>2</sup>) by end use type. The results confirm that fuel consumed to run the heating plant accounts for the largest portion of the site energy use and cost.




Figure 10. Energy End Use Breakdown in kBtu/ft.<sup>2</sup>

## 4.03 Energy Efficiency Measures (EEMs)

#### Short Term EEM's

## 4.03.1 EEM 1 – Village Hall LED Lighting Retrofit and Lighting Controls Upgrade

This measure investigates the impact on energy consumption of reduced lighting power density utilizing high efficiency LED lighting technology and retrofit products throughout the building. The new LED lighting will result in a reduced lighting power density and potential for high savings. All of the typical 13W and 28W compact fluorescent lighting, as well as the 32W T8 fluorescent lighting in the basement of the building could be replaced with LED retrofit products. The existing lighting power density of the Village Hall is estimated to be 0.52 W/ft<sup>2</sup>. The resulting lighting power density of the entire facility is estimated to be in the range of 0.26 W/ft.<sup>2</sup> after a complete retrofit.

In addition, installing occupancy sensors could result in further energy reduction. This building currently has no form of automatic lighting controls installed. The occupancy sensors would automatically turn lights on and off depending on whether the space is occupied. This measure will prevent lights from staying on for extended periods of time while the spaces are not being used.





Figure 11. Proposed Philips LED fixture

Figure 12. Typical occupancy sensor

### 4.03.2 EEM 2 – Library Lighting Controls / Daylighting Upgrades

This measure investigates the energy reduction associated with installing occupancy lighting control sensors and photocells for natural daylighting. This building currently has no form of automatic lighting controls installed. The occupancy sensors would automatically turn lights on and off depending on whether the space is occupied. This measure will prevent lights from staying on for extended periods while the spaces are not in use. The photocells will dim and/or turn the lights off in a space based on the current level of daylight measured by the photocell. We estimate the following spaces/zones would be ideal for occupancy and/or daylighting sensors:

- Main Library Entrance
- Main Library Rear
- Picture Book Room
- Barnes Room
- Director's Office
- Staff Office
- Book Shop
- Staff Lounge
- Restrooms

## Long Term EEM's

### 4.03.3 EEM 3 – Village Hall Upgraded Windows

This measure assesses the energy savings associated with replacing the existing windows with higher thermal performance, high efficiency, low-e double glazing with thermally broken framing (U-0.40 assembly and SHGC 0.45). Although there was found to be considerable energy savings with this measure, the high cost to replace the glazing in each building results in a long payback.

### 4.03.4 EEM 4 – Village Hall Upgraded Wall Insulation

This measure assesses the energy savings associated with improving the thermal performance of the walls of the Village Hall by adding R-7.5 insulation throughout the building. Although there was found to be considerable energy savings with this measure, the high cost to implements these envelope improvements results in a long payback.

### 4.03.5 EEM 5 – Steam Boiler Replacement and Radiator Valves for Village Hall

As the existing steam boiler is at the end of its useful life, this measure analyzes replacing the equipment with a new higher efficiency steam boiler. The increased heating plant efficiency will provide opportunity to reduce natural gas usage and CO2 emissions. Current best achievable steam boiler efficiency is in the range of 80% - 83%. In addition, it was noted during the site survey that many of the windows at the Village Hall are kept open by occupants during the winter time due to overheating generated by the steam radiators. We recommend installing new manually adjustable thermostatic valves on every operating steam radiator in the building if this option is pursued. These valves will allow for greater control of the steam supplied from the radiators, and will also reduce the amount of waste heat energy generated by the heating plant. Note that due to the complex nature of quantifying waste heat generated from the opening of windows, energy savings associated with installing radiator valves was not calculated for this measure.

### 4.03.6 EEM 5A – Condensing Gas-Fired Hot Water Boilers

This project would eliminate the existing dual fuel fired steam boiler and convert the Village Hall to a hot water system utilizing new gas-fired, high efficiency condensing boilers as the primary source of heating. The low cost of natural gas will reduce operating costs compared to oil. In general, hot water heating systems are more efficient than steam heating systems. Installing a hot water boiler plant will allow the building to move away from the obsolete steam heating system along with their associated system losses and higher maintenance issues and costs. This project would necessitate a complete replacement of the heating distribution system. Current best achievable hot water boiler efficiency is in the range of 90% - 91%. Note that the new system would still serve the hot water heating system at the library.



Figure 13. Aerco condensing boiler

## 4.03.7 EEM 5B – Geothermal Heat Pumps for Village Hall

An alternative to EEM 5A would be to disconnect the steam heating system from the Village Hall and heat/cool the building using geothermal water source heat pumps. As there is available space in the parking lot for a well field, it is estimated that about 30 geothermal wells could be installed. Utilizing a closed loop geothermal system would remove the high energy costs of natural gas and #2 oil for heating and provide an overall energy use intensity (EUI) reduction and cost savings due to high heat pump operating efficiencies. We estimate the building has enough space for a 30 - 40 ton well field, which could potentially satisfy the entire Village Hall heating and cooling loads. Each zone in the building would be retrofitted with console units, which would provide heating and cooling to the spaces they serve (picture below). Note that the hot water heating system for the Library would remain in place, since the well field would not likely be able to support both buildings. Savings for this measure were calculated based on the existing steam boiler still serving the library.






Figure 15. Water Furnace console heat pump

# Figure 14. Geothermal heat pump heating / cooling process

## 4.03.8 EEM 5C – Air Source VRF Heat Pumps for Village Hall

Another alternative to EEM 5A and 5B would be to remove the existing steam heating system and convert the Village Hall to a more traditional air source heat pump system with variable refrigerant flow (VRF). Air source heat pumps typically offer high heating and cooling efficiencies, which could result in an overall EUI reduction and cost savings. Indoor units would be installed where appropriate, providing heating and cooling to the spaces they serve. Note that the hot water heating system for the Library would remain in place. Savings for this measure were calculated based on the existing steam boiler still serving the library.



Figure 16. City-Multi VRF heat pump units

## 4.03.9 EEM 5D – Air Source VRF Heat Pumps for Village Hall and Condensing Gas-Fired Hot Water Boiler for Library

This measure combines EEM 5C with the replacement of the existing steam boiler (serving only the Library in this scenario), addressing the heating plants for both buildings. The boiler would be replaced with a new gas-fired, hot water condensing boiler to exclusively serve the Library. The increased heating plant efficiency will reduce natural gas usage and CO<sub>2</sub> emissions. Hot water boiler efficiency is expected to be in the range of 90% - 91%, due to the use of the existing building distribution systems. Note that the existing steam heating distribution system serving the Village Hall could be demolished as part of this project, or could alternatively be abandoned in place depending on field conditions and project cost.

### 4.03.10 EEM 6 - Roof-Mounted Solar Photovoltaic (PV) System for Library

As there is available space on the roof of the library, the installation of solar electric PV panels has been reviewed. It is estimated that about 2,000 ft<sup>2</sup> of roof is available for solar panels. The general orientation of the building is favorable for solar collection, and there are no nearby tall buildings or trees that could potentially cause shading. This makes the library a good candidate for solar PV, and this upgrade would provide significant energy savings toward electricity usage. We estimate the library would have enough roof space for a 30 - 40 kW PV system, which could potentially provide up to 33% of the building's current annual electricity usage.




Figure 17. Proposed PV cell locations

Figure 18. Typical PV cell

## 4.03.11 EEM 7 – Library AHU Replacement

HV-1, serving the main floor of the Library, appears to be original to the building and although still in fair condition is beyond its useful life and should be replaced. We recommend replacing the unit with a new variable air volume (VAV) air-handling unit with VAV boxes replacing each of the existing zone dampers. The new unit would be equipped with supply and return fan variable frequency drives (VFD's), which would allow the fans to modulate speed based on the building load. Allowing the fans will modulate to a minimum speed would reduce fan energy costs and provide an overall energy savings compared to the existing HV-1.

## 4.03.12 EEM 8 – Village Hall / Library Plug Load Management and Reduction

This measure analyzes the savings associated with plug load management. Plug loads include miscellaneous equipment such as computer monitors, phone chargers, and others. Incorporating smart energy efficient strategies to reduce plug load usage could result in a reduction of approximately 5% of the current plug load electric consumption. Strategies to reduce plug load usage include using smart power strips, which cut power to devices based on a schedule or timer, and smart devices that use occupancy sensors to switch off the power to a nearby receptacle.





Figure 19. Typical Occupancy Sensor and Plug Load Receptacle

Figure 20. Typical smart power strip

## 5.0 James Harmon Community Center

## 5.01 Existing Conditions

The James Harmon Community Center is a 4-story, 17,000 square foot multi-use building located at 44 Main Street in Hastings-on-Hudson, NY and was constructed in 2007. The building contains three (3) above grade floors, as well as a basement level. The lower level contains the Youth Center, the first floor contains offices and the community room, and the second floor contains the TV / Media center and various offices. Photos 31 and 32 show an aerial and exterior view of the building.



Photo 31. Aerial view of Community Center



Photo 32. Community Center exterior

Typical building hours for the Community Center range from 9:00am – 4:30pm Monday through Thrusday, and 9:00am – 1:00pm on Fridays. It was noted that the Recreation Department is officially closed on weekends, however the building occasionally allows residents to rent out the large community room on the first floor for parties and events on Saturdays. The Youth Services center on the lower level is also open to students on weekends. A breakdown of the building operating hours is shown below in Table 12.

	Table 12. Community Center Operating Hours								
Time	Monday	Tuesday	Wednesday	Thursday	Friday	Weekend			
9:00am	Building opens	Building opens	Building opens	Building opens	Building opens	Building			
1:00pm	-	-	-	-	Building closes	occasionally			
4:30pm	Building closes	Building closes	Building closes	Building closes	-	open on Saturdays			

## 5.01.1 Existing Heating Systems

Heating for the Community Center is provided by one (1) gas-fired hot water boiler manufactured by Weil McLain (Photo 33). The boiler has a gross output capacity of 991 MBH, and is equipped with a Power Flame burner that has a maximum capacity of 1,232 MBH. It was noted that the boiler appears to be in good condition. A summary of the heating plant is shown below in Table 13.

Table 13. Community Center Heating Plant Summary							
Manufacturer Type Capacity Fuel Quantity Year Typical Boiler (MBH) Source Installed Operating Time						Typical Boiler Operating Time	
Weil McLain	Hot Water	991	Natural Gas	1	2007	3:30am – 7:00pm	

The boiler is automatically controlled by the building's digital building management system (BMS), and typically initiates occupied mode at approximately 3:30am Monday through

Friday during the heating season (Photo 34). The boiler then cycles on/off in order to achieve the BMS hot water supply temperature setpoint of  $165^{\circ}$ F. It was noted that the boiler operates in unoccupied mode from 7:00pm – 3:30am Monday through Friday. According to the BMS, the boiler is not active during weekends.





Photo 33. HW boiler serving Community Center

Photo 34. Hot water system BMS graphic

Hot water generated by the boiler is distributed throughout the building via two (2) 3 HP hot water pumps (Photo 35) and serves various perimeter radiation (Photo 36) as well as hot water coils located in the four (4) RTU's and one (1) HV unit serving the building. It was noted that the hot water pumps are equipped with variable frequency drives (VFD's) and have the ability to modulate speed based on heating demand.



Photo 34. Hot water pumps



Photo 35. Typical finned tube radiation

Heating for each space in the building is controlled remotely by the BMS through wallmounted temperature sensors (Photo 36). Since the majority of spaces in the building are served by variable air volume (VAV) boxes, each temperature sensor typically monitors one zone and an associated finned tube radiation valve grouped with that specific zone. It was noted that space temperature setpoints can be adjusted via the BMS workstation located in the Recreation Department on the first floor of the building. A description of the BMS can be found in section 5.01.4.



Photo 36. Typical temperature sensor

## 5.01.2 Existing Cooling Systems

Cooling for the Community Center is provided by a total of four (4) packaged Carrier rooftop units (RTU's) equipped with DX cooling. Cold air is generated by the RTU's and then supplied to spaces throughout the building via individual VAV boxes. Cooling setpoints for each space are controlled by the BMS and monitored by wall-mounted temperature sensors. A summary of the cooling capacities for each RTU is provided in section 5.01.3.

### 5.01.3 Existing Ventilation Systems

Mechanical ventilation for the Community Center consists of the four (4) Carrier RTU's (Photo 37) and one (1) Magic Aire HV unit (Photo 38) that serve the entire building. The four RTU's are all located on the roof of the building, while the HV unit is located in the basement. There are also various corresponding exhaust fans that serve these spaces (Photo 39).

It was noted that three (3) of the RTU's (RT-1, RT-2, RT-4) serve multiple spaces and contain VAV boxes. All of these systems are controlled by the BMS. Table 14 below shows a summary of the major systems serving the building.

	Table 14. Community Center Mechanical Ventilation System Summary								
Unit Tag	Area Served	Cooling Capacity (Tons)	Heating Capacity (MBH)	Motor HP	Max. CFM	100% OA Unit (Y/N)			
RT-1	Second Floor	6	48.2	3	2,100	No			
RT-2	First Floor	5	42.2	2	1,750	No			
RT-3	Community Room	25	414.4	10	10,000	No			
RT-4	Lower Level	20	138.8	5	6,000	No			
HV-1	Basement	-	24	1/3	1,000	Yes			





Photo 37. Typical RTU serving Community Center

Photo 38. HV-1 serving Community Center



Photo 39. Typical exhaust fan serving Community Center

## 5.01.4 Existing Control Systems

All of the HVAC systems at the Community Center are controlled by the building's BMS. The BMS has system summary pages for the hot water system, four (4) RTU systems, and one (1) HV unit system. There are also individual VAV graphics for each of the VAV boxes in the building.

Hot water heating is primarily controlled based on hot water supply temperature. The hot water system is currently set to maintain a constant hot water supply temperature of 165°F. The BMS graphic of the hot water system also allows the user to monitor various control points such as return water temperature, hot water pump status and speed, and system differential pressure (Photo 40).




Photo 40. Hot water system BMS graphic

The four (4) RTU's serving the building appear to be controlled by discharge air temperature or static pressure, depending on the unit. Each RTU has its own BMS graphic, where the user can monitor various points such as fan status, damper position, temperature setpoints, and static pressure (Photo 41). It was noted that HV-1, serving the basement, appears to be controlled based on discharge air temperature and does not have the same control points as the RTU's as it is a less complex system (Photo 42).




Photo 41. Typical RTU BMS graphic




Photo 42. HV-1 BMS graphic

The spaces in the building are separated into zones by VAV boxes on every floor. Each VAV box has an associated wall-mounted temperature sensor, and controls the amount of airflow supplied to the space based on whether it needs heating or cooling. Each VAV box also has its own BMS graphic, where the user can monitor various parameters including damper position and airflow and temperature setpoints (Photo 43). If a VAV box has an associated finned tube radiation zone, the radiation valve status is shown on the graphic as well.




Photo 43. Typical VAV box BMS graphic

#### 5.01.5 Existing Domestic Water Systems

Domestic hot water (DHW) is generated by a combination gas-fired PVI DHW heater and storage tank (Photo 44). The DHW heater has a total capacity of 140 MBH and storage capacity of 125 gallons. The domestic hot water loop is controlled by an aquastat and is set to supply 110°F throughout the building. A summary table of the DHW system is shown below in Table 15.

Table 15. DHW System Summary								
Manufacturer	Fuel Source	Heating Capacity (MBH)	Storage Capacity (Gal)	HWS Temperature (°F)	Quantity	Year Installed		
PVI	Natural Gas	140	125	110	1	2007		



Photo 44. PVI DHW heater and storage tank

# 5.01.6 Existing Lighting System

Interior lighting fixtures primarily consist of 32W T8 LED and Fluorescent lamps, which are in all spaces throughout the building (Photos 45 and 46). The lobby and community room have additional ceiling pendants and wall-mounted fixtures that all contain fluorescent lamps (Photos 47 – 49). It was noted that the Community Center is in the process of converting all fixtures to LED lamps.



Photo 45. Typical 32W T8 lighting fixtures in offices



Photo 46. Typical 32W T8 lighting fixtures in Youth services



Photo 47. Lobby ceiling pendants and wallmounted light fixtures



Photo 49. Community room wall-mounted light fixtures



Photo 48. Community room ceiling pendants

# 5.01.7 Existing Lighting Controls

Interior lighting is primarily controlled by ceiling-mounted occupancy sensors in each space (Photo 50). Lighting in the community room is controlled manually.

Exterior lighting is controlled by a timer located in the basement electrical room (Photo 51).



Photo 50. Typical occupancy sensor




Photo 51. Timer for exterior lighting


### 5.02 Community Center Analysis of Present Energy Use

A historical energy use analysis was performed for the energy sources at the Community Center. The following data was analyzed based on 2016-2018 energy consumption and costs. Based on the utility bills provided, OLA was able to calculate a combined site EUI for the building. The Community Center used approximately 107.9 kBtu/ft<sup>2</sup> site energy and had a total energy cost of \$43,027 based on 2016-2018 data. Table 16 below provides a summary of the annual energy usage and costs for 2016-2018.

Table 16. 2016-2018 Annual Overall Site Energy							
	Energy Usage	kBtu	Cost (\$)	Cost (\$) per ft <sup>2</sup>	Site EUI (kBtu/ft <sup>2</sup> )	CO2 Emissions (lb/year)	
Electric (kWh)	209,400	714,473	\$30,700	\$1.81	42.0	133,399	
Natural Gas (therm)	11,213	1,121,250	\$12,327	\$0.73	65.9	131,284	
Total		1,835,723	\$43,027	\$2.53	107.9	264,683	
Gross Area (ft <sup>2</sup> )				17,000			

Figure 21 provides the annual site EUI per energy type based on analysis of the utility bills for 2016-2018. Figure 22 provides the annual energy cost summary by energy type from the same average year. Natural gas for heating is the dominant energy source for this building, and is projected to account for 61% of the overall energy consumption of the building. However, natural gas only accounts for 29% of the cost, due to the higher cost of electricity. Figure 23 provides the annual CO2 emissions breakdown by energy type.








Figure 23. Existing Annual CO<sub>2</sub> Emissions Breakdown in lb/year

### 5.02.1 Electrical Usage

The historical electric usage for the Community Center is shown in Figure 24. Peak electricity usage typically occurs during the summer months (May – September), likely due to the need to run the window AC units in order to cool the building. The highest monthly usage recorded during this time was 21,680 kWh during August 2018.




Figure 24. 2016 – 2018 Historical Electricity Use

The historical electric demand is shown in Figure 25. Similar to the historical electricity usage above, the building's peak demand typically occurs between May and September. The highest recorded demand of 81.6 kW occurred in September 2016.




Figure 25. 2016 – 2018 Historical Electric Demand

OLA was provided with complete electric utility bills for this analysis, and determined an average blended electricity rate of 0.147 \$/kWh based on the bills provided.

### 5.02.2 Natural Gas Usage

Figure 26 below shows the historical 2016-2018 natural gas usage for the Community Center. Since gas in this building is used for heating only, usage is found to be highest during the winter months. A peak usage of 2,726 therms was recorded in December 2017.




Figure 26. 2016 – 2018 Historical Natural Gas Usage

OLA was provided with complete utility bills for this analysis and determined a natural gas of 1.10 \$/therm based on the bills provided. For the purposes of this study, this calculated rate was used to estimate energy cost savings.

### 5.02.3 Utility Rates and Costs

The Community Center is served by one (1) electric meter and one (1) gas meter. Estimated demand, energy, and blended electric and gas rates for the building were determined based on monthly usage and monthly charges. For the purposes of this study, all energy cost savings were based on calculated average utility rates. Electricity energy cost savings were based on average demand and energy charges. Table 17 below shows a breakdown of the utility rates for each fuel source.

Table 17. Utility Rates							
Utility	Unit	2016/17	2017/18	Average			
	\$/kW	\$25.08	\$27.13	\$26.11			
Electric	\$/kWh	\$0.062	\$0.065	\$0.064			
	\$/kWh (Blended)	\$0.142	\$0.151	\$0.147			
Natural Gas	\$/therm	\$1.05	\$1.15	\$1.10			

### 5.02.4 Energy Utilization

Figure 27 below shows the breakdown of energy intensity (kBtu/ft<sup>2</sup>) by end use type. The results confirm that fuel consumed to run the heating plant accounts for the largest portion of the site energy use and cost.




Figure 27. Energy End Use Breakdown in kBtu/ft.<sup>2</sup>

### 5.03 Energy Efficiency Measures (EEMs)

### Short Term EEM's

#### 5.03.1 EEM 1 – LED Lighting Retrofits

This measure investigates the impact on energy consumption of reduced lighting power density utilizing high efficiency LED lighting technology and retrofit products throughout the building. The new LED lighting will result in a reduced lighting power density and potential for high savings. All of the typical 32W T8 fluorescent lighting throughout the Community Center and the existing wall-mounted fluorescent fixtures in the multi-purpose room could be replaced with LED retrofit products. The existing lighting power density of the building is estimated to be 0.56 W/ft<sup>2</sup>. The resulting lighting power density of the entire facility is estimated to be in the range of 0.42 W/ft.<sup>2</sup> after a complete retrofit. Note that the Community Center is already in the process of converting all fixtures to LED lamps.

### 5.03.2 EEM 2 – Rescheduling of RTU's

The current operating hours of the HVAC equipment at the Community Center appears to not be synchronized with the actual weekly occupied hours at the building. This measure studies the potential savings from reducing the run hours on the four (4) RTU's serving the building. Adjusting the run hours could provide a significant electricity savings, and reduce the overall site and source EUI.

#### 5.03.3 EEM 3 – Variable Frequency Drives (VFD's) on RT-3 and RT-4

Installing VFD's on RT-3 and RT-4 and making these units variable air volume (VAV) systems would allow the supply and exhaust fans on these units to modulate based on space temperature (or duct static pressure in the case of RT-4). If space temperature setpoint is met, the fans will modulate to a preset minimum speed, thereby reducing fan energy costs while still providing ventilation.

#### Long Term EEM's

#### 5.03.4 EEM 4 – Heating Plant Upgrades: High Efficiency Gas-Fired Hot Water Boiler

This project would eliminate the existing standard efficiency gas-fired boiler at the community center and install a new high efficiency, condensing boiler for heating. We estimate that the boiler efficiency of the existing heating plant is approximately 81%. Current best achievable hot water boiler efficiency is in the range of 90% - 91% when used to serve an existing building.



Figure 28. Aerco condensing boiler

## 5.03.5 EEM 5 – Supplemental Domestic Hot Water Heat Pump

Supplementing the existing gas-fired domestic hot water heater with a 125-gallon electric heat pump system should be considered in the future. Providing the building with a high efficient electric heat pump water heater would reduce the site EUI of the building and CO<sub>2</sub> emissions.



Figure 29. Typical residential style DHW heat pump

# 6.0 Hook and Ladder Fire Company

### 6.01 Existing Conditions

The Hook and Ladder Fire Company building is a 2-story, 9,000 square foot volunteer fire department located at 50 Main Street in Hastings-on-Hudson, NY and was constructed in the early 1900s. It was noted that the building has been converted for many different purposes and the original construction has been altered significantly over time. The first floor contains the main garage, kitchen, workout room, and lounge area for the fire company, while the second floor contains the chief's office and additional lounge space. There is also a basement level that contains the mechanical equipment serving the building. Photos 52 and 53 shows an aerial and exterior view of the building.



Photo 52. Aerial view of Hook and Ladder Co.



Photo 53. Hook and Ladder Co. exterior

As Hook and Ladder Co. is considered a volunteer fire department, at least one volunteer is present at the building on a daily basis. However, based on observations made during the survey and through interviewing building staff it appears the building is unoccupied at night. Volunteers will typically only occupy the building in the case of a fire call during these hours.

### 6.01.1 Existing Heating Systems

Heating for the building is provided by one (1) gas-fired hot water boiler manufactured by Weil McLain (Photo 54). The boiler has a gross capacity of 296 MBH. Hot water generated by the boiler is distributed throughout the building via four (4) inline hot water recirculation pumps that separate the building into four (4) separate zones which include the Chief's office, truck room (main garage), bar room, and the second floor lounge space. Each zone contains perimeter finned tube radiation for heating (Photo 55). It was noted that the large majority of hot water piping is uninsulated. A summary of the heating plant is shown below in Table 18.

Table 18. Hook and Ladder Heating Plant Summary						
Manufacturer         Type         Capacity (MBH)         Fuel Source         Quantity Installed         Year         Typical Boiler					21	
Weil McLain	Hot Water	296	Natural Gas	1		Always active



Photo 54. HW boiler serving Hook and Ladder Co.



Photo 55. Typical finned tube radiation

Each heating zone is controlled by a local wall-mounted thermostat, which controls the finned tube radiation in that particular zone (Photo 56). It was noted that the thermostat controlling the finned tube radiation in the bar room appears to have recently been replaced. Building staff indicated that thermostats are typically kept at a constant temperature setpoint (approximately 70°F) during the heating season.



Photo 56. Typical heating thermostat

# 6.01.2 Existing Cooling Systems

Cooling is provided by a combination of window AC units and Mitsubishi split AC units (Photos 57 and 58). There are two (2) window AC units, which serve the first floor workout room and second floor lounge space. Each window AC unit has an approximate capacity of 1 - 1.5 tons (12-18 MBH) of cooling. There are also three (3) Mitsubishi split AC units, which serve the bar room and Chief's office respectively. The two (2) units serving the bar room have a capacity of 2.5 tons (24-30 MBH) each, and the unit serving the Chief's office has a total capacity of 3 tons (36 MBH). A summary of the cooling systems serving the building is shown below in Table 19.

	Table 19. Hook and Ladder Cooling Plant Summary							
Туре	Area Served	Manufacturer	Total Capacity (Tons)	Total Quantity				
Window	Workout room,	-	1.5	2				
AC unit	Second Floor Lounge							
Split AC	Bar Room,	Mitsubishi	2.5 – 3	3				
unit	Chief's Office							





Photo 57. Typical window AC unit

Photo 58. Mitsubishi split AC unit serving bar room

# 6.01.3 Existing Ventilation Systems

Hook and Ladder Co. does not have any mechanical ventilation systems. Ventilation is only provided when opening windows and doors in the building.

# 6.01.4 Existing Domestic Water Systems

Domestic hot water (DHW) is generated by a combination gas-fired Rheem DHW heater and storage tank, which is located in the basement (Photo 16). The DHW heater has a total capacity of 40 MBH and storage capacity of 50 gallons. A summary of the DHW system is shown below in Table 20.

Table 21. Hook and Ladder DHW System Summary							
Manufacturer	Fuel Source	Heating Capacity (MBH)	Storage Capacity (Gal)	HWS Temperature (°F)	Quantity	Year Installed	
Rheem	Natural Gas	40	50	-	1	2003	



Photo 59. Rheem DHW heater

# 6.01.5 Existing Lighting System

Interior lighting primarily consists of 32W T8 fluorescent and round 13W LED light fixtures found in the main garage, chief's office, bar room, and kitchen (Photos 60 and 61). There are additional light fixtures that contain Satco T8 U-tube shaped fluorescent lamps found in the workout room and second floor lounge (Photo 62).



Photo 60. Typical T8 fluorescent lighting



Photo 62. Typical Satco T8 lighting



Photo 61. Typical LED lighting

# 6.01.6 Existing Lighting Controls

The majority of lighting in the building is controlled manually by toggle switches. However, there is a row of lights in the truck room that is controlled by a wall-mounted occupancy sensor (Photo 63).




Photo 63. Occupancy sensor in truck room

## 6.02 Hook and Ladder Fire Company Analysis of Present Energy Use

A historical energy use analysis was performed for the energy sources at Hook and Ladder Fire Company. The following data was analyzed based on yearly energy consumption and costs. Based on the utility bills provided, OLA was able to calculate a combined site EUI for the building. The building used approximately 71.1 kBtu/ft<sup>2</sup> site energy and had a total energy cost of \$7,419 based on 2016-2018 data. Table 22 below provides a summary of the annual energy usage and costs for 2016-2018.

Table 22. 2016-2018 Annual Overall Site Energy							
	Energy Usage	kBtu	Cost (\$)	Cost (\$) per ft <sup>2</sup>	Site EUI (kBtu/ft <sup>2</sup> )	CO2 Emissions (lb/year)	
Electric (kWh)	8,646	29,500	\$723	\$0.08	3.3	5,508	
Natural Gas (therm)	6,105	610,450	\$6,696	\$0.74	67.8	71,476	
Total		639,950	\$7,419	\$0.82	71.1	76,984	
Gross Area (ft <sup>2</sup> )				9,000			

Figure 30 provides the annual site EUI per energy type based on analysis of the utility bills for 2016-2018. Figure 31 provides the annual energy cost summary by energy type from the same year. Natural gas for heating is the dominant energy source for this building and is projected to account for 95% of the overall energy consumption of the building, and 90% of the total cost. The large gas usage is likely due to the heating plant constantly running to achieve the building temperature setpoint of 70°F. This is because building staff do not lower the zone thermostats during unoccupied hours. Figure 32 provides the annual CO<sub>2</sub> emissions breakdown by energy type.






Figure 31. Existing Annual Energy Cost Breakdown




Figure 32. Existing Annual CO<sub>2</sub> Emissions Breakdown in Ib/year

# 6.02.1 Electrical Usage

The historical electric usage for Hook and Ladder Fire Company is shown in Figure 33. Peak electricity usage typically occurs during the summer months (May – September), likely due to the need to run the window AC units in order to cool the building. The highest monthly usage recorded during this time was 1,320 kWh during August 2018.




Figure 33. 2016 – 2018 Historical Electricity Use

It was noted that the building moved away from demand based electricity usage in 2017.

OLA was provided with complete electric utility bills for this analysis, and determined an electricity rate of 0.066 \$/kWh based on the bills provided. For the purposes of this study, this calculated rate was used to estimate energy cost savings. Note that this rate was determined using the bills from when the building switched to a new rate structure (January 2017 – present).

### 6.02.2 Natural Gas Usage

Figure 34 below shows the historical 2016-2018 natural gas usage for the building. Since gas in this building is used for heating only, usage is found to be highest during the winter months. A peak usage of 1,366 therms was recorded in December 2017.




Figure 34. 2016-2018 Historical Natural Gas Usage

OLA was provided with complete utility bills for this analysis and determined an average natural gas of 1.10 \$/therm based on the bills provided. For the purposes of this study, this calculated rate was used to estimate energy cost savings.

### 6.02.3 Utility Rates and Costs

Hook and Ladder Company is served by one (1) electric meter and one (1) gas meter. Estimated electric and gas rates for the building were determined based on monthly usage and monthly charges. For the purposes of this study, electricity energy cost savings were based on the 2017/18 utility rate as mentioned in section 6.02.1. Natural gas energy cost savings were based on the calculated average utility rate. Table 23 below shows a breakdown of the utility rates for each fuel source.

Table 23. Utility Rates							
Utility	Unit	2016/17	2017/18	Average			
Electric	\$/kWh	-	\$0.066	-			
Natural Gas	\$/therm	\$1.03	\$1.16	\$1.10			

# 6.02.4 Energy Utilization

Figure 35 below shows the breakdown of energy intensity ( $kBtu/ft^2$ ) by end use type. The results confirm that fuel consumed to run the heating plant accounts for the largest portion of the site energy use and cost.




Figure 35. Energy End Use Breakdown in kBtu/ft.<sup>2</sup>

### 6.03 Energy Efficiency Measures (EEMs)

### Short Term EEM's

#### 6.03.1 EEM 1 – LED Lighting Retrofits

This measure investigates the impact on energy consumption of reduced lighting power density utilizing high efficiency LED lighting technology and retrofit products throughout the building. The new LED lighting will result in a reduced lighting power density and potential for high savings. All of the typical 32W T8 fluorescent lighting in the building could be replaced with LED retrofit products. The existing lighting power density of the building is estimated to be 0.43 W/ft<sup>2</sup>. The resulting lighting power density of the entire facility is estimated to be in the range of 0.31 W/ft<sup>2</sup> after a complete retrofit.

#### 6.03.2 EEM 2 – Lighting Controls Upgrades

This measure investigates the energy reduction associated with installing occupancy lighting control sensors. This building currently has no form of automatic lighting controls installed. The occupancy sensors would automatically turn lights on and off depending on whether the space is occupied. This measure will prevent lights from staying on for extended periods of time while the spaces are not being used. Note that savings for this measure is based on EEM 1 being implemented.

#### 6.03.3 EEM 3 – Hot Water Piping Insulation

As the majority of hot water piping in the basement is uninsulated, this measure estimates the energy reduction and cost savings associated with installing standard 1" pipe insulation on all of the accessible piping.

#### 6.03.4 EEM 4 – Heating Night Setback

This measure assesses the energy reduction and cost savings associated with implementing a night setback heating setpoint for the boiler. All of the existing dial Honeywell thermostats could be replaced with programmable thermostats that have the ability to adjust heating setpoints based on a predetermined occupied and unoccupied schedule. Lowering the heating setpoint will reduce boiler run time and reduce the overall EUI of the building.



Figure 36. Typical Honeywell programmable thermostat

### Long Term EEM's

### 6.03.5 EEM 5 – Heating Plant Upgrades: High Efficiency Gas-Fired Hot Water Boiler

This project would eliminate the existing standard efficiency gas-fired boiler at the building and install a new high efficiency, condensing boiler for heating. We estimate that the boiler efficiency of the existing heating plant is approximately 81%. Current best achievable hot water boiler efficiency is in the range of 90% - 91%.

# 7.0 Ambulance Corps Garage

# 7.01 Existing Conditions

Hastings-on-Hudson Ambulance Corps garage is a 1-story, 3,600 square foot volunteer ambulance garage located at 47 Main Street in Hastings-on-Hudson, NY and was constructed in 1979. The first floor contains the main garage, kitchen/lounge area, bathroom, and boiler room for the garage. Photos 64 and 65 show an aerial and exterior view of the building.



Photo 64. Aerial view of Hook and Ladder Co.



Photo 65. Ambulance Garage exterior

As the ambulance garage is considered a volunteer ambulatory service, there are no permanent occupants at the building. Based on observations made during the survey, it appears the building is typically occupied by one or two volunteers during the day and unoccupied at night. Volunteers likely only occupy the building in the case of an emergency call during night hours. It was noted that no volunteers were present at the building during the site survey.

# 7.01.1 Existing Heating Systems

Heating for the building is provided by one (1) gas-fired hot water boiler manufactured by Bunrham (Photo 16). The size of the boiler plant was unable to be verified, as the boiler did not have any nameplate data and OLA was unable to open the front panel of the boiler. Hot water generated by the heating plant is distributed to various perimeter radiators located in the main garage (Photo 67). There appears to be no form of heating for the kitchen and lounge area. A summary of the heating plant is shown below in Table 24.

Table 24. Ambulance Garage Heating Plant Summary						
Manufacturer	Туре	Capacity (MBH)	Fuel Source	Quantity	Year Installed	Typical Boiler Operating Time
Burnham	Hot Water		Natural Gas	1		



Photo 66. HW boiler serving Ambulance Garage



Photo 67. Typical hot water radiator

Heating for the building is controlled by a local wall-mounted thermostat, which controls all of the perimeter radiators in the main garage (Photo 68). It was noted that the thermostat is enclosed in a plastic casing, and appears to be left at a constant temperature between  $75 - 80^{\circ}$ F.



Photo 68. Thermostat serving Ambulance Garage

# 7.01.2 Existing Cooling Systems

Cooling for the building is provided by three (3) Friedrich window AC units, which serve the main garage and lounge area respectively (Photos 69 and 70). Each window AC unit has an approximate capacity of 1 - 1.5 tons (12-18 MBH) of cooling, and is remotely controlled. A summary of the window AC units serving the building is shown below in Table 25.

Table 25. Ambulance Garage Cooling Plant Summary						
Туре	Manufacturer Total Capacity Estimated					
		(Tons)	Total Quantity			
Window AC unit	Friedrich	1 – 1.5	3			



Photo 69. Typical window AC unit serving lounge area



Photo 70. Typical window AC unit serving main garage

# 7.01.3 Existing Ventilation Systems

There is no mechanical ventilation system serving the Ambulance Garage. Ventilation is primarily provided by opening windows and the garage doors. It was noted that there is a vent located in the main garage that could provide ventilation for the space, but its purpose could not be confirmed (Photo 71).



Photo 71. Vent located in main garage

# 7.01.4 Existing Domestic Water Systems

Domestic hot water (DHW) is generated by a combination gas-fired Bradford White DHW heater and storage tank, which is located in the boiler room (Photo 72). The DHW heater has a total capacity of 40,000 Btu/hr and storage capacity of 40 gallons. A summary of the DHW system is shown below in Table 26.

Table 26. Ambulance Garage DHW System Summary						
Manufacturer	Fuel Source	Heating Capacity (MBH)	Storage Capacity (Gal)	Quantity	Year Installed	
Bradford White	Natural Gas	40	40	1	2014	



Photo 72. Bradford White DHW heater

# 7.01.5 Existing Lighting System

Interior lighting primarily consists of 2 and 3-bulb T8 fluorescent light fixtures containing Sylvania 32W T8 fluorescent lamps. These fixtures are found throughout the main garage and lounge area (Photos 73 and 74).



Photo 73. Typical T8 fluorescent lighting in main garage




Photo 74. Typical T8 fluorescent lighting in lounge area

Exterior lighting is minimal and typically features round ceiling mounted fixtures, which appear to contain fluorescent bulbs (Photo 75).



Photo 75. Typical exterior lighting

# 7.01.6 Existing Lighting Controls

All interior lighting is controlled manually by toggle switches (Photo 76). Exterior lighting appears to be controlled by timers, but this could not be verified (Photo 77).



Photo 76. Typical manual light switches



Photo 77. Timers appear to be for exterior lighting

### 7.02 Ambulance Corps Garage Analysis of Present Energy Use

A historical energy use analysis was performed for the energy sources at the Ambulance Corps garage. The following data was analyzed based on yearly energy consumption and costs. Based on the utility bills provided, OLA was able to calculate a combined site EUI for the building. Note that OLA was only provided with invoices for gas bills, and actual usage for this building was inferred based on monthly \$/therm rates calculated from Hook and Ladder Co. gas bills. The building used approximately 68.3 kBtu/ft<sup>2</sup> site energy and had a total energy cost of \$4,937 based on 2017-2018 data. OLA could not calculate an average EUI over multiple years due to the limited amount of utility bills provided. Table 27 below provides a summary of the annual energy usage and costs for 2017-2018.

	Table 27. 2017-2018 Annual Overall Site Energy							
	Energy Usage	kBtu	Cost (\$)	Cost (\$) per ft <sup>2</sup>	Site EUI (kBtu/ft <sup>2</sup> )	CO2 Emissions (lb/year)		
Electric (kWh)	12,121	43,713	\$3,227	\$1.34	17.2	7,722		
Natural Gas (therm)	1,225	122,479	\$1,710	\$0.71	51.0	14,341		
Total		163,836	\$4,937	\$2.06	68.3	22,062		
Gross Area (ft <sup>2</sup> )				2,400				

<sup>\*</sup> Inferred based on monthly \$/therm unit prices from Hook and Ladder Co.

Figure 37 provides the site EUI per energy type based on analysis of the utility bills for 2017-2018. Figure 38 provides the energy cost summary by energy type from the same year. Natural gas for heating is the dominant energy source for this building, and is projected to account for 75% of the overall energy consumption of the building, and 35% of the total cost. Figure 39 provides the annual CO<sub>2</sub> emissions breakdown by energy type.




Figure 37. Existing Annual Fuel Type Site EUI Breakdown in kBtu/ft.<sup>2</sup>




Figure 38. Existing Annual Energy Cost Breakdown




Figure 39. Existing Annual CO<sub>2</sub> Emissions Breakdown in Ib/year

# 7.02.1 Electrical Usage

The historical electric usage for the Ambulance Corps garage is shown in Figure 40. Peak electricity usage typically occurs during the summer months (May – September), likely due to the need to run the window AC units in order to cool the building. The highest monthly usage recorded during this time was 2,026 kWh during July 2016.




Figure 40. 2016 – 2018 Historical Electricity Use

OLA was provided with complete electric utility bills for this analysis, and determined an electricity rate of 0.266 \$/kWh based on the bills provided. For the purposes of this study, this calculated rate was used to estimate energy cost savings.

### 7.02.2 Natural Gas Usage

Figure 41 below shows the historical 2017-2018 natural gas usage for the building. As OLA was only provided with invoices from monthly gas bills, the actual usage has been inferred based on monthly \$/therm unit prices calculated from the Hook and Ladder Co. gas bills. A peak usage of 186 therms was recorded in December 2017.




Figure 41. 2017-2018 Historical Natural Gas Usage

OLA was not provided with complete utility bills for this analysis and could not determine an actual natural gas rate. Invoices for natural gas bills were provided for the months December 2017 – August 2018. The total cost from these months was used as the annual gas utility cost for this building. For the purposes of this study, an estimated natural gas rate of \$1.40/therm was calculated based on the inferred gas usage (determined by monthly \$/therm rates from Hook and Ladder Co.) and the annual gas utility cost based on the invoices provided. This calculated rate was used to estimate energy cost savings.

### 7.02.3 Utility Rates and Costs

The Ambulance Corps garage is served by one (1) electric meter and one (1) gas meter. Estimated electric and gas rates for the building were determined based on monthly usage and monthly charges. For the purposes of this study, all energy cost savings were based on 2017/18 utility rates. Table 28 below shows a breakdown of the utility rates for each fuel source.

Table 28. Utility Rates							
Utility Unit 2016/17 2017/18							
Electric	\$/kWh	\$0.249	\$0.266				
Natural Gas	\$/therm	-	\$1.40				

# 7.02.4 Energy Utilization

Figure 42 below shows the breakdown of energy intensity (kBtu/ft<sup>2</sup>) by end use type. The results confirm that fuel consumed to run the heating plant accounts for the largest portion of the site energy use and cost.




Figure 42. Energy End Use Breakdown in kBtu/ft.<sup>2</sup>

### 7.03 Energy Efficiency Measures (EEMs)

### Short Term EEM's

### 7.03.1 EEM 1 – LED Lighting Retrofits

This measure investigates the impact on energy consumption of reduced lighting power density utilizing high efficiency LED lighting technology and retrofit products throughout the building. The new LED lighting will result in a reduced lighting power density and potential for high savings. All of the typical 34W T8 fluorescent lighting in the building could be replaced with LED retrofit products. The existing lighting power density of the building is estimated to be 0.72 W/ft<sup>2</sup>. The resulting lighting power density of the entire facility is estimated to be in the range of 0.49 W/ft.<sup>2</sup> after a complete retrofit.

### 7.03.2 EEM 2 – Night Setback Heating

This measure assesses the energy reduction and cost savings associated with implementing a night setback heating setpoint for the boiler. The existing Honeywell thermostat could be replaced with a programmable thermostat that has the ability to adjust heating setpoint based on a predetermined occupied and unoccupied schedule. Lowering the heating setpoint will reduce boiler run time and reduce the overall EUI of the building.

# 8.0 Chemka Pool Building

### 8.01 Existing Conditions

The Chemka pool building is a 1-story, 4,200 square foot pool building and locker room facility located at Hillside Avenue in Hastings-on-Hudson, NY. The building contains a lifeguard staff work and lounge area, as well as male and female locker rooms. There is also a lower level that contains mechanical and filtration equipment for the pool complex. Photos 78 and 79 show an aerial and exterior view of the building.





Photo 78. Aerial view of Chemka pool

Photo 79. Chemka pool building exterior

Hours for the pool building vary throughout the summer of 2018. The pool is typically occupied from 12:00pm – 8:00pm on weekdays 10:00am – 8:00pm on weekends during the summer. A detailed breakdown of the occupancy hours at the Chemka Pool is shown below in Table 29. The pool opened on May 23 and closed on September 9, 2018. The pool building is unoccupied during the offseason.

	Table 29. Chemka Pool Building Operating Hours						
Date	Time	Monday	Tuesday	Wednesday	Thursday	Friday	Weekend
5/23 – 6/23	12:00pm	Building	Building	Building opens	Building	Building	Building
&	12.00pm	opens	opens	Building opens	opens	opens	open
8/20 - 9/2	8:00pm	Building	Building	Building closes	Building	Building	10:00am –
	6.00pm	closes	closes	Building closes	closes	closes	8:00pm
	12:30pm	Building	Building	Building opens	Building	Building	Building
6/24 – 8/19	12.30pm	opens	opens	Building opens	opens	opens	open
	8:00pm	Building	Building	Building closes	Building	Building	10:00am –
	8.00pm	closes	closes	Building closes	closes	closes	8:00pm
	3:00pm	Building	Building	Building opens	Building	Building	Building
9/3 - 9/9		opens	opens		opens	opens	open
	7:00pm	Building	Building	<b>Building closes</b>	Building	Building	11:00am –
	7.00pm	closes	closes	Building closes	closes	closes	7:00pm

### 8.01.1 Existing Pool Filtration Systems

The Chemka Pool complex features three (3) different pools: the main pool, training pool, and wading pool. Each pool contains its own dedicated feature pump and chemical monitoring system (Photos 80 and 81). The main and training pools also have their own dedicated filtration tanks, which collect and filter the pool water before it is pumped to its respective pool.



Photo 80. Main pool feature pump



Photo 81. Typical pool chemical monitoring system

# 8.01.2 Existing Heating Systems

As the pool building is used seasonally, there is no heating plant serving the locker rooms and staff area. The locker room and staff areas are winterized during the off season. The pool equipment room is heated by a wall-mounted electric resistance heater to protect that equipment.

# 8.01.3 Existing Cooling Systems

There is no form of mechanical cooling at the pool building. The only conditioning for the locker rooms and staff office is provided by natural airflow through doorways.

### 8.01.4 Existing Ventilation Systems

There is no mechanical ventilation system serving the pool building. Ventilation is provided only by natural airflow through the locker rooms and staff office as noted above.

### 8.01.5 Existing Domestic Water Systems

Domestic hot water (DHW) is generated by two (2) combination electric Rheem DHW heaters and storage tanks located in the building (Photo 82). Each DHW heater has a total input capacity of 9 kW and storage capacity of 120 gallons. A summary of the DHW system is shown below in Table 30.

Table 30. Chemka Pool Building DHW System Summary						
Manufacturer	Fuel Source	Heating Capacity	Storage Capacity (Gal)	Quantity	Year Installed	
Rheem	Electric	9 kW (each) 30.7 MBH (each)	120 (each)	2	2004	



Photo 82. Rheem electric DHW heater

# 8.01.6 Existing Lighting System

Interior lighting for the locker rooms and staff office primarily consists of round ceiling mounted fixtures, which contain a mixture of LED and fluorescent bulbs (Photos 83 and 84).



Photo 83. Typical locker room lighting



Photo 84. Typical staff office lighting

Exterior lighting primarily consists of wall and ceiling mounted fixtures containing fluorescent lamps (Photo 85). There are two (2) exterior light towers that provide light for the entire pool complex. Each tower contains approximately sixteen (16) bulbs (Photo 86). The wattage of these bulbs could not be verified during the site visit.



Photo 85. Typical exterior lighting



Photo 86. Typical exterior lighting tower

# 8.01.7 Existing Lighting Controls

All interior lighting is controlled manually by toggle switches. The exterior light towers are controlled by timers; the control panels for which are located in the pool equipment room.

#### 8.02 Chemka Pool Building Analysis of Present Energy Use

A historical energy use analysis was performed for the energy sources at the Chemka Pool building. The following data was analyzed based on yearly energy consumption and costs. Based on the utility bills provided, OLA was able to calculate a combined site EUI for the building. The building used approximately 89.1 kBtu/ft<sup>2</sup> site energy and had a total energy cost of \$26,347 based on 2016-2018 data. Table 31 below provides a summary of the annual energy usage and costs for 2016-2018.

Table 31. 2016-2018 Annual Overall Site Energy						
	Energy Usage	kBtu	Cost (\$)	Cost (\$) per ft <sup>2</sup>	Site EUI (kBtu/ft²)	CO2 Emissions (lb/year)
Electric (kWh)	109,680	374,228	\$26,347	\$6.57	89.1	69,872
Total		374,228	\$26,347	\$6.57	89.1	69,872
Gross Area (ft <sup>2</sup> )		4,200				

### 8.02.1 Electrical Usage

The historical electric usage for the Chemka Pool building is shown in Figure 43. Peak electricity usage occurs during the summer months (May – September), due to the continuous operation of the pool equipment. The highest monthly usage recorded during this time was 20,240 kWh during June 2017.




Figure 43. 2016 – 2018 Historical Electricity Use

The historical electric demand is shown in Figure 44. Similar to the historical electricity usage above, the building's peak demand occurs between May and September. The highest recorded demand of 107.2 kW occurred in August 2018.




Figure 44. 2016 – 2018 Historical Electric Demand

OLA was provided with complete electric utility bills for this analysis, and determined an average blended electricity rate of 0.240 \$/kWh based on the bills provided.

### 8.02.2 Utility Rates and Costs

The Chemka Pool building is served by one (1) electric meter. Estimated demand, energy, and total blended electric rates for the building were determined based on monthly usage and monthly charges. For the purposes of this study, electricity energy cost savings were based on average demand and energy charges. Table 32 below shows a breakdown of the utility rates for each fuel source.

Table 32. Utility Rates						
Utility	Unit	2016/17	2017/18	Average		
	\$/kW	\$33.21	\$36.04	\$34.62		
Electric	\$/kWh	\$0.077	\$0.072	\$0.074		
Liootilo	\$/kWh (Blended)	\$0.229	\$0.251	\$0.240		

# 8.02.3 Energy Utilization

Figure 45 below shows the breakdown of energy intensity (kBtu/ft<sup>2</sup>) by end use type. The pumping energy for the pool filtration system accounts for 64% of the total electricity usage.




Figure 45. Energy End Use Breakdown in kBtu/ft.<sup>2</sup>

### 8.03 Energy Efficiency Measures (EEMs)

### Short Term EEM's

### 8.03.1 EEM 1 – Complete LED Lighting Retrofit

Although much of the space has already been converted to LED lighting, this measure investigates the impact of a complete LED retrofit and energy consumption of reduced lighting power density. The new LED lighting will result in a reduced lighting power density and potential for high savings. All of the typical 23W fluorescent and 32W T8 fluorescent lighting in the building could be replaced with LED retrofit products. The existing lighting power density of the building is estimated to be 0.33 W/ft<sup>2</sup>. The resulting lighting power density of the entire facility is estimated to be in the range of 0.19 W/ft.<sup>2</sup> after a complete retrofit.

### 8.03.1 EEM 2 – Variable Speed Pumps and High Efficiency Motors

This measure assesses the impact of installing variable frequency drives (VFD's) and high efficiency motors on the pumps serving the three (3) different pools on site. Allowing the pool pumps to modulate to lower speeds during unoccupied hours would result in a significant energy and cost reduction.

### 8.03.2 EEM 3 – Air Source VRF Heat Pump for Pool Equipment Room

This measure assesses the energy reduction associated with installing a single-zone air source heat pump to heat and cool the pool equipment room. Air source heat pumps typically offer high heating and cooling efficiencies, which could result in an overall EUI reduction and cost savings. Indoor units would be installed where appropriate, providing heating and cooling to the spaces they serve.



Figure 46. Single-zone Mitsubishi air-source heat pump

### 8.03.3 EEM 4 – Domestic Hot Water Heat Pumps

Replacing the existing electric resistance domestic hot water heaters with a commercial grade electric heat pump system should be considered in the future. It is possible to utilize the existing storage tanks. Providing the building with a new high efficient electric heat pump water heater would reduce the source EUI of the building.



Figure 47. Colmac DHW heat pump

## Long Term EEM's

### 8.03.4 EEM 5 – Solar Tube Skylight

This measure assess the impact of installing skylights on the roof of the building that utilize natural daylight for lighting in the pool building locker rooms. Solar tube technology harnesses and transfers natural sunlight into the space with reflective material within the tubing. This would offset a portion of the energy usage and costs associated with lighting, thereby reducing greenhouse gas emissions.



Figure 48. Typical skylight diagram



Figure 49. "Solatube" skylight installed in locker room

## 9.0 Department of Public Works (DPW) Garage

### 9.01 Existing Conditions

The Department of Public Works (DPW) garage is a 1-story, 12,000 square foot garage located at 69 Southside Avenue in Hastings-on-Hudson, NY and was constructed in approximately 1985. The building acts as a storage and maintenance facility for the vehicles and associated equipment used for public service in the town. One half of the garage is used as a repair shop, and contains offices, restrooms, and a lounge for the mechanics. The other half is used as storage for the vehicles. Photos 87 and 88 show an aerial and exterior view of the building.





Photo 87. Aerial view of DPW garage

Photo 88. DPW Garage exterior

Typical building hours for the garage range from 7:00am – 3:30pm Monday through Friday, and 8:00am – 12:00pm on Saturdays. The garage is closed on Sundays. A breakdown of the building operating hours is shown below in Table 33.

	Table 33. DPW Garage Operating Hours										
Time	Monday	Tuesday	Wednesday	Thursday	Friday	Weekend					
7:00am	Building opens	Building opens	Building opens	Building opens	Building opens	Saturday: 8:00am – 12:00pm					
3:30pm	Building closes	Building closes	Building closes	Building closes	Building closes	Sunday: Building closed					

### 9.01.1 Existing Heating Systems

Heating for the garage is provided by a combination of an American Standard condensing gas-fired furnace serving the repair shop (Photo 89), and Reznor gas-fired unit heaters serving the remainder of the garage (Photo 90). A summary table of the heating systems at the DPW garage is located in Table 34 below.

	Table 34. DPW Garage Heating Plant Summary									
Manufacturer	Туре	Capacity (MBH)	Fuel Source	Quantity	Year Installed	Typical Operating Time				
American Standard	Furnace	-	Natural Gas	1		7:00am – 3:30pm				
Reznor	Unit Heater	75* (each)	Natural Gas	2		7:00am – 3:30pm				

\*Based on existing drawings



Photo 89. Gas-fired furnace serving repair shop



Photo 90. Typical gas-fired unit heater serving garage

The gas-fired furnace is located on an elevated platform and serves the open areas of the repair shop only. The offices, restrooms, and lounge area are all considered enclosed spaces and are not adequately heated by the furnace. Heating for these spaces is provided only by plug-in heaters and radiators (Photo 91). There is an additional office that is served by electric baseboard and controlled be a wall-mounted Lux thermostat (Photo 92). It was noted that only two (2) of the unit heaters serving the garage have been replaced and are currently functioning (Photo 93). The remaining unit heaters have been dysfunctional for several years according to staff and are abandoned in place.



Photo 90. Typical plug-in space heater



Photo 92. Thermostat controlling electric baseboard



Photo 93. Typical gas-fired unit heater abandoned in place

Heating for the repair shop is controlled by a wall-mounted programmable Honeywell thermostat located outside one of the offices (Photo 94). It was noted that staff typically set the thermostat for approximately 68°F during occupied hours, and will automatically reduce the temperature setpoint to approximately 62°F during unoccupied hours. Heating for the garage is also controlled by similar wall-mounted Honeywell thermostats (Photo 95). Each thermostat typically controls one of the Reznor unit heaters.





Photo 94. Thermostat controlling gas-fired furnace Photo

Photo 95. Typical thermostat controlling unit heater

### 9.01.2 Existing Cooling Systems

Cooling is provided by a combination of window AC units serving the offices and lounge within the repair shop, and ceiling fans in the garage. There are four (4) Friedrich window AC units that serve the offices and lounge. Each window AC unit has an approximate capacity of 1 - 1.5 tons (12-18 MBH) of cooling, and is controlled manually A summary of the window AC units serving the building is shown below in Table 35.

Table 35. DPW Garage Cooling Plant Summary							
Туре	Manufacturer	Total Capacity	Estimated				
		(Tons)	Total Quantity				
Window AC unit	Friedrich	1 – 1.5	4				

### 9.01.3 Existing Ventilation Systems

There is no mechanical ventilation system serving the garage. Ventilation is provided only by opening the garage doors.

### 9.01.4 Existing Domestic Water Systems

Domestic hot water (DHW) is generated by one (1) combination gas-fired Rheem DHW heater and storage tank located in the repair shop (Photo 96). The DHW heater has a total input capacity of 38 MBH and storage capacity of 40 gallons. A summary of the DHW system is shown below in Table 36.

Table 36. DPW Garage DHW System Summary							
Manufacturer	Fuel Source	Heating Capacity (MBH)	Storage Capacity (Gal)	Quantity	Year Installed		
Rheem	Natural Gas	30	40	1	2003		



Photo 82. Rheem DHW heater

## 9.01.5 Existing Lighting System

Interior lighting primarily consists of T8 fluorescent light fixtures in offices, restrooms, and the lounge area, ceiling hung metal halide fixtures in the repair shop, and ceiling hung high pressure sodium (HPS) fixtures in the remainder of the garage (Photos 97 - 99).



Photo 97. Typical T8 fluorescent light fixtures




Photo 98. Typical metal halide light fixtures



Photo 99. Typical HPS light fixtures

## 9.01.6 Existing Lighting Controls


All interior lighting is manually controlled by toggle switches.

### 9.02 DPW Garage Analysis of Present Energy Use

A historical energy use analysis was performed for the energy sources at the DPW Garage. The following data was analyzed based on yearly energy consumption and costs. Based on the utility bills provided, OLA was able to calculate a combined site EUI for the building. The building used approximately 66.3 kBtu/ft<sup>2</sup> site energy and had a total energy cost of \$13,053 based on 2016-2018 data. Table 37 below provides a summary of the annual energy usage and costs for 2016-2018.

Table 37. 2016-2018 Annual Overall Site Energy									
	Energy Usage	kBtu	Cost (\$)	Cost (\$) per ft <sup>2</sup>	Site EUI (kBtu/ft <sup>2</sup> )	CO2 Emissions (lb/year)			
Electric (kWh)	35,091	122,494	\$5,792	\$0.48	10.2	22,871			
Natural Gas (therm)	6,728	672,800	\$7,262	\$0.61	56.1	78,776			
Total		795,294	\$13,053	\$1.09	66.3	101,647			
Gross Area (ft <sup>2</sup> )		12,000							

Figure 50 provides the annual site EUI per energy type based on analysis of the utility bills for 2016-2018. Figure 51 provides the annual energy cost summary by energy type from the same year. Natural gas for heating is the dominant energy source for this building, and accounts for 85% of the overall energy consumption of the building. However, natural gas only accounts for 56% of the cost, due to the higher cost of electricity. Figure 52 provides the annual CO<sub>2</sub> emissions breakdown by energy type.



Natural Gas 78,776 77%

Figure 52. Existing Annual CO<sub>2</sub> Emissions Breakdown in Ib/year

### 9.02.1 Electrical Usage

The historical electric usage for the DPW Garage is shown in Figure 53. Peak electricity usage typically occurs during the winter months for this building, likely due to electric heaters, and because there is no form of cooling at the facility. The highest monthly usage recorded during this time was 5,310 kWh during January 2018.




Figure 53. 2016 – 2018 Historical Electricity Use

The historical electric demand is shown in Figure 54. Similar to the historical electricity usage above, the building's peak demand typically occurs during the winter months. The highest recorded demand of 14.6 kW occurred in February 2018.




Figure 54. 2016 – 2018 Historical Electric Demand

OLA was provided with complete electric utility bills for this analysis, and determined an average blended electricity rate of 0.161 \$/kWh based on the bills provided.

### 9.02.2 Natural Gas Usage

Figure 55 below shows the historical 2016-2018 natural gas usage for the building. Since gas in this building is used for heating only, usage is found to be highest during the winter months. A peak usage of 2,374 therms was recorded in February 2017.




Figure 55. 2016-2018 Historical Natural Gas Usage

OLA was provided with complete utility bills for this analysis and determined a natural gas of 1.08 \$/therm based on the bills provided. For the purposes of this study, this calculated rate was used to estimate energy cost savings.

### 9.02.3 Utility Rates and Costs

The DPW garage is served by one (1) electric meter and one (1) gas meter. Estimated demand, energy, and blended electric and gas rates for the building were determined based on monthly usage and monthly charges. For the purposes of this study, all energy cost savings were based on calculated average utility rates. Electricity energy cost savings were based on average demand and energy charges. Table 38 below shows a breakdown of the utility rates for each fuel source.

Table 38. Utility Rates								
Utility	Unit	2016/17	2017/18	Average				
	\$/kW	\$25.21	\$27.33	\$26.27				
Electric	\$/kWh	\$0.061	\$0.065	\$0.063				
Liouno	\$/kWh (Blended)	\$0.160	\$0.162	\$0.161				
Natural Gas	\$/therm	\$1.06	\$1.10	\$1.08				

## 9.02.4 Energy Utilization

Figure 56 below shows the breakdown of energy intensity (kBtu/ft<sup>2</sup>) by end use type. The results confirm that fuel consumed to run the heating plant accounts for the largest portion of the site energy use and cost.




Figure 56. Energy End Use Breakdown in kBtu/ft.<sup>2</sup>

### 9.03 Energy Efficiency Measures (EEMs)

### Short Term EEM's

### 9.03.1 EEM 1 – LED Lighting Retrofits

This measure investigates the impact on energy consumption of reduced lighting power density utilizing high efficiency LED lighting technology and retrofit products throughout the building. The new LED lighting will result in a reduced lighting power density and potential for high savings. All of the typical 32W T8 fluorescent lighting and HPS / metal halide flood lighting in the building could be replaced with LED retrofit products. The existing lighting power density of the building is estimated to be 0.33 W/ft<sup>2</sup>. The resulting lighting power density of the entire facility is estimated to be in the range of 0.16 W/ft.<sup>2</sup> after a complete retrofit.

### Long Term EEM's

### 9.03.2 EEM 2 – Air Source VRF Heat Pump for Repair Shop

This measure assesses the energy reduction associated with installing a multi-zone air source heat pump with variable refrigerant flow (VRF) to heat the repair shop and adjacent office spaces. Air source heat pumps typically offer high heating and cooling efficiencies, which could result in an overall EUI reduction and cost savings. Indoor units would be installed where appropriate, providing heating and cooling to the spaces they serve.



Figure 57. City-Multi VRF heat pump units

## 10.0 Energy Efficiency Measure (EEM) Summary

Table 39 summarizes the results of the energy analysis for the EEMs investigated.

Participant's Name and Address: Village of Hastings-on-Hudson Maple Avenue Vastings-on-Hudson, NY ENERGY EFFICIENCY MEASURE SUMMARY																
Measure Description	Measure Status (See Notes)	Building Electricity Usage (kWh)	Building Oil Usage (gallons)	Building Gas Usage (therms)	Building Energy Use (kBtu/ft <sup>2</sup> )	Electricity Saved (kWh)	Natural Gas Saved (therms)	Site Energy Saved (kBtu/ft <sup>2</sup> )	Demand Saved (kW)	CO2 Emissions Saved (Ib/year)	Annual Utility Cost (\$/year)				Estimated Cost for Implementation (\$)	Simple Payback (Total Cost Basis)
Village Hall and Library								1		1					r	
Existing Building (Combined 2017-2018 U		252,360	2,621	12,107	102.4	-	-	-	-	-	\$58,494	-	-	-	-	-
Existing Building (Adjusted Baseline Usage - 0	Gas Only)	252,360	0	16,027	103.4	-	-	-	-	-	\$56,601	-	-	-	-	-
EEM 1 Village Hall LED Lighting Retrofit and Lighting Controls Upgrade	R	244,039	0	16,027	102.2	8,321	0	1.2	2.7	5,301	\$55,994	\$608	\$0	\$608	\$16,000	26.3
EEM 2 Library Lighting Controls and Daylighting Upgrade	R	241,260	0	16,027	101.9	2,780	0	0.4	0	1,771	\$55,808	\$185	\$0	\$185	\$10,000	53.9
EEM 3 Building Envelope Upgrades - New Windows	R	241,260	0	14,917	97.2	0	1,110	4.7	0	12,995	\$54,569	\$0	\$1,239	\$1,239	\$362,000	292.2
EEM 4 Building Envelope Upgrades - Wall Insulation and Air Barrier	R	241,260	0	13,702	92.1	0	1,215	5.1	0	14,227	\$53,213	\$0	\$1,356	\$1,356	\$160,000	118.0
EEM 5 Steam Boiler Replacement	R	241,260	0	13,225	90.1	0	476	2.0	0	5,577	\$52,681	\$0	\$532	\$532	\$165,000	310.3
EEM 5A Condensing Gas-Fired Hot Water Boilers	R	241,260	0	12,197	85.8	0	1,505	6.3	0	17,621	\$51,533	\$0	\$1,680	\$1,680	\$593,000	353.0
EEM 5B Geothermal Heat Pumps for VH	RS	273,494	0	7,842	72.1	-32,235	5,860	20.0	-25.0	48,078	\$50,431	-\$3,759	\$6,541	\$2,782	\$1,100,000	395.4
EEM 5C Air Source VRF Heat Pumps for VH	R	280,701	0	7,842	73.1	-39,441	5,860	19.0	-28.4	43,487	\$52,457	-\$5,785	\$6,541	\$756	\$256,000	338.6
Air Source VRF Heat Pumps for VH EEM 5D + Condensing Gas-Fired Hot Water Boiler for Library	R	280,701	0	7,052	69.8	-39,441	6,650	22.3	-28.4	52,738	\$51,575	-\$5,785	\$7,423	\$1,638	\$490,000	299.1
EEM 6 Library Roof-Mounted Solar PV System	RS	199,289	0	13,702	86.1	41,971	0	6.0	0	26,738	\$50,292	\$2,921	\$0	\$2,921	\$145,000	49.6
EEM 7 Library AHU Replacement	R	225,321	0	13,702	89.8	15,939	0	2.3	0	10,154	\$52,191	\$1,022	\$0	\$1,022	\$324,000	316.9
EEM 8 Village Hall / Library Plug Load Management and Reduction	R	234,020	0	13,702	91.1	7,240	0	1.0	0	4,612	\$52,749	\$464	\$0	\$464	\$47,000	101.2
James Harmon Community Center											-					
Existing Building (Adjusted Baseline Usa		209,400	0	11,691	110.8	-	-	-	-	-	\$43,027	-	-	-	-	-
EEM 1 LED Lighting Retrofits	R	203,315	0	11,691	109.6	6,085	0	1.2	2.4	3,877	\$42,578	\$449	\$0	\$449	\$16,000	35.6
EEM 2 Rescheduling of RTU's	R	196,770	0	11,691	108.3	6,545	0	1.3	0	4,169	\$42,161	\$417	\$0	\$417	\$1,200	2.9
EEM 3 Variable Frequency Drives (VFD's) on RT-3 and RT-4	R	182,057	0	11,691	105.3	14,713	0	3.0	0	9,373	\$41,223	\$937	\$0	\$937	\$36,000	38.4
EEM 4 Condensing Gas-Fired Hot Water Boiler	RS	182,057	0	10,311	97.2	0	1,380	8.1	0	16,164	\$39,705	\$0	\$1,518	\$1,518	\$191,000	125.9
EEM 5 Supplemental Domestic Hot Water Heat Pump	RS	183,468	0	10,154	96.6	-1,411	157	0.6	-1.5	935	\$39,662	-\$128	\$172	\$44	\$20,000	456

Measure Status: Recommended (R); Further Study Recommended (RS)

Notes:

1.) Energy and cost savings for all EEM's are considered incremental. Savings for a particular measure is calculated assuming the preceding measure has been implemented.

2.) Village Hall - Library EEM's 5 - 7 are designated as long term. Savings for long term EEM's are based on EEM 4, and are not incremental (i.e. EEM 7 is not incremental to EEM 6).

3.) Village Hall - Library EEM 8 savings is based on EEM 4 and is not incremental to long term EEM's 5 - 7.

Hook and Ladder Company																
Existing Building (Adjusted Baseline U	sage)	8,646	0	6,362	74.0	-	-	-	-	-	\$7,419	-	-	-	-	-
EEM 1 LED Lighting Retrofit	R	6,828	0	6,362	73.3	1,818	0	0.7	1.1	1,158	\$7,267	\$152	\$0	\$152	\$6,000	39.5
EEM 2 Lighting Controls Upgrade	R	6,354	0	6,362	73.1	474	0	0.2	0	302	\$7,227	\$40	\$0	\$40	\$6,000	151.4
EEM 3 Hot Water Piping Insulation	R	6,354	0	5,997	69.0	0	365	4.1	0	4,274	\$6,827	\$0	\$400	\$400	\$3,300	8.2
EEM 4 Heating Night Setback	R	6,354	0	4,668	54.3	0	1,329	14.8	0	15,562	\$5,369	\$0	\$1,458	\$1,458	\$7,000	4.8
EEM 5 Condensing Gas-Fired Hot Water Boiler	RS	6,354	0	4,195	49.0	0	473	5.3	0	5,542	\$4,850	\$0	\$519	\$519	\$80,000	154.1
Ambulance Corps Garage											•	•	•	•		
Existing Building (Adjusted Baseline U	sage)	12,121	0	1,978	99.7	-	-	-	-	-	\$4,937	-	-	-	-	-
EEM 1 LED Lighting Retrofit	R	10,069	0	1,978	96.7	2,052	0	2.9	0.8	1,307	\$4,391	\$546	\$0	\$546	\$7,000	12.8
EEM 2 Heating Night Setback	R	10,069	0	1,479	75.9	0	499	20.8	0	5,847	\$3,694	\$0	\$697	\$697	\$2,000	2.9
Chemka Pool Building																
Existing Building		109,680	0	0	89.1	-	-	-	-	-	\$26,347	-	-	-	-	-
EEM 1 Complete LED Lighting Retrofit	R	109,138	0	0	88.7	542	0	0.4	0.6	346	\$26,287	\$60	\$0	\$60	\$3,000	50.3
EEM 2 Variable Speed Pumps and High Efficiency Motors	R	68,797	0	0	55.9	40,340	0	32.8	0	25,699	\$23,310	\$2,977	\$0	\$2,977	\$83,000	27.9
EEM 3 Air Source VRF Heat Pump for Pool Equipment Room	R	67,148	0	0	54.6	1,649	0	1.3	6.7	1,050	\$23,235	\$75	\$0	\$75	\$12,000	159.8
EEM 4 Domestic Hot Water Heat Pumps	RS	63,386	0	0	51.5	3,762	0	3.1	7.5	2,397	\$22,696	\$539	\$0	\$539	\$56,000	103.9
EEM 5 Solar Tube Skylight	R	62,852	0	0	51.1	534	0	0.4	0	340	\$22,568	\$128	\$0	\$128	\$44,000	342.8
DPW Garage																
Existing Building (Adjusted Baseline U	sage)	35,901	0	8,077	77.5	-	-	-	-	-	\$13,053	-	-	-	-	-
EEM 1 LED Lighting Retrofit	R	30,101	0	8,077	75.9	5,800	0	1.6	2.1	3,695	\$12,631	\$422	\$0	\$422	\$11,000	26.0
EEM 2 Air Source VRF Heat Pumps for Repair Shop	RS	54,151	0	4,894	56.2	-24,051	3,183	19.7	-17.0	37,272	\$13,401	-\$4,199	\$3,429	-\$770	\$130,000	
Measure Status: Recommended (R); Further	Study Recon	nmended (RS	)													

Notes:

L) Energy and cost savings for all EEM's are considered incremental. Savings for a particular measure is calculated assuming the preceding measure has been implemented.
 L) Village Hall - Library EEM's 5 - 7 are designated as long term. Savings for long term EEM's are based on EEM 4, and are not incremental (i.e. EEM 7 is not incremental to EEM 6).
 Village Hall - Library EEM's 5 - 7 are designated as long term. Savings for long term EEM's are based on EEM 4, and are not incremental (i.e. EEM 7 is not incremental to EEM 6).
 Village Hall - Library EEM 8 savings is based on EEM 4 and is not incremental to long term EEM's 5 - 7.

## **11.0 Recommendations for Strategic Implementation**

This section is provided to clarify the sequence and scope of our recommendations and implementation and provide commentary on the recommended measures. This section will be update after a review discussion with the Village of Hastings to develop a prioritization of EEMs. Please note that costs are preliminary and should be further explored, designed and bid to establish reliable costs for implementation. These costs are for "order of magnitude" only and should be understood to be preliminary and not for budgeting purposes.

	1		Table 40. Recommended Sequence for Implementation				1
				CO2 Emissions	Annual Energy Cost		Simple
Time Period	Building			Saved	Saved	Implementation	
(Implementation)	Key		EEM	(lb/year)	(\$/yr)	Costs	(years)
	HL	EEM 4	Hook and Ladder - Heating Night Setback	15,562	\$1,458	\$7,000	5
	AC	EEM 2	Ambulance Corps - Heating Night Setback	5,847	\$697	\$2,000	3
Short Term	HL	EEM 3	Hook and Ladder - Hot Water Piping Insulation	4,274	\$400	\$3,300	8
Low Cost EEM's	CC	EEM 2	Community Center - Rescheduling of RTU's	4,169	\$417	\$1,200	3
	AC	EEM 1	Ambulance Corps - LED Lighting Retrofit	1,307	\$546	\$7,000	13
	CP	EEM 1	Chemka Pool Building - Complete LED Lighting Retrofit	346	\$60	\$3,000	50
	HL	EEM 1	Hook and Ladder - LED Lighting Retrofit	1,158	\$152	\$6,000	39
	HL	EEM 2	Hook and Ladder - Lighting Controls Upgrade	302	\$40	\$6,000	151
	DPW	EEM 1	DPW Garage - LED Lighting Retrofit	3,695	\$422	\$11,000	26
	LI	EEM 2	Library - Lighting Controls and Daylighting Upgrade	1,771	\$185	\$10,000	54
	VH	EEM 1	Village Hall - LED Lighting Retrofit and Lighting Controls Upgrade	5,301	\$608	\$16,000	26
	VH / LI	EEM 8	Village Hall / Library Plug Load Management and Reduction	4,612	\$464	\$47,000	101
Remaining Short	CC	EEM 1	Community Center - LED Lighting Retrofits	3,877	\$449	\$16,000	36
Term EEM's	СР	EEM 2	Chemka Pool Building - Variable Speed Pumps and High Efficiency Motors	25,699	\$2,977	\$83,000	28
	СС	EEM 3	Community Center - Variable Frequency Drives (VFD's) on RT-3 and RT-4	9,373	\$937	\$36,000	38
	CP	EEM 4	Chemka Pool Building - Domestic Hot Water Heat Pumps	2,397	\$539	\$56,000	104
CP EEM 3		EEM 3	Chemka Pool Building - Air Source VRF Heat Pump for Pool Equipment Room	1,050	\$75	\$12,000	160
	DPW	EEM 2	DPW Garage - Air Source VRF Heat Pumps for Repair Shop	37,272	-\$770	\$130,000	-
	VH	EEM 4	Village Hall - Building Envelope Upgrades: Wall Insulation and Air Barrier	14,227	\$1,356	\$160,000	118
	VH	EEM 3	Village Hall - Building Envelope Upgrades: New Windows	12,995	\$1,239	\$362,000	292
			Village Hall / Library - Steam Boiler Replacement	5,577	\$532	\$165,000	310
		EEM 5,	Village Hall / Library - Condensing Gas-Fired Hot Water Boilers	17,621	\$1,680	\$593,000	353
	VH/LI	5A, 5B,	Village Hall - Geothermal Heat Pumps	48,078	\$2,782	\$1,096,750	394
Long Term		5C, 5D	Village Hall - Air Source VRF Heat Pumps	43,487	\$756	\$256,000	339
EEM's		30, 3D	Village Hall / Library - Air Source VRF Heat Pumps and Condensing Gas-Fired Hot Water Boiler	52,738	\$1,638	\$490,000	299
	LI	EEM 6	Library - Roof-Mounted Solar PV System	26,738	\$2,921	\$145,000	50
	LI	EEM 7	Library - AHU Replacement	10,154	\$1,022	\$324,000	317
	CP	EEM 5	Chemka Pool Building - Solar Tube Skylight	340	\$128	\$44,000	343
	CC	EEM 4	Community Center - Condensing Gas-Fired Hot Water Boiler	16,164	\$1,518	\$191,000	126
	HL	EEM 5	Hook and Ladder - Condensing Gas-Fired Hot Water Boiler	5,542	\$519	\$80,000	154
	СС	EEM 5	Community Center - Supplemental Domestic Hot Water Heat Pump	935	\$44	\$20,000	456

CC - James Harmon Community Center

CP - Chemka Pool Building

DPW - DPW Garage

HL - Hook and Ladder Company

LI - Library

VH - Village Hall

### 1. Low-cost measures

Several buildings can benefit from simple low-cost measures like programmable set-back thermostats, pipe insulation, proper scheduling of equipment, and simple LED retrofits. Regarding scheduling and thermostats, occupants of the buildings should be educated that the goal is operate at a high efficiency without energy waste, and on how to mitigate unnecessary energy use by using the night setback.

Simple screw-in and swap-in retrofits for LED lights in the Pool building and Ambulance corps can also be prioritized.

### 2. LED Lighting and Lighting Controls

Additional LED lighting retrofits and lighting controls are cost effective measures that should also be prioritized. Some buildings may require more elaborate retrofit kits or fixture replacements such as in the Community Center, but many can use T8 retrofit products. The lighting controls recommended for various buildings include occupancy sensors and daylight sensing in various locations. These are fairly easy to implement and can be preferably all be done as part of a larger lighting upgrade project Village wide.

Continuing to trend energy costs and consumption to try to approach high performance operation will emphasize the importance of optimizing the building operation.

### 3. Variable Speed Drives for RTUs and Pool pumps

Some HVAC can benefit from the use of variable speed drives to save energy. These measures have the potential to save considerable energy and associated GHG emissions for the Community Center RTU's and the Pool pump motors. The measures have a reasonable payback and make sense to prioritize after the lower cost measures.

### 4. Air-source heat pumps (Space Heat)

Several measures look at using cold-climate air-source heat pumps in lieu of electric resistance heat or in the case of the DPW garage, gas fired heat. In the case of the Pool building, a small heat pump to heat the mechanical room is preferable to electric resistance heat and can cut GHGs. For the DPW Garage, it appeared that an air-source heat pump system could provide additional benefits of providing cooling as well as heat to the office spaces, some of which only have space heaters that provide poor or no temperature control, and only have window units for cooling. Heat pump systems have the ability to reduce GHGs significantly.

### 5. Village Hall Envelope Improvements

Several measures looked at improving the envelope (windows and walls) of the Village Hall. Given the age of the building, these measures would obviously be capital intensive, but do have the benefit of reducing building loads, reducing GHGs significantly, and likely improving occupant comfort. These may be considered longer term measures. We would recommend considering these measures before investing in the heating system however, in order to optimize any future heating plant, and reduce equipment sizing requirements.

## 6. Village Hall / Library Heating System

The Village Hall and Library heating system is currently shared. This study looked at several options to improve the energy performance and reduce GHGs for both buildings. Both geothermal and air-source heat pump systems were considered as a replacement heating system for the Village Hall. The geothermal option does have the potential to save more energy than an air-source heat pump, however it comes with significantly higher capital cost. We also determined that a geothermal system likely cannot serve both Village Hall and Library due to lack of available land area.

Recent improvements in cold-climate air-source heat pumps would make it possible to heat the Village Hall building and avoid using the boiler. The boiler could be retained to heat just the Library, and eventually replaced in the future with a condensing gas boiler to heat the Library. This is a cost effective approach since the Library already has a hydronic heating system. At the request of HEWG, OLA reviewed the possibility of installing air source heat pumps solely for the Police Station. It is estimated that this project would cost in the range of \$80,000 - \$90,000, and could serve as the first initial phase of EEM's 5C / 5D if these measures are implemented. The Police Station operates 24/7 and therefore

is likely to provide the greatest savings benefit for the building overall. Note that the existing emergency power capacity would need to be reviewed as part of this design effort.

### 7. Library AHU Replacement

The Library main air-handling unit (HV-1) is original to the building, past its expected useful life and should be planned for eventual replacement. The existing system use constant speed fans, but a future modern system would use variable speed fans for energy savings. This is capital intensive project, but should be considered for the future.

### 8. Community Center and Hook & Ladder Condensing Boilers

These buildings all have existing hydronic heating systems with boilers that are not too old. Eventually the equipment may need to be replaced, and the current best available boiler technology would be condensing boilers to improve efficiency and reduce emission.

### 9. Heat Pump Domestic Hot Water Heaters

Several buildings can benefit from using heat-pump water heaters, particularly the Pool building which likely has more of a hot water load and uses electric resistance heaters. The Community Center water heater is not at the end of its useful life yet, but eventually could be replaced with a heat-pump water heater.

# 12.0 Appendices

Appendix A:

Energy Star Target Finder Results



ENERGY STAR<sup>®</sup> Statement of Energy Design Intent (SEDI)<sup>1</sup> Ambulance Corps



Primary Property Type: Fire Station Gross Floor Area (ft<sup>2</sup>): 2,400 Estimated Date of Certification of Occupancy:

Date Generated: March 04, 2019

## ENERGY STAR® Design Score<sup>2</sup>

1. This form is required when applying for Designed to Earn the ENERGY STAR recognition. It was generated from ENERGY STAR Portfolio Manager.

2. The ENERGY STAR 1 – 100 Score is based on total annual Source Energy. To be eligible for Designed to Earn the ENERGY STAR recognition you must score at least 75.

Property & Contact Information for D	Design Project	
Property Address	Project Architect	Owner Contact
Ambulance Corps		
47 Main Street	,	,
Hastings-on-Hudson, New York 10706	() <u>-</u>	()
Property ID: 6664032	Architect Of Record	Property Owner
	, ,	, ()

Estimated Design Energy		
Fuel Type	Usage	Energy Rate (\$/Unit)
Electric - Grid	12,121 kWh (thousand Watt-hours)	\$ 0.27/kWh (thousand Watt-hours)
Natural Gas	1,225 therms	\$ 1.40/therms

Estimated Design Use Details							
🛱 This Use Detail is used to calculate the 1-100 ENERGY STAR Score.							
Fire Station							
Weekly Operating Hours	168						
Number of Workers on Main Shift	5						
Number of Computers	4						
🛧 Gross Floor Area	2,400 Sq. Ft.						

Design Energy and Emission Results			
Metric	Design Project	Median Property	Estimated Savings
ENERGY STAR Score (1-100)	N/A	50	N/A
Energy Reduction (from Median)(%)	-18.4	0	N/A
Source Energy Use Intensity (kBtu/ft²/yr)	101	124	23
Site Energy Use Intensity (kBtu/ft²/yr)	68	83	15
Source Energy Use (kBtu/yr)	244,424	299,681	55,257
Site Energy Use (kBtu/yr)	163,856	200,900	37,044
Energy Costs (\$)	4,939	6,055	1,116
Total GHG Emissions (Metric Tons CO2e)	10	12	2


Designed to Earn the ENERGY STAR: Application Checklist		
This section is only required if you are using this document to apply for Designed to Earn the ENERGY STAR. All design projects that achieve an EPA energy performance score of 75 or higher are eligible for this certification.		
<ol> <li>Does your <u>property type</u> match the function or use of a property that's eligibility to receive an ENERGY STAR design score?</li> </ol>	Yes	No/Not Sure
If you are not sure your project is eligible for an ENERGY STAR design score, please describe the property's major functions or use:		
<ul><li>2) Is the design project at least 95% complete with construction documents?</li><li>If no, please explain:</li></ul>	Tes Yes	No No
3) Is the property currently unoccupied and not yet generating energy bills?	Yes	No No
4) Do energy calculations account for the whole building intended operations and all energy sources?	Yes	No No
5) Is the Architect of Record (AOR) applying for ENERGY STAR partnership?	Yes	No No
6) Was the design record created in the owner's Portfolio Manager account?	Yes	No No
<ul><li>7) Are you seeking other qualifications for this design project?</li><li>If so, please select all that apply:</li></ul>	Yes	No No
<ul> <li>AIA 2030 Commitment</li> <li>Architecture 2030 Challenge</li> <li>Federal, State or Local Disclosure Ordinance</li> <li>Green Globes</li> <li>LEED</li> <li>Other, please indicate:</li> </ul>		

I \_\_\_\_\_\_ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature:	Date:	
Verifying Professional		
, ()		



**Note**: When applying for the ENERGY STAR Designed to Earn, the signature of the Verifying Professional must match the stamp.



I agree to adhere to the ENERGY STAR Identity Guidelines when using the Designed to Earn the ENERGY STAR recognition graphic in association with this project.

### Architect of Record Acknowledgement

As the Architect of Record representative, I confirm that the information on this SEDI is true and accurate to the best of my knowledge. It is our best estimate for all energy use of specified systems and processes but does not guarantee the operational performance of this building. Instead, this project has been specified to achieve Designed to Earn the ENERGY STAR recognition in an effort to assist the Owner/Developer in meeting their operational performance goal for the building to earn ENERGY STAR certification.

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

### **Building Owner/Developer Acknowledgement**

As the Building Owner/Developer representative, I concur that this project be nominated for Designed to Earn the ENERGY STAR recognition. Our organization understands the importance of measuring actual energy use in Portfolio Manager after receiving the Certificate of Occupancy to verify that this property is performing as intended. We understand that once the building earns an ENERGY STAR score of 75 or higher, it may be eligible for ENERGY STAR certification.

Signature: _	
--------------	--



ENERGY STAR<sup>®</sup> Statement of Energy Design Intent (SEDI)<sup>1</sup> Chemka Pool Building



Primary Property Type: Other - Entertainment/Public Assembly Gross Floor Area (ft<sup>2</sup>): 4,200 Estimated Date of Certification of Occupancy: \_\_\_\_\_

Date Generated: March 04, 2019

## ENERGY STAR® Design Score<sup>2</sup>

Design Coole

1. This form is required when applying for Designed to Earn the ENERGY STAR recognition. It was generated from ENERGY STAR Portfolio Manager.

2. The ENERGY STAR 1 – 100 Score is based on total annual Source Energy. To be eligible for Designed to Earn the ENERGY STAR recognition you must score at least 75.

Property & Contact Information for Design Project			
Property Address	Project Architect	Owner Contact	
Chemka Pool Building			
Hillside Avenue	, ( )	, ( )	
Hastings-on-Hudson, New York 10706	() <u></u>	() <del>-</del>	
Property ID: 6664188	Architect Of Record	Property Owner	
		, ( ) -	
	·, ·, ·	\/ <sup>_</sup>	

Estimated Design Energy		
Fuel Type	Usage	Energy Rate (\$/Unit)
Electric - Grid	109,680 kWh (thousand Watt-hours)	\$ 0.24/kWh (thousand Watt-hours)

### Estimated Design Use Details

lpha This Use Detail is used to calculate the 1-10	) ENERGY STAR Score.
Other - Entertainment/Public Assembly	
Weekly Operating Hours	60
Number of Workers on Main Shift	10
Number of Computers	2
🚖 Gross Floor Area	4,200 Sq. Ft.

Design Energy and Emission Results			
Metric	Design Project	Median Property	Estimated Savings
ENERGY STAR Score (1-100)	N/A	50	N/A
Energy Reduction (from Median)(%)	122.7	0	N/A
Source Energy Use Intensity (kBtu/ft <sup>2</sup> /yr)	249	112	-137
Site Energy Use Intensity (kBtu/ft²/yr)	89	40	-49
Source Energy Use (kBtu/yr)	1,047,839	470,430	-577,409
Site Energy Use (kBtu/yr)	374,228	168,011	-206,217
Energy Costs (\$)	26,323	11,817	-14,506
Total GHG Emissions (Metric Tons CO2e)	31	14	-17


Designed to Earn the ENERGY STAR: Application Checklist		
This section is only required if you are using this document to apply for Designed to Earn the ENERGY STAR. All design projects that achieve an EPA energy performance score of 75 or higher are eligible for this certification.		
<ol> <li>Does your property type match the function or use of a property that's eligibility to receive an ENERGY STAR design score?</li> </ol>	Yes	No/Not Sure
If you are not sure your project is eligible for an ENERGY STAR design score, please describe the property's major functions or use:	n	
2) Is the design project at least 95% complete with construction documents? If no, please explain:	Tes Yes	□ No
3) Is the property currently unoccupied and not yet generating energy bills?	Yes	No No
<b>4)</b> Do energy calculations account for the whole building intended operations and all energy sources?	Yes	No No
5) Is the Architect of Record (AOR) applying for ENERGY STAR partnership?	? 🛛 Yes	No No
6) Was the design record created in the owner's Portfolio Manager account?	Yes	No No
7) Are you seeking other qualifications for this design project? If so, please select all that apply:	Yes	🗋 No
<ul> <li>AIA 2030 Commitment</li> <li>Architecture 2030 Challenge</li> <li>Federal, State or Local Disclosure Ordinance</li> <li>Green Globes</li> <li>LEED</li> <li>Other, please indicate:</li> </ul>		

I \_\_\_\_\_\_ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature:	_Date:
Verifying Professional	
, ()	



**Note**: When applying for the ENERGY STAR Designed to Earn, the signature of the Verifying Professional must match the stamp.



I agree to adhere to the ENERGY STAR Identity Guidelines when using the Designed to Earn the ENERGY STAR recognition graphic in association with this project.

### Architect of Record Acknowledgement

As the Architect of Record representative, I confirm that the information on this SEDI is true and accurate to the best of my knowledge. It is our best estimate for all energy use of specified systems and processes but does not guarantee the operational performance of this building. Instead, this project has been specified to achieve Designed to Earn the ENERGY STAR recognition in an effort to assist the Owner/Developer in meeting their operational performance goal for the building to earn ENERGY STAR certification.

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

### **Building Owner/Developer Acknowledgement**

As the Building Owner/Developer representative, I concur that this project be nominated for Designed to Earn the ENERGY STAR recognition. Our organization understands the importance of measuring actual energy use in Portfolio Manager after receiving the Certificate of Occupancy to verify that this property is performing as intended. We understand that once the building earns an ENERGY STAR score of 75 or higher, it may be eligible for ENERGY STAR certification.

Signature:
------------



ENERGY STAR<sup>®</sup> Statement of Energy Design Intent (SEDI)<sup>1</sup> James Harmon Community Center



Primary Property Type: Mixed Use Property Gross Floor Area (ft<sup>2</sup>): 17,000 Estimated Date of Certification of Occupancy: \_\_\_\_\_

Date Generated: March 04, 2019

## ENERGY STAR® Design Score<sup>2</sup>

1. This form is required when applying for Designed to Earn the ENERGY STAR recognition. It was generated from ENERGY STAR Portfolio Manager.

2. The ENERGY STAR 1 – 100 Score is based on total annual Source Energy. To be eligible for Designed to Earn the ENERGY STAR recognition you must score at least 75.

Property & Contact Information for Design Project			
Property Address	Project Architect	Owner Contact	
James Harmon Community Center 44 Main Street			
Hastings-on-Hudson, New York 10706	, ()	, ()	
Property ID: 6664076	Architect Of Record	Property Owner	
		, ( ) -	
	( ) -	\/	

Estimated Design Energy		
Fuel Type	Usage	Energy Rate (\$/Unit)
Natural Gas	11,213 therms	\$ 1.10/therms
Electric - Grid	209,400 kWh (thousand Watt-hours)	\$ 0.15/kWh (thousand Watt-hours)

#### Estimated Design Use Details This Use Detail is used to calculate the 1-100 ENERGY STAR Score. Social/Meeting Hall **Other - Recreation** Weekly Operating Hours 40 Weekly Operating Hours 40 5 20 Number of Workers on Main Shift Number of Workers on Main Shift Number of Computers 0 Number of Computers 15 Gross Floor Area 3,000 Sq. Ft. Gross Floor Area 4,000 Sq. Ft. Office Weekly Operating Hours 40 Number of Workers on Main Shift 10 Percent That Can Be Cooled 50 % or more Number of Computers 10 Percent That Can Be Heated 50 % or more Gross Floor Area 10,000 Sq. Ft.


Design Energy	and Emission Results			
Metric		Design Project	Median Property	Estimated Savings
ENERGY STAR		N/A	50	N/A
	n (from Median)(%)	60.6	0	N/A
	Ise Intensity (kBtu/ft²/yr) Intensity (kBtu/ft²/yr)	186 108	116 67	-70 -41
Source Energy L		3,177,889	1,978,295	-1,199,594
Site Energy Use		1,835,773	1,142,803	-692,970
Energy Costs (\$)		43,116	26,840	-16,276
	sions (Metric Tons CO2e)	120	74	-46
Designed to Ea	rn the ENERGY STAR: Application	Checklist		
	ly required if you are using this document PA energy performance score of 75 or hig			STAR. All design projects
	perty type match the function or use of a ceive an ENERGY STAR design score?	property that's	Yes	No/Not Sure
	not sure your project is eligible for an ENE ase describe the property's major function			
	project at least 95% complete with constru se explain:	uction documents?	Tes Yes	□ No
3) Is the property	v currently unoccupied and not yet genera	ting energy bills?	Yes	No No
<ol> <li>Do energy cal and all energy</li> </ol>	culations account for the whole building in sources?	tended operations	Yes	🗋 No
5) Is the Archited	t of Record (AOR) applying for ENERGY	STAR partnership?	Yes	No No
6) Was the desig	n record created in the owner's Portfolio N	Manager account?	Yes	No No
7) Are you seeki	ng other qualifications for this design proje	ect?	Yes	No No
lf so, pleas	se select all that apply:		_	_
	AIA 2030 Commitment Architecture 2030 Challenge Federal, State or Local Disclosure Ordin Green Globes LEED Other, please indicate:			

I \_\_\_\_\_\_ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature:	Date:
Verifying Professional	
, ()	



**Note**: When applying for the ENERGY STAR Designed to Earn, the signature of the Verifying Professional must match the stamp.



I agree to adhere to the ENERGY STAR Identity Guidelines when using the Designed to Earn the ENERGY STAR recognition graphic in association with this project.

### Architect of Record Acknowledgement

As the Architect of Record representative, I confirm that the information on this SEDI is true and accurate to the best of my knowledge. It is our best estimate for all energy use of specified systems and processes but does not guarantee the operational performance of this building. Instead, this project has been specified to achieve Designed to Earn the ENERGY STAR recognition in an effort to assist the Owner/Developer in meeting their operational performance goal for the building to earn ENERGY STAR certification.

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

### **Building Owner/Developer Acknowledgement**

As the Building Owner/Developer representative, I concur that this project be nominated for Designed to Earn the ENERGY STAR recognition. Our organization understands the importance of measuring actual energy use in Portfolio Manager after receiving the Certificate of Occupancy to verify that this property is performing as intended. We understand that once the building earns an ENERGY STAR score of 75 or higher, it may be eligible for ENERGY STAR certification.

Signature: _	
--------------	--



ENERGY STAR<sup>®</sup> Statement of Energy Design Intent (SEDI)<sup>1</sup> Department of Public Works Garage



Primary Property Type: Non-Refrigerated Warehouse Gross Floor Area (ft<sup>2</sup>): 12,000 Estimated Date of Certification of Occupancy:

Date Generated: March 04, 2019

## ENERGY STAR® Design Score<sup>2</sup>

1. This form is required when applying for Designed to Earn the ENERGY STAR recognition. It was generated from ENERGY STAR Portfolio Manager.

2. The ENERGY STAR 1 – 100 Score is based on total annual Source Energy. To be eligible for Designed to Earn the ENERGY STAR recognition you must score at least 75.

Property & Contact Information for D	Design Project	
Property Address Department of Public Works Garage 69 Southside Avenue Hastings-on-Hudson, New York 10706	Project Architect	Owner Contact 
Property ID: 6664054	Architect Of Record	Property Owner 

Estimated Design Energy		
Fuel Type	Usage	Energy Rate (\$/Unit)
Electric - Grid	35,901 kWh (thousand Watt-hours)	\$ 0.16/kWh (thousand Watt-hours)
Natural Gas	6,728 therms	\$ 1.08/therms

Estimated Design Use Details	
$ m \rassignarrow$ This Use Detail is used to calculate the 1-100 E	NERGY STAR Score.
Non-Refrigerated Warehouse	
★ Weekly Operating Hours	60
The Number of Workers on Main Shift	5
rercent Used for Cold Storage	0
rercent That Can Be Cooled	All of it - 100%
rercent That Can Be Heated	All of it - 100%
☆Gross Floor Area	12,000 Sq. Ft.
Number of Walk-in Refrigeration/Freezer Units	0


Design Energy and	Emission Results			
Metric		Design Project	Median Property	Estimated Savings
ENERGY STAR Scor		48	50	N/A
Energy Reduction (fro		2.3	0	N/A
Source Energy Use In		87	85	-2
Site Energy Use Inter Source Energy Use (I		66 1,049,423	64 1,025,620	-2 -23,803
Site Energy Use (kBt		795,294	777,254	-18,040
Energy Costs (\$)	(, y )	13,046	12,750	-296
Total GHG Emissions	s (Metric Tons CO2e)	46	45	-1
Designed to Earn th	ne ENERGY STAR: Application (	Checklist		
that achieve an EPA e	quired if you are using this document energy performance score of 75 or hig	her are eligible for thi		STAR. All design projects
	y type match the function or use of a p an ENERGY STAR design score?	property that's	Yes	No/Not Sure
	sure your project is eligible for an ENE describe the property's major functions			
2) Is the design proje If no, please ex	ct at least 95% complete with constru kplain:	ction documents?	☐ Yes	□ No
3) Is the property cur	rently unoccupied and not yet generat	ing energy bills?	Yes	No No
<ol> <li>Do energy calculat and all energy sou</li> </ol>	tions account for the whole building in rces?	tended operations	Yes	🔲 No
5) Is the Architect of I	Record (AOR) applying for ENERGY	STAR partnership?	Yes	No No
6) Was the design re-	cord created in the owner's Portfolio N	lanager account?	Yes	🔲 No
	ther qualifications for this design proje	ct?	Yes	No No
If so, please se	elect all that apply:			
Arc Fec Gre LEE	2030 Commitment hitecture 2030 Challenge deral, State or Local Disclosure Ordina een Globes ED her, please indicate:			

I \_\_\_\_\_\_ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature:	_Date:
Verifying Professional	
, ()	



**Note**: When applying for the ENERGY STAR Designed to Earn, the signature of the Verifying Professional must match the stamp.



I agree to adhere to the ENERGY STAR Identity Guidelines when using the Designed to Earn the ENERGY STAR recognition graphic in association with this project.

### Architect of Record Acknowledgement

As the Architect of Record representative, I confirm that the information on this SEDI is true and accurate to the best of my knowledge. It is our best estimate for all energy use of specified systems and processes but does not guarantee the operational performance of this building. Instead, this project has been specified to achieve Designed to Earn the ENERGY STAR recognition in an effort to assist the Owner/Developer in meeting their operational performance goal for the building to earn ENERGY STAR certification.

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

### **Building Owner/Developer Acknowledgement**

As the Building Owner/Developer representative, I concur that this project be nominated for Designed to Earn the ENERGY STAR recognition. Our organization understands the importance of measuring actual energy use in Portfolio Manager after receiving the Certificate of Occupancy to verify that this property is performing as intended. We understand that once the building earns an ENERGY STAR score of 75 or higher, it may be eligible for ENERGY STAR certification.

Signature:	_
------------	---



ENERGY STAR<sup>®</sup> Statement of Energy Design Intent (SEDI)<sup>1</sup> Hook and Ladder Fire Company



Primary Property Type: Fire Station Gross Floor Area (ft<sup>2</sup>): 9,000 Estimated Date of Certification of Occupancy:

Date Generated: March 04, 2019

## ENERGY STAR® Design Score<sup>2</sup>

1. This form is required when applying for Designed to Earn the ENERGY STAR recognition. It was generated from ENERGY STAR Portfolio Manager.

2. The ENERGY STAR 1 – 100 Score is based on total annual Source Energy. To be eligible for Designed to Earn the ENERGY STAR recognition you must score at least 75.

Property & Contact Information for Design Project			
Property Address Hook and Ladder Fire Company 50 Main Street Hastings-on-Hudson, New York 10706	Project Architect	Owner Contact 	
Property ID: 6664038	Architect Of Record	Property Owner 	

Estimated Design Energy		
Fuel Type	Usage	Energy Rate (\$/Unit)
Electric - Grid	8,646 kWh (thousand Watt-hours)	\$ 0.08/kWh (thousand Watt-hours)
Natural Gas	6,105 therms	\$ 1.10/therms

Estimated Design Use Details		
lpha This Use Detail is used to calculate the 1-10	) ENERGY STAR Score.	
Fire Station		
Weekly Operating Hours	168	
Number of Workers on Main Shift	5	
Number of Computers	5	
🛧 Gross Floor Area	9,000 Sq. Ft.	

Design Energy and Emission Results			
Metric	Design Project	Median Property	Estimated Savings
ENERGY STAR Score (1-100)	N/A	50	N/A
Energy Reduction (from Median)(%)	-35.6	0	N/A
Source Energy Use Intensity (kBtu/ft <sup>2</sup> /yr)	80	124	44
Site Energy Use Intensity (kBtu/ft²/yr)	71	110	39
Source Energy Use (kBtu/yr)	723,625	1,123,806	400,181
Site Energy Use (kBtu/yr)	640,000	993,934	353,934
Energy Costs (\$)	7,441	11,557	4,116
Total GHG Emissions (Metric Tons CO2e)	34	54	20


Designed to Earn the ENERGY STAR: Application Checklist			
This section is only required if you are using this document to apply for Designed to Earn the ENERGY STAR. All design projects that achieve an EPA energy performance score of 75 or higher are eligible for this certification.			
<ol> <li>Does your <u>property type</u> match the function or use of a property that's eligibility to receive an ENERGY STAR design score?</li> </ol>	Yes	No/Not Sure	
If you are not sure your project is eligible for an ENERGY STAR design score, please describe the property's major functions or use:			
2) Is the design project at least 95% complete with construction documents? If no, please explain:	Tes Yes	No No	
3) Is the property currently unoccupied and not yet generating energy bills?	Yes	No No	
4) Do energy calculations account for the whole building intended operations and all energy sources?	Yes	🔲 No	
5) Is the Architect of Record (AOR) applying for ENERGY STAR partnership?	Yes	No No	
6) Was the design record created in the owner's Portfolio Manager account?	Yes	No No	
<ul><li>7) Are you seeking other qualifications for this design project?</li><li>If so, please select all that apply:</li></ul>	Yes	No No	
<ul> <li>AIA 2030 Commitment</li> <li>Architecture 2030 Challenge</li> <li>Federal, State or Local Disclosure Ordinance</li> <li>Green Globes</li> <li>LEED</li> <li>Other, please indicate:</li> </ul>			

I \_\_\_\_\_\_ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature:	Date:	
Verifying Professional		
, , ()		



**Note**: When applying for the ENERGY STAR Designed to Earn, the signature of the Verifying Professional must match the stamp.



I agree to adhere to the ENERGY STAR Identity Guidelines when using the Designed to Earn the ENERGY STAR recognition graphic in association with this project.

### Architect of Record Acknowledgement

As the Architect of Record representative, I confirm that the information on this SEDI is true and accurate to the best of my knowledge. It is our best estimate for all energy use of specified systems and processes but does not guarantee the operational performance of this building. Instead, this project has been specified to achieve Designed to Earn the ENERGY STAR recognition in an effort to assist the Owner/Developer in meeting their operational performance goal for the building to earn ENERGY STAR certification.

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

### **Building Owner/Developer Acknowledgement**

As the Building Owner/Developer representative, I concur that this project be nominated for Designed to Earn the ENERGY STAR recognition. Our organization understands the importance of measuring actual energy use in Portfolio Manager after receiving the Certificate of Occupancy to verify that this property is performing as intended. We understand that once the building earns an ENERGY STAR score of 75 or higher, it may be eligible for ENERGY STAR certification.

Signature:
------------



ENERGY STAR<sup>®</sup> Statement of Energy Design Intent (SEDI)<sup>1</sup> Village Hall / Library



Primary Property Type: Social/Meeting Hall Gross Floor Area (ft<sup>2</sup>): 23,820 Estimated Date of Certification of Occupancy: \_\_\_\_\_

Date Generated: March 04, 2019

## ENERGY STAR® Design Score<sup>2</sup>

1. This form is required when applying for Designed to Earn the ENERGY STAR recognition. It was generated from ENERGY STAR Portfolio Manager.

2. The ENERGY STAR 1 – 100 Score is based on total annual Source Energy. To be eligible for Designed to Earn the ENERGY STAR recognition you must score at least 75.

Property & Contact Information for [	Design Project	
<b>Property Address</b> Village Hall / Library 7 Maple Avenue Hastings-on-Hudson, New York 10706	Project Architect 	Owner Contact 
Property ID: 6664014	Architect Of Record	Property Owner , , ()

Estimated Design Energy		
Fuel Type	Usage	Energy Rate (\$/Unit)
Natural Gas	12,107 therms	\$ 1.12/therms
Electric - Grid	252,360 kWh (thousand Watt-hours)	\$ 0.15/kWh (thousand Watt-hours)
Fuel Oil (No. 2)	2,621 Gallons	\$ 2.39/Gallons

Estimated Design Use Details			
$ m \dot{s}$ This Use Detail is used to calculate the 1-1	00 ENERGY STAR Sco	ire.	
Library		Office	
Weekly Operating Hours	60	reference with the set of the set	60
Number of Workers on Main Shift	10	The second states the second structure the second structure to the second structure of the second stru	30
Number of Computers	20	rercent That Can Be Cooled	50 % or more
☆Gross Floor Area	13,225 Sq. Ft.	Number of Computers	30
		Percent That Can Be Heated	50 % or more
		☆Gross Floor Area	8,595 Sq. Ft.
Police Station			
Weekly Operating Hours	168		
Number of Workers on Main Shift	10		
	-		
Number of Computers	8		
☆Gross Floor Area	2,000 Sq. Ft.		

Page 1 of 3


Design Energy a	nd Emission Results			
Metric		Design Project	Median Property	Estimated Savings
ENERGY STAR S	. ,	N/A	50	N/A
Energy Reduction		18.3	0	N/A
	e Intensity (kBtu/ft²/yr) htensity (kBtu/ft²/yr)	169 102	143 86	-26 -16
Source Energy Us		4,047,495	3,421,313	-626,182
Site Energy Use (k		2,433,450	2,056,974	-376,476
Energy Costs (\$)		58,435	49,394	-9,041
	ons (Metric Tons CO2e)	164	138	-26
Designed to Earr	n the ENERGY STAR: Application (	Checklist		
	r required if you are using this document A energy performance score of 75 or hig			STAR. All design projects
	<u>erty type</u> match the function or use of a p eive an ENERGY STAR design score?	property that's	Yes	No/Not Sure
	ot sure your project is eligible for an ENE se describe the property's major functions			
2) Is the design pr If no, please	oject at least 95% complete with constru e explain:	ction documents?	PYes	□ No
3) Is the property of	currently unoccupied and not yet generat	ting energy bills?	Yes	No No
<ol> <li>Do energy calculated and all energy s</li> </ol>	ulations account for the whole building in sources?	tended operations	Yes	🔲 No
5) Is the Architect	of Record (AOR) applying for ENERGY	STAR partnership?	Yes	No No
6) Was the design	record created in the owner's Portfolio N	lanager account?	Yes	No No
	g other qualifications for this design proje	ect?	Yes	No No
If so, please	e select all that apply:			
	AIA 2030 Commitment Architecture 2030 Challenge Federal, State or Local Disclosure Ordina Green Globes LEED Other, please indicate:			

I \_\_\_\_\_\_ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature:	Date:	
Verifying Professional		
, , ()		



**Note**: When applying for the ENERGY STAR Designed to Earn, the signature of the Verifying Professional must match the stamp.



I agree to adhere to the ENERGY STAR Identity Guidelines when using the Designed to Earn the ENERGY STAR recognition graphic in association with this project.

### Architect of Record Acknowledgement

As the Architect of Record representative, I confirm that the information on this SEDI is true and accurate to the best of my knowledge. It is our best estimate for all energy use of specified systems and processes but does not guarantee the operational performance of this building. Instead, this project has been specified to achieve Designed to Earn the ENERGY STAR recognition in an effort to assist the Owner/Developer in meeting their operational performance goal for the building to earn ENERGY STAR certification.

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

### **Building Owner/Developer Acknowledgement**

As the Building Owner/Developer representative, I concur that this project be nominated for Designed to Earn the ENERGY STAR recognition. Our organization understands the importance of measuring actual energy use in Portfolio Manager after receiving the Certificate of Occupancy to verify that this property is performing as intended. We understand that once the building earns an ENERGY STAR score of 75 or higher, it may be eligible for ENERGY STAR certification.

Signature:
------------

Appendix B:

Utility Bill Summaries

		Gas							Oil							Elect	ricity								То	tal Energy			
																		Production	Delivery				Gas	Oil	Electricity	Total	Total Site Heating	Total Source Heating	To
ı	To Days	Month	therms	Cost	\$/therm	From	То	Days	Month	Gallons	Cost	\$/gal	From To	Days	Month	kWh	kW	Cost	Cost	Total Cost	\$/kWh	Month	(kBtu/ft <sup>2</sup> )	Total Cost					
1/0/00		January-15	5						January-15	5					January-15	5						January-15	0.0	0	0.0	0.0	0.0	0.0	\$0
1/0/00		February-1	5						February-15	5					February-15	5						February-15	0.0	0	0.0	0.0	0.0	0.0	
1/0/00		March-15	5						March-15	6					March-15	i						March-15	0.0		0.0	0.0		0.0	÷ -
1/0/00		April-15	5						April-15	5					April-15	5						April-15	0.0	0	0.0		0.0	0.0	÷ -
1/0/00		May-1	5						May-15	5					May-15	5						May-15	0.0	0	0.0	0.0	0.0	0.0	
1/0/00		June-15	5						June-15	6			1/0/00		June-15	5						June-15	0.0	0	0.0	0.0		0.0	
1/0/00		July-15	5						July-15	5			1/0/00		July-15	5						July-15	0.0	0	0.0	0.0	0.0	0.0	φu
1/0/00		August-15	5						August-15				1/0/00		August-15							August-15	0.0	0	0.0	0.0	0.0	0.0	
1/0/00		September-15	5						September-15				1/0/00		September-15							September-15	0.0	0	0.0	0.0		0.0	φ0
1/0/00		October-15	5						October-15				1/0/00		October-15							October-15	0.0	0	0.0	0.0	0.0	0.0	\$0
1/0/00		November-15	5						November-15				1/0/00		November-15							November-15	0.0	0	0.0			0.0	÷.
1/0/00		December-15							December-15	•			1/0/00		December-15	,						December-15	0.0	0	0.0	0.0	0.0	0.0	
1/0/00		January-16	j .						January-16	5			1/0/00		January-16	5						January-16	0.0	0	0.0	0.0	0.0	0.0	
1/0/00		February-16	5		-				February-16 March-16				1/0/00		February-16 March-16							February-16 March-16	0.0		0.0	0.0	0.0	0.0	ψ(
1/0/00		March-16				_				2			1/0/00	-		2				-			0.0	0	0.0	0.0	0.0	0.0	) \$(
1/0/00		April-16 Mav-16		-		_			April-16 Mav-16				1/0/00 1/0/00		April-16 Mav-16	899		\$14.21	\$176.55	£100.76	\$0.212	April-16 Mav-16	0.0	0	0.0	1.3	0.0	0.0	
1/0/00		June-16		-		_			June-16				1/0/00		June-16	6 095 1.410		\$14.21				June-16	0.0		2.0		0.0	0.0	
1/0/00		July-16		-		_			July-16				1/0/00		July-16	2.026		\$50.52				July-16	0.0	0	2.0	2.0	0.0	0.0	
1/0/00		August-16			-	-		+ +	August-16				1/0/00		August-16	1.970		\$79.39				August-16	0.0	0	2.9				
1/0/00		September-16	2		-	-		+ +	September-16				1/0/00		September-16	1.80		\$92.95	<b>\$</b> \$1.2.14			September-16	0.0		2.6			0.0	φι
1/0/00		October-16	3					+ +	October-16				1/0/00	-	October-16	1,369		\$68.32				October-16	0.0		2.0				
1/0/00		November-16	3					+ +	November-16				1/0/00	-	November-16	1,303		\$33.80				November-16	0.0	0	1.5			0.0	) \$34
1/0/00		December-16	3					+ +	December-16				1/0/00	-	December-16	1.13		\$42.70				December-16	0.0	0	1.0	1.6	0.0	0.0	
1/0/00		January-17	7						January-17				1/0/00		January-17	1,10		\$44.34				January-17	0.0	0	1.8				
1/0/00		February-1	7						February-17	,			1/0/00		February-17	1,20		\$56.57				February-17	0.0	0	1.7	1.0	0.0	0.0	) \$5
1/0/00		March-17	7						March-17				1/0/00		March-17	86		\$40.53				March-17	0.0	0	1.2	1.2	0.0	0.0	
1/0/00		April-17	7						April-17				1/0/00		April-17	72		\$27.41				April-17	0.0		1.2	1.2		0.0	ψi
1/0/00		May-1	7						May-17	,			1/0/00		May-17	58		\$26.72			\$0.235	May-17	0.0		0.8				
1/0/00	)	June-17	7					1 1	June-17				1/0/00		June-17	928		\$46.27			\$0.246	June-17	0.0	0	1.3	1.3	0.0	0.0	
1/0/00		July-1						1 1	Julv-17				1/0/00		July-17	1.512		\$100.40			\$0.273	July-17	0.0	0	2.1	2.1	0.0	0.0	
1/0/00	)	August-17	7						August-17				1/0/00		August-17	963		\$55.77			\$0.262	August-17	0.0	0	1.4	1.4	0.0	0.0	) \$5
1/0/00	)	September-17	7						September-17				1/0/00		September-17	923	1	\$55.94	\$193.73	\$249.67	\$0.270	September-17	0.0	0	1.3	1.3	0.0	0.0	) \$5
1/0/00	)	October-17	7						October-17				1/0/00		October-17	1,14		\$58.89	\$228.22	\$287.11	\$0.252	October-17	0.0	0	1.6	1.6	0.0	0.0	) \$5
1/0/00	)	November-17	7					1 1	November-17				1/0/00		November-17	673	6	\$31.03	3 \$147.44	\$178.47	\$0.265	November-17	0.0	0	1.0	1.0	0.0	0.0	) \$3
1/0/00		December-17	7 186						December-17				1/0/00		December-17	724		\$36.59	\$169.18	\$205.77	\$0.284	December-17	7.7	0	1.0	8.8	7.7	8.1	\$20
1/0/00	)	January-18	3 148	3 \$164	\$1.1°	1			January-18	5			1/0/00		January-18	1,02		\$43.74	\$228.48	\$272.22	\$0.265	January-18	6.2	0	1.5	7.6	6.2	6.5	5 \$20
1/0/00	)	February-18	3 126	5 \$164	\$1.30	0			February-18	8			1/0/00		February-18	3 1,22		\$73.62	2 \$247.79	\$321.41	\$0.263	February-18	5.3	0	1.7	7.0	5.3	5.5	5 \$23
1/0/00	)	March-18	3 156	5 \$203	\$ \$1.30	0			March-18				1/0/00		March-18	1,31 <sup>.</sup>		\$118.21	1 \$282.18	\$400.39	\$0.305	March-18	6.5	0	1.9	8.4	6.5	6.8	\$32
1/0/00		April-18	3 156						April-18				1/0/00		April-18	1,206		\$43.27				April-18	6.5	0	1.7	÷.=			
1/0/00		May-18	3 133					$\downarrow$ $\top$	May-18	3			1/0/00		May-18	960		\$38.94				May-18	5.5	0	1.4	6.9	5.5	5.8	· • • •
1/0/00		June-18	3 102						June-18	1	L		1/0/00		June-18	850		\$45.37				June-18	4.2		1.2	5.5			· • • •
1/0/00		July-18	3 118						July-18	1			1/0/00		July-18	94 <sup>-</sup>		\$56.42				July-18	4.9	0	1.3	6.3	4.9	•	
1/0/00		August-18	99	\$203	\$2.0	5			August-18				1/0/00		August-18	1,144		\$80.36	\$ \$240.01	\$320.37	\$0.280	August-18	4.1	0	1.6	5.8	4.1	4.3	\$283
anual /	September 2016)		,	ol \$0	) #DIV/0!	T					60					13.502	1	0	r	\$2.257	\$0.249		0.00	0.0	19.2	19.20	0.00	0.00	\$3,357
	September 2016		1.22							U 0	\$0 \$0					13,50		0	+	\$3,357			51.03	0.0					
muai (3	September 2017)		1,223	÷.,	+	v				0	÷.		1			14,12		v	1	ə,227	¢0.∠00		51.03	0.0	17.2	00.20	51.03	55.50	\$4,93



			Gas								Oil									Electricity									т	otal Energy			
1		1		1	1						0		1		-					Liobalicity	1	T	1				1	1	1		I		1 1
																						Energy	Delivery		Energy						Total Site	Total Source	
																						Production			Cost		Gas	Oil	Electricity	Total	Heating	Heating	Tota
From	То	Days	Month	therms	Cost	\$/t	herm	From	То	Days	Month	Gallons	Cost	\$/gal	From	То	Days	Month	kWh	kW	\$/kW	Cost	Cost	Total Cost	\$/kWh \$/kWh	Month	(kBtu/ft <sup>2</sup> )	Total Cost (\$					
1/0/00			January-1	5							January-1	5						January-								January-15	5 0.0	0	0 0.	0.0	0.	0.0.	0 \$0
1/0/00			February-1	5							February-18	ō						February-	15							February-15	5 0.0	0	0 0.	0.0	0.0	0 0.	
1/0/00			March-1	ō							March-18							March-								March-15	5 0.0	0	0 0.	0.0	0.	0 0.	φΰ
1/0/00			April-18	5							April-18							April-								April-15	5 0.0	0	0 0.	0.0	0.0	0 0.	0 \$0
1/0/00			May-1	5							May-18	5						May-	-							May-15	5 0.0	0	0 0.	0.0	0.0	0.0.	φõ
1/0/00			June-1	5							June-18	5			1/0/00	)		June-								June-15	5 0.0	0	0 0.	0.0	0.0	0 0.	0 \$0
1/0/00			July-1	5							July-18	i i			1/0/00	)		July-	-							July-15	5 0.0	0	0 0.	0.0	0.0	0 0.	φ.
1/0/00			August-15	5							August-18	i i			1/0/00	)		August-								August-15	5 0.0	0	0 0.	0.0	0.0	0 0.	φ.
1/0/00			September-15	5							September-15				1/0/00	)		September-								September-15	5 0.0	0	0 0.	5	0.0		÷ +÷
1/0/00			October-15	0							October-15	•			1/0/00	)		October-				_				October-15	0.0	0	0 0.		0.		- +-
1/0/00			November-15	-	_						November-15		I	_	1/0/00	1		November-	15							November-15	0.0	U	0 0.	0.0	0.	0.0.	- <i>+</i> -
1/0/00			December-15	2						<u> </u>	December-15				1/0/00		+	December-	15	+	+	+	+			December-15	0.0	J	0.	0.0	0.	0.	0 \$0
			January-16		_	_					January-16				1/0/00		-	January-								January-16	6 0.0	-	0 0.		0.		
1/0/00			February-16 March-16							<u> </u>	February-16 March-16				1/0/00		+	February- March-		+	+	+	+			February-16 March-16	<u>6</u> 0.0		0 0.	0.0	0.0	0 0.	0 \$0
1/0/00			April-16	2							April-16			-	1/0/00			April-								April-16	5 0.0 6 0.0	0	0 0.		0.	0 0.	φ.
1/0/00			May-16	2							May-16			-	1/0/00			April- May-		16.8	\$21.9	3 \$266.1	6 \$986.0	\$1.252.17	\$0.198 \$0.04		5 0.0	-	0 5.		0.0		
1/0/00			June-16			-					June-16				1/0/00		-	June-						\$3.069.03	\$0.186 \$0.05		S 0.0	-	0 13.		÷.		
1/0/00			July-16			-					July-16				1/0/00		-	July-				0 \$1.272.3			\$0.182 \$0.06		5 0.0	-	0 16		0.	0 0.	
1/0/00			August-16	2		-					August-16				1/0/00		-	August-				3 \$1,212.3		\$3,780.04	\$0.170 \$0.05		0.0	0	0 10.		0.	0 0.	
1/0/00			September-16								September-16			-	1/0/00			September-				9 \$1,370.2			\$0.142 \$0.06		5 0.0	0	0 16		0.		
1/0/00			October-16	3							October-16			-	1/0/00			October-				3 \$567.3		\$1,554.63	\$0.200 \$0.07		0.0	0	0 10.		0.		
1/0/00			November-16			-					November-16				1/0/00	1		November-				5 \$236.3		\$ \$2.197.63	\$0.639 \$0.06		0.0	0	0 2	8 2.8	0.	0.0	0 \$236 0
1/0/00			December-16			-					December-16				1/0/00	1		December-		5.6				5 \$1.341.63	\$0.479 \$0.08		0.0	0	0 2	3 2.3	0.	0 0.	
1/0/00			January-1	7		-					January-1				1/0/00			January-					· • • • • • • • • • •	\$1.378.50	\$0.345 \$0.08		7 0.0	0	0 3		0.	÷ .	
1/0/00			February-1	7							February-17				1/0/00			February-		7.2	\$23.1			\$1.352.47				0	0 3		0.		
1/0/00			March-17	7							March-17				1/0/00	0		March-		6.4				\$1,470.15	\$0.360 \$0.09		0.0	0	0 3.	3 3.3	0.0	0 0.	0 \$373
1/0/00			April-17	7							April-17	•			1/0/00			April-		7.2				\$1,285.51	\$0.342 \$0.08		0.0	0	0 3.	1 3.1	0.	0 0.	
1/0/00			May-1	7							Mav-1	,			1/0/00			Mav-		16.0		4 \$338.2	0 \$943.8	\$1.282.05	\$0.364 \$0.09		0.0	0	0 2	9 2.9	0.0	0 0.	0 \$338
1/0/00			June-17	7							June-17				1/0/00	)		June-	17 20,240	34.4	\$24.3	6 \$1,322.6	9 \$1,003.93	\$2,326.62	\$0.115 \$0.06	5 June-17	7 0.0	0	0 16.	4 16.4	0.0	0 0.	0 \$1,323
1/0/00			July-17	7							July-17				1/0/00	)		July-	17 18,320	0 101.6	\$25.9	8 \$1,561.1	1 \$2,669.70	\$4,230.81	\$0.231 \$0.08	5 July-17	0.0	D	0 14.	9 14.9	0.0	0.	0 \$1,561
1/0/00			August-17	7							August-17				1/0/00	)		August-	17 18,000	0 101.6	\$23.5	5 \$1,384.6	3 \$2,489.6	\$3,874.24	\$0.215 \$0.07	7 August-17	7 0.0	0	0 14.	6 14.6	0.	0.0.	0 \$1,385
1/0/00			September-17	7							September-17				1/0/00	)		September-	17 19,680	98.4	\$24.3	6 \$1,542.1	2 \$2,490.4	\$4,032.60	\$0.205 \$0.07	8 September-17	0.0	0	0 16.	0 16.0	0.0	D 0.	0 \$1,542
1/0/00			October-17	7							October-17	·			1/0/00	)		October-	17 6,560		\$23.5	5 \$538.9	0 \$1,747.98	\$2,286.88	\$0.349 \$0.08	2 October-17	0.0	0	0 5.	3 5.3	0.0	0 0.	0 \$539
1/0/00			November-17	'							November-17				1/0/00	)		November-	17 3,280	79.2	\$25.1	7 \$330.7	7 \$2,073.69	\$2,404.46	\$0.733 \$0.10	1 November-17	0.0	0	0 2.	7 2.7	0.	0 0.	0 \$331
1/0/00			December-17								December-17				1/0/00	)		December-	17 3,760	9.6			4 \$1,168.2	\$1,535.86	\$0.408 \$0.09	8 December-17	0.0	0	0 3.	1 3.1	0.	0 0.	0 \$368
1/0/00			January-18	3							January-18	3			1/0/00			January-		9.6	\$26.4		1 \$1,167.0		\$0.374 \$0.06		0.0	0	0 3.	1 3.1	0.	0.0.	0 \$239
1/0/00			February-18	3							February-18	8			1/0/00			February-	18 3,600				2 \$1,081.10	\$1,376.52	\$0.382 \$0.08	2 February-18	3 0.0	0	0 2.	9 2.9	0.	0.0.	0 \$295
1/0/00			March-18	3							March-18				1/0/00			March-		7.2			7 \$1,125.72		\$0.411 \$0.11		0.0	-	0 3.		0.	÷ .	
1/0/00			April-18	3							April-18				1/0/00			April-		7.2					\$0.342 \$0.05		0.0	0	0 2.		0.0	0 0.	
1/0/00			May-18	3							May-18	1			1/0/00			May-		6.4				\$1,631.18	\$0.104 \$0.03		3 0.0	0	0 12.		0.		
1/0/00			June-18	3							June-18	3			1/0/00	)		June-						\$1,854.83	\$0.147 \$0.06		0.0	0	0 10.		0.0	0 0.	
1/0/00			July-18	3							July-18	5			1/0/00	)		July-					8 \$2,944.49		\$0.290 \$0.07		3 0.0	0	0 10.		0.	0.	0 0011 0
1/0/00			August-18	3							August-18	5			1/0/00	)		August-	18 20,000	107.2	\$25.0	5 \$1,574.4	4 \$2,807.3	\$4,381.83	\$0.219 \$0.07	9 August-18	8 0.0	0	0 16.	2 16.2	. 0.	0 0.	0 \$1,574 0
															-																		
ng Annual (Se						0 #D						(	\$(		_				109,520					\$25,118			0.00				0.0		0 \$25,118
ng Annual (Se		0047)		1	0 6	0 #D	DIV/0!					1 7	) \$0	<b>.</b>					109.840	0 107.2	\$36.0	4 \$7.85	6 640 72	\$27.576	\$0.251 \$0.07	· · ·	0.00	0 0.	.0 89.	2 89.23	0.0	0 00	\$27,576



			Gas				1			<b>.</b>										El a stat a l'										-	4-1 E				
	1	1	Gas	т <u> </u>		т <u> </u>	_	-		Oil						1	-	т <u> </u>		Electricity	1			1	-	1			1	То	tal Energy		т <u> </u>	1	
																						Energy Production	Delivery (Demand)			Energy Cost		Gas	Oil	Electricity	Total	Total Site Heating	Total Source Heating		Total Co
From	То	Days	Month	therms	Cost	\$/therm	From	n To	o Days	Mont		Gallons	Cost	\$/gal	From	То	Days	Month	kWh	kW	\$/kW	Cost	Cost	Total Cost	t \$/kWh	\$/kWh	Month	(kBtu/ft <sup>2</sup> )	(kBtu/ft <sup>2</sup> )	(kBtu/ft <sup>2</sup> )	(kBtu/ft <sup>2</sup> )	(kBtu/ft <sup>2</sup> )	(kBtu/ft <sup>2</sup> )	Total Cos	(1)
1/0/00	0		January-15	5						Janu								Januar									January-15	0.0		0.0		0.0	0.0	φ0	,
1/0/00	0		February-15	5						Febru								Februar			_	_			-		February-15	0.0		0.0		0.0	0.0	) \$0	
1/0/00			March-15	-			_				rch-15							Marc	-		-	_		-	-	-	March-15	0.0		0.0		0.0	0.0	- ÷	
1/0/00	0		April-15 Mav-15	5			_				pril-15 1av-15							Apr Ma			-	_		-	-	-	April-15 Mav-15	0.0		0.0		0.0	0.0	5 \$0 5 \$0	
1/0/00	0		June-15	5			_				une-15				1/0/00			Jun			-	-		-	-	-	June-15	0.0		0.0		0.0	0.0	- ÷	
1/0/00	-		July-15	5							uly-15				1/0/00	5		Ju				-				-	July-15	0.0		0.0		0.0	0.0	) \$0 ) \$0	
1/0/00			August-15	5							ust-15				1/0/00	2		Augus								1	August-15	0.0		0.0		0.0	0.0		
1/0/00			September-15	5						Septem					1/0/00			Septembe							1		September-15	0.0		0.0		0.0	0.0	5 \$0	
1/0/00	0		October-15	5						Octo	ber-15				1/0/00	)		Octobe	r-15								October-15	0.0	0 0	0.0	0.0	0.0	0.0	) \$0	,
1/0/00	0		November-15	5						Novem	ber-15				1/0/00	)		Novembe	r-15								November-15	0.0	0 0	0.0	0.0	0.0	0.0	C \$0	,
1/0/00	0		December-15	5						Decem	ber-15				1/0/00	)		Decembe	r-15								December-15	0.0	0 0	0.0		0.0	0.0	D \$0	
1/0/00	-		January-16							Janu	1 .				1/0/00			Januar									January-16	0.0		0.0		0.0	0.0		
1/0/00			February-16	6						Febru					1/0/00			Februar									February-16	0.0		0.0		0.0	0.0		
1/0/00			March-16	6			_				rch-16				1/0/00			Marc							_		March-16	0.0		0.0		0.0	0.0	D \$0	,
1/0/00	0		April-16		_		_				pril-16 1av-16				1/0/00	)		Apr		40.0		00 <b>#</b> 400.4	0 0050.0	4 64 004 0	0 00 400	¢0.000	April-16	0.0		0.0		0.0		φ0	
1/0/00	0		May-16 June-16								une-16				1/0/00			Ma Jun		0 40.0 0 54.4			2 \$952.8 4 \$1.286.2			2 \$0.032 5 \$0.052	May-16 June-16	0.0		2.7		0.0			2 0.0254 1 0.0465
1/0/00			June-16 July-16								ulv-16				1/0/00		_	Jun		-			4 \$1,286.2					0.0		3.1		0.0			0.0465
1/0/00	0		August-16	5 1	0 \$42	\$4.2	22				ust-16				1/0/00			Augus		0 74.4		3 \$1,155.9		6 \$2,870.7		++++++		0.0		0 3.9		0.0	0.0		
1/0/00	0		September-16	3 3		\$1.8				Septem					1/0/00			Septembe					1 \$1,960.3					0.1	-	3.9		0.1		φ1,100	0.0825
1/0/00			October-16	5 72	8 \$661	\$0.9				Octo					1/0/00			Octobe					1 \$1,484.6					4.3		3.1		4.3		- ÷.,	5 0.0990
1/0/00			November-16	6 1.51		\$0.8				Novem	-		1		1/0/00			Novembe					1 \$1.192.5					8.9		3.1		8.9	9.4		0.1190
1/0/00	0		December-16	6 2,46	9 \$2,170	\$0.8	38			Decem	ber-16				1/0/00	)		Decembe	-16 16,40	0 36.8	0 \$24.2	20 \$879.9	5 \$1,015.9	9 \$1,895.9	4 \$0.116	6 \$0.054	December-16	14.5	i C	3.3	17.8	14.5	15.2	2 \$3,050	0.1793
1/0/00	0		January-17	7 2,02	\$2,384	\$1.1	18			Janu	ary-17				1/0/00	)		Januar	/-17 19,28	0 40.0	0 \$24.2	\$938.8	\$1,054.7	1 \$1,993.5	8 \$0.103	3 \$0.049	January-17	11.9	0 0	3.9	15.8	11.9	12.5	5 \$3,323	3 0.1954
1/0/00	0		February-17	7 1,80	φ2,100	\$1.2				Febru					1/0/00	)		Februar				9 \$1,007.2	\$989.4	3 \$1,996.6	8 \$0.124	4 \$0.062		10.6	6 C	3.2		10.6	i 11.1		0.1868
1/0/00	0		March-17	7 1,66	\$1,714	\$1.0					rch-17				1/0/00	)		Marc		0 38.4						2 \$0.062	March-17	9.8		3.5		9.8			0.1643
1/0/00			April-17			\$1.2					pril-17				1/0/00			Apr								8 \$0.053	April-17	3.1		3.1		3.1			
1/0/00	0		May-17	7 29	φοσι	ψ1.2					lay-17				1/0/00			Ma					7 \$1,198.7			- + + + + + + + + + + + + + + + + + + +		0.8		3.0		0.8			0.0652
1/0/00	0		June-17	/	9 \$46	\$5.1					ine-17				1/0/00			Jun			÷		0 \$1,744.5			9 \$0.067	June-17	0.2		3.1	÷	0.2		¢ .,.=0	3 0.0660
1/0/00	-		July-17	7	8 \$41	\$5.1 \$ \$4.8					uly-17				1/0/00	2		Ju					3 \$1,882.4 7 \$1.694.7			2 \$0.081	July-17	0.1		4.2		0.1		· • • • • • • •	0.1023
1/0/00			August-17 September-17	7 2	9 \$43					Septem	ust-17				1/0/00			Augus		0 67.2 0 69.6			57 \$1,894.7 57 \$1,802.5			6 \$0.073 6 \$0.077	August-17 September-17	0.4		0 <u>3.7</u> 0 <u>3.3</u>	4.1	0.4			0.0855
1/0/00			October-17	7 41	÷••					Octo					1/0/00			Octobe					4 \$1.622.0			5 \$0.068	October-17	1.6		3.0		1.6	0.0	5 \$1,400	
1/0/00	0		November-17	1.92		7 \$1.0				Novem					1/0/00	5		Novembe		0 50.4			0 \$1.368.1	1 \$2,347.7			November-17	5.8		3.2	-	5.8	60		
1/0/00	0		December-17	2.72	÷.,•	\$0.9				Decem					1/0/00	2		Decembe		-	÷ +=•:		3 \$1.207.6	· • • • • • • • • • • • • • • • • • • •	+++++++			8.0		3.9		8.0		÷ ÷,•=•	0.1433
1/0/00	0		January-18	3 2,20		\$ \$1.1				Janu	ary-18		1		1/0/00			Januar					3 \$1,287.9			6 \$0.049		6.8		3.9		6.8			5 0.1308
1/0/00	0		February-18	3 1,71	1 \$2,344	\$1.3	37			Febru	ary-18				1/0/00	)		Februar	/-18 18,48	0 74.4	0 \$25.9	1 \$1,250.3	9 \$1,976.8	6 \$3,227.2	5 \$0.175	5 \$0.068	February-18	5.7	· C	3.7	9.4	5.7	6.0	\$2,503	3 0.1472
1/0/00	0	1	March-18	3 1,63		\$1.1	13			Ma	rch-18				1/0/00	D		Marc	n-18 17,04	0 41.6			3 \$1,194.4				March-18	9.6	i (	3.4	13.0	9.6	10.1	1 \$3,489	0.2052
1/0/00	-		April-18	3 56	i3 \$773	\$ \$1.3					pril-18				1/0/00			Apr			÷ +=•··	+++++++++++++++++++++++++++++++++++++++	6 \$1,028.3	· • • • • • • •		7 \$0.043	April-18	3.3	0	3.2		3.3	3.5	- ÷.,	0.0859
1/0/00	0		May-18	3 12	3 \$216						lay-18				1/0/00	)		Ma					2 \$1,572.8			÷ ••••	May-18	0.7	-	3.1	÷	0.7			0.0563
1/0/00	0		June-18	3 1	0 \$49	φ1.6					ine-18				1/0/00	)		Jun					1 \$1,508.8					0.1	-	3.8	÷	0.1	÷.	φ.,	. 0.000
1/0/00			July-18		8 \$43						uly-18				1/0/00			Ju					3 \$1,938.6					0.0		4.0		0.0		- ÷.,•••	0.0814
1/0/00	0		August-18	3	8 \$44	\$5.4	14			Auç	ust-18				1/0/00	)		Augus	t-18 21,68	0 70.4	\$25.0	)5 \$1,668.2	\$1,919.4	5 \$3,587.6	7 \$0.165	5 \$0.077	August-18	0.0	0 0	) 4.4	4.4	0.0	0.0	J \$1,712	0.1006
	0	0040		44.00	F #44.0-0								<b>*</b> C		1							0 640 TO	-	rl 600.00		o 60.000					400.00			A 40 747	
ning Annual (S				11,08	· · · · · · · · · · · · · · · · · · ·	\$1.0 \$1.1						0	\$0 \$0		l				204,88	0 81.6 0 74.4	+=+	· • · • • • •			2 \$0.142 8 \$0.15			65.21 66.71				65.21 66.71		7 \$40,715 4 \$45,339	
ming Annual (S	September	r zv17)			3 \$12,327							U	φU		1				213,92	v (4.4	u ⇒27.′	ະວຸ \$13,91	1 \$18,42	o <b>\$</b> 3∠,33	o \$0.15'	1 \$0.065		00./1	0.0	42.9	109.64	65.96	69.25	4 \$45,338 \$43.027	2.0009



			Gas								Oil								E	lectricity									т	otal Energy			-
																				localony		Production	Delivery		End	rgy st	Gas	Oil	Electricity	Total	Total Site Heating	Total Source Heating	Total
From	То	Days	Month	therms	Cost			From	То	Days	Month	Gallons	Cost	\$/gal	From	То	Days	Month	kWh	kW	\$/kW	Cost	Cost	Total Cost	\$/kWh \$/k		(kBtu/f	<sup>2</sup> ) (kBtu/f	. / (	(kBtu/ft <sup>2</sup> )	(kBtu/ft <sup>2</sup> )	(kBtu/ft <sup>2</sup> )	Total Cost (\$/f
1/0/0			January-15			#DI					January-1	5						January-15								January		0.0	0 0.0	0.0	0.0	0.0	φ0
1/0/0			February-15 March-15			#DI					February-1	5		-				February-15				_				February	-	0.0	0 0.0		0.0	0.0	- +-
1/0/0			April-15			#DI	V/0! V/0!			-	March-1 April-1	-						March-15 April-15								March April		0.0	0 0.0		0.0	0.0	- <del>-</del> -
1/0/0			April-15 Mav-15			#DI #DI				-	April-1 Mav-1	5						April-15 May-15								April		0.0	0 0.0	0.0	0.0	0.0	÷ + •
1/0/0			June-15		-	#DI					June-1	5		-	1/0/00			June-15								June		0.0	0 0.	0.0	0.0		
1/0/0			July-15				V/0!				July-1	-			1/0/00			July-15								July		0.0	0 0.	0.0	0.0	0.0	0 \$0
1/0/0	-		August-15			#DI					August-1	5			1/0/00			August-15								August		0.0	0 0.0	0.0	0.0	0.0	
1/0/0			September-15			#DI					September-1	5			1/0/00			September-15								September		0.0	0 0.0	0.0	0.0	0.0	
1/0/0	00		October-15			#DI	V/0!				October-1	5			1/0/00			October-15								October	-15	0.0	0 0.0	0.0	0.0	0.0	0 \$0
1/0/0	00		November-15		1	#DI	V/0!				November-1	5			1/0/00			November-15								November	-15	0.0	0 0.0	0.0	0.0	0.0	0 \$0
1/0/0			December-15			#DI					December-1	5			1/0/00			December-15								December		0.0	0 0.0	0.0	0.0	0.0	0 \$0
1/0/0			January-16	i i		#DI					January-1	6			1/0/00			January-16								January		0.0	0 0.0		0.0	0.0	
1/0/0			February-16			#DI					February-1	6			1/0/00			February-16								February		0.0	0 0.0	0.0	0.0	0.0	
1/0/0			March-16			#DI					March-1	-			1/0/00			March-16								March		0.0	0 0.0	0.0	0.0	0.0	0 \$0
1/0/0			April-16			#DI					April-1				1/0/00			April-16								April		0.0	0 0.0	0.0	0.0	0.0	0\$0
1/0/0			May-16			#DI					May-1	-			1/0/00			May-16	1,872	10.80	\$21.9				<b>+•</b> ••• <b>••</b>		-	0.0	0 0.		0.0	0.0	
1/0/0	-		June-16			#DI					June-1	-			1/0/00			June-16	1,818	8.82	\$22.6		5 \$211.74		\$0.171 \$		-	0.0	0 0.		0.0	0.0	0 \$99 0
1/0/0			July-16		-	#DI				-	July-1			-	1/0/00			July-16	1,908	9.72		0 \$118.86			\$0.191 \$			0.0	0 0.		0.0	0.0	0 \$119 0
1/0/0			August-16 September-16		<u> </u>	#DI	V/0! V/0!				August-1 September-1	0		-	1/0/00			August-16 September-16	2,322	10.44 10.62	\$21.9	3 \$133.0 <sup>2</sup> 9 \$158.88	1 \$253.30 3 \$264.54		\$0.166 \$ \$0.182 \$	0.057 August 0.068 September		0.0	0 0.	0.7	0.0	0.0	÷ ÷ ÷ ÷ ÷
1/0/0			October-16	6	0 \$32 1 \$91		\$1.49			-	October-1	6			1/0/00			October-16	2,322	9,18		9 \$158.88 3 \$118.81	5 \$264.54 1 \$218.66					0.0	0 0.	÷	0.0	0.0	5 \$210
1/0/0			November-16	570	5 \$498		\$1.49			-	November-1	6			1/0/00			November-16	2.052	9.10	\$21.9		5 \$220.50			0.048 November		4.8	0 0.	1.0	0.5	0.5	
1/0/0			December-16	1.01	+		\$0.86			+	December-1	6			1/0/00			December-16	2,032	9.72	\$23.4	400.00	3 \$261.87	+	\$0.163 \$			8.4	0 0.	7 91	4.0	0.0	
1/0/0			January-17	806			\$0.80				Januarv-1	7		-	1/0/00			January-17	3.618	12.42	\$24.2		3 \$201.07 3 \$318.89		\$0.137 \$			6.7	0 1.	0.1	6.7	0.0	
1/0/0			February-17	2.374			\$1.11				February-1	7			1/0/00			February-17	4,698	13.32	\$23.1		9 \$321.97	+	\$0.129 \$			19.8	0 1.		19.8		· • • • • • •
1/0/0			March-17	1.13	4 \$1,102		\$0.97				March-1				1/0/00			March-17	4,000	13.32	\$25.9		1 \$358.48		\$0.143 \$			9.5	0 1.	21.1	9.5	9.9	
1/0/0			April-17	39	\$80	)	\$2.04				April-1				1/0/00			April-17	4.356	14.58	\$23.5					.052 April		0.3	0 1.	2 1.6	0.3	0.3	3 \$307 0
1/0/0	00		May-17		5 \$32	2	\$6.39				Mav-1				1/0/00			Mav-17	1,926	10.62	\$22.7		3 \$248.64		\$0.194 \$			0.0	0 0.	0.6	0.0		
1/0/0	00		June-17	. (	\$32	2 #DI	V/0!				June-1	7			1/0/00			June-17	1,944	10.26	\$24.3	6 \$133.8 <sup>-</sup>	1 \$255.89	\$389.70	\$0.200 \$	.069 June	-17	0.0	0 0.0	6 0.6	0.0	0.0	0 \$166 0
1/0/0	00		July-17	. (	\$32	2 #DI	V/0!				July-1	7			1/0/00			July-17	2,214	9.72	\$25.9	8 \$186.08	\$259.04	\$445.12	\$0.201 \$	.084 July	-17	0.0	0 0.0	6 0.6	0.0	0.0	0 \$218 (
1/0/0	00		August-17	(	\$32	2 #DI	V/0!				August-1	7			1/0/00			August-17	2,070	10.26	\$23.5	5 \$157.79	9 \$264.25	\$422.04	\$0.204 \$	0.076 August	-17	0.0	0 0.0	6 0.6	0.0	0.0	0 \$190 0
1/0/0	00		September-17		1 \$31	1	\$31.39	-			September-1	7			1/0/00			September-17	1,890	9.00	\$24.4		7 \$240.81			.080 September	17	0.0	0 0.	5 0.5	0.0	0.0	
1/0/0			October-17	6	1 \$117		\$1.92	-			October-1	7			1/0/00			October-17	1,674	8.46	\$23.5		1 \$222.63		\$0.205 \$			0.5	0 0.	5 1.0	0.5	0.5	
1/0/0			November-17	668	8 \$664		\$0.99				November-1	7			1/0/00			November-17	1,908	8.46	\$25.1		\$233.33			0.065 November		5.6	0 0.	6.1	5.6	5.8	
1/0/0			December-17	1,940			\$0.87				December-1	7			1/0/00			December-17	2,664	11.16	\$25.9		1 \$320.20			0.067 December		16.2	0 0.8		16.2		
1/0/0	-		January-18	1,72	3 \$1,888	-	\$1.09				January-1	8	l	_	1/0/00			January-18	5,310	13.86	\$26.4		2 \$391.93		\$0.123 \$			14.4	0 1.	5 15.9	14.4		
1/0/0			February-18	1,520	5 \$1,952		\$1.28				February-1	8		-	1/0/00			February-18	5,292	14.58	\$25.9				\$0.140 \$			12.7	0 1.	5 14.2	12.7	13.4	
1/0/0			March-18	1,23			\$1.06				March-1			_	1/0/00			March-18	5,058	14.40	\$27.6		5 \$407.43		\$0.177 \$			10.3	0 1.4	11.0	10.3	10.8	
1/0/0	-		April-18	40	\$85		\$2.13			+	April-1	-			1/0/00			April-18	4,158	13.50	\$25.0		3 \$347.55		\$0.126 \$		-	0.3	0 1.:		0.3	0.4	
1/0/0			May-18 June-18	04	5 \$37 3 \$334		\$7.40 \$1.37			+	May-1 June-1		l		1/0/00			May-18 June-18	2,916 2,178	12.60 8.82		5 \$140.46 1 \$134.10	6 \$325.55 0 \$239.92		\$0.160 \$ \$0.172 \$			0.0	0 0.		0.0	0.0	
1/0/0			June-18 Julv-18	24	3 \$334 ) \$31		\$1.37 V/0!				June-1 July-1				1/0/00			June-18 July-18	2,178	8.82 9.54	\$25.9				\$0.172 \$			2.0	0 0.	2.6	2.0	2.1	
1/0/0			July-18 August-18		) \$31 ) \$32		V/0! V/0!				August-1				1/0/00			August-18	2,430	9.54 10.44	\$27.6					0.068 July 1.078 August		0.0	0 0.	0.7	0.0	0.0	
1/0/0	0		August-18	u (	J	∠ #DI	v/U!			1	August-1	0	I	1	1/0/00			August-18	2,010	10.44	φ∠5.0	J \$202.90	J ⊅291.98	\$494.89	φυ. 190 - Φ	August	-10	0.0	U. U.	0.7	0.0	0.0	φ <u>2</u> 35 0.
ning Annual	(Septemi	ber 2016)		6.00	\$6.349	9	\$1.06						\$(	)	1				33.714	14.58	\$25.2	1 \$2.06	5 \$3.340	\$5.406	\$0.160 \$	.061	5	0.05	0.0 9.0	59.64	50.05	52 55	5 \$11.754
ning Annual				7.45			\$1.10						\$(	)	1				38.088	14.58	\$27.3					.065	6		0.0 10.		62.08		9 \$14,352 1.1
age	1.			6,728			\$1.08						\$		1				35,901	14.58				1.7	\$ 0.161 \$ 0		1 -			66.27	56.07	58.87	\$13.053



			Gas							Oil									Electricity									Tot	al Energy			
																														<b>T</b> ( ) (0)	<b>T</b> ( ) 0	
																										Gas	Oil	Electricity	Total	Total Site Heating	Total Source Heating	То
	τ.	David	N	44	0	¢ //h	<b>F</b>	τ.	Davis	N a su dh	0	0	¢/	<b>F</b>	τ.	Davis	Month	1.3.6.0-	134/	\$/kW	Production	Delivery	T-4-1 04	\$/kWh	Month		(kBtu/ft <sup>2</sup> )	Total Cost				
om 1/0/00	To	Days	Month January-15	therms	Cost	\$/therm #DIV/0!	From	То	Days	Month January-15	Gallons	Cost	\$/gal	From	To	Days	January-15	kWh	kW	\$/KVV	Cost	Cost	Total Cost	\$/KVVN	January-15	(kBtu/ft <sup>2</sup> )	(KBtu/ft)	(KBtu/ft)	(κΒτα/π.) 0.0	(	(KBtu/ft)	-
1/0/00			February-15			#DIV/0! #DIV/0!				February-15	2						February-15								February-15	0.0	0	0.0	0.0		0.0	φu
1/0/00			March-15			#DIV/0!	-		-	March-15							March-15				1 1				March-15	0.0	0	0.0	0.0		0.0	÷ -
1/0/00			April-15			#DIV/0!	-			April-15							April-15				1				April-15	0.0	0	0.0	0.0	0.0	0.0	\$0 \$0
1/0/00			Mav-15			#DIV/0!	-			Mav-15							Mav-15				1				May-15	0.0	0	0.0	0.0	0.0	0.0	\$0
1/0/00			June-15			#DIV/0!	-			June-15				1/0/00			June-15								June-15	0.0	0	0.0	0.0	0.0	0.0	\$0
1/0/00			July-15			#DIV/0!				July-15				1/0/00			July-15				1				July-15	0.0	0	0.0	0.0		0.0	÷ -
1/0/00			August-15			#DIV/0!				August-15				1/0/00			August-15	48	3.24	\$23.45	\$7.71	\$76.07	\$83.78	\$1.745	August-15	0.0	0	0.0	0.0		0.0	\$8 0
1/0/00			September-15			#DIV/0!				September-15				1/0/00			September-15	504	3.24	\$22.69		\$73.62	\$107.68	\$0.214	September-15	0.0	0	0.2	0.2		0.0	
1/0/00			October-15			#DIV/0!				October-15				1/0/00			October-15	492	2.88	\$21.93		\$63.26	\$95.13		October-15	0.0	0	0.2	0.2	0.0	0.0	\$32 0
1/0/00			November-15			#DIV/0!				November-15				1/0/00			November-15	504	1.08	\$21.94	\$29.29	\$23.72	\$53.01		November-15	0.0	0	0.2	0.2	0.0	0.0	\$29 0
1/0/00			December-15			#DIV/0!				December-15	6			1/0/00			December-15	528	5.40	\$25.71	\$34.77	\$139.05	\$173.82	\$0.329	December-15	0.0	0	0.2	0.2	0.0	0.0	\$35 0
1/0/00			January-16			#DIV/0!				January-16	6			1/0/00			January-16	864	3.12	\$24.20	\$41.31	\$75.61	\$116.92	\$0.135	January-16	0.0	0	0.3	0.3	0.0	0.0	\$41
1/0/00			February-16			#DIV/0!				February-16	i			1/0/00			February-16	1,200	3.36	\$22.69	\$46.84	\$76.34	\$123.18	\$0.103	February-16	0.0	0	0.5	0.5	0.0	0.0	\$47
1/0/00			March-16			#DIV/0!				March-16	i			1/0/00			March-16	288	3.00	\$22.69	\$17.33	\$68.16	\$85.49	\$0.297	March-16	0.0	0	0.1	0.1	0.0	0.0	\$17
1/0/00			April-16			#DIV/0!				April-16	i			1/0/00			April-16	288	2.88	\$23.45		\$67.62	\$81.59		April-16	0.0	0	0.1	0.1	0.0	0.0	
1/0/00			May-16			#DIV/0!				May-16	i			1/0/00			May-16	552	2.76	\$21.93	\$19.84	\$60.62	\$80.46		May-16	0.0	0	0.2	0.2		0.0	φ <u></u> 20
1/0/00			June-16			#DIV/0!				June-16	i			1/0/00			June-16	636	3.48	\$22.69		\$79.07	\$113.94		June-16	0.0	0	0.2	0.2	0.0	0.0	
1/0/00			July-16			#DIV/0!				July-16	i			1/0/00			July-16	696	3.60	\$24.20			\$130.73		July-16	0.0	0	0.3	0.3	0.0	0.0	
1/0/00			August-16	20	\$49	\$2.44				August-16	6			1/0/00			August-16	564	2.64	\$21.93		<i>40.100</i>			August-16	0.2	0	0.2	0.4	•=	0.2	
1/0/00			September-16	31	\$59	\$1.89				September-16	i			1/0/00			September-16	408	2.52	\$22.69			\$87.70		September-16	0.3	0	0.2	0.5		0.4	
1/0/00			October-16	359	\$329	\$0.92				October-16	i			1/0/00			October-16	540	3.12	\$21.93			\$111.68		October-16	4.0	0	0.2	4.2		4.2	
1/0/00			November-16	744		\$0.84				November-16				1/0/00			November-16	600	3.00	\$23.45					November-16	8.3	0	0.2	8.5		8.7	
1/0/00			December-16	1,217		\$0.84				December-16				1/0/00			December-16	660	3.48	\$24.20		\$93.55	\$130.82		December-16	13.5	0	0.3	13.8		14.2	
1/0/00			January-17	993		\$1.12			_	January-17				1/0/00			January-17	1,068			\$50.68	\$6.40	\$57.08	\$0.053	January-17	11.0	0	0.4	11.4		11.6	
1/0/00			February-17 March-17	1,024 844		\$1.14 \$0.99			_	February-17 March-17							February-17	804			\$49.45 \$52.62	\$5.12	\$54.57		February-17	11.4 9.4	0	0.3	11.7	11.4 9.4	11.9	÷ • • • • •
1/0/00				÷ · ·	++++	+++++	÷		_					1/0/00			March-17	864 708			\$52.62	\$4.88	\$57.50		March-17	9.4	0	0.3	9.7		9.8	
			April-17	258	\$334	\$1.29			_	April-17							April-17				<b>+---</b>	\$1.56	\$39.21		April-17	2.9	0	0.3	0.1	2:0	0.0	φ012
1/0/00			May-17	141 41	\$189 \$82	\$1.34 \$2.0			_	May-17 June-17				1/0/00			May-17	624 708			\$38.68 \$46.25	\$2.75 \$2.26	\$41.43	\$0.066 \$0.069	May-17	1.6	0	0.2	1.8	1.0	1.6	\$228 \$129
1/0/00			June-17 Julv-17	21		\$2.0				Julie-17 July-17				1/0/00			June-17 Julv-17	624			\$46.25	\$2.20	\$46.51	\$0.069	June-17 Julv-17	0.5	0	0.3	0.7	0.5	0.5	
1/0/00			August-17	Z1 72	\$04 \$115	\$2.5 \$1.5				August-17				1/0/00			August-17	576			\$31.71	\$2.42	\$51.82		August-17	0.2	0	0.2	1.0		0.2	
1/0/00			September-17	92		\$1.5			-	September-17				1/0/00		1	September-17	936			\$69.36	\$8.27	\$77.63		September-17	0.0	0	0.2	1.0		1.1	
1/0/00			October-17	265	\$369	\$1.4			-	October-17				1/0/00			October-17	684			\$45.89	\$2.05	\$47.94	+	October-17	2.0	0	0.4	3.2		3.1	
1/0/00			November-17	203	\$949	\$1.3		+	+	November-17			+	1/0/00		+	November-17	636			\$39.54	\$2.03	\$40.97		November-17	10.9	0	0.3	11.1		11.4	÷
1/0/00			December-17	1.366		\$0.8		1		December-17		t	1	1/0/00		1	December-17	564			\$38.13	\$1.46			December-17	15.2	0	0.2	15.4		15.9	+
1/0/00			January-18	1,300		\$0.00		1		January-18	1	t	1	1/0/00		1	January-18	756			\$35.21	\$0.00		\$0.070	January-18	12.9	0	0.2	13.4			\$1,240
1/0/00			February-18	964		\$1.30			1	February-18				1/0/00			February-18	684			\$43.97	\$0.00			February-18	10.7	0	0.3	11.0		11.2	1 1
1/0/00			March-18	643		\$1.30			1	March-18				1/0/00			March-18	696			\$65.53	\$0.00	\$65.53		March-18	7.1	0	0.3	7.4		7.5	
1/0/00			April-18	643		\$1.30			1	April-18				1/0/00			April-18	432			\$17.22	\$0.00	\$17.22	<b>40</b> . <b>00</b>	April-18	7.1	0	0.2	7.3	7.1	7.5	
1/0/00			May-18	171	\$261	\$1.53	3	1	1	May-18	1	1	1	1/0/00		1	May-18	504			\$22.45	\$0.00	\$22.45		May-18	1.9	0	0.2	2.1	1.9	2.0	
1/0/00			June-18	51	\$102	\$1.99		1	1	June-18	8	1	1	1/0/00		1	June-18	744			\$42.67	\$0.00	\$42.67	\$0.057	June-18	0.6	0	0.3	0.8	0.6	0.6	
1/0/00			July-18	88	\$151	\$1.7	1			July-18	8			1/0/00			July-18	1,152			\$73.66	\$0.00	\$73.66	\$0.064	July-18	1.0	0	0.4	1.4	1.0	1.0	\$224
1/0/00			August-18	43	\$88	\$2.0	5			August-18	8			1/0/00			August-18	1,320			\$97.97	\$0.00	\$97.97	\$0.074	August-18	0.5	0	0.5	1.0	0.5	0.5	\$186
			× 1					·	·		·		·			·									~ 1						•	·
Annual (S	eptember	2016-2017)		5,746	\$5,926	\$1.0	3				0	\$0						8,184	3.60				\$842	\$0.103		63.84	0.0		66.95	63.84	67.04	
nnual (S	ontombor	2017-2018)		6.463	\$7.466	\$1.10	6				0	\$0						9.108					\$605	\$0.066		71.81	0.0	3.5	75.26	71.81	75.40	\$8,070



OH Library - 7 Maple Aven	lue																														
		Gas							Oil									Electricity									T	otal Energy			
																				Energy Production	Delivery (Demand)		Energ		Gas	Oil	Electricity	Total	Total Site Heating	Total Source Heating	e Total Co
From To	Days	Month	therms	Cost	\$/therm	From	То	Days	Month	Gallons	Cost	\$/gal	From	То	Days	Month	kWh	kW	\$/kW	Cost	Cost	Total Cost	\$/kWh \$/kW	n Month	(kBtu/ft <sup>2</sup> )	Total Cost (\$/ft <sup>2</sup> )					
1/0/00		January-15							January-15	5						January-15								January-		0 0.	.0 0.0	0.0	0.0	0.	0 \$0
1/0/00		February-15							February-15	5						February-15	i i							February-		-	.0	0.0	0.0	0.	.0 \$0
1/0/00		March-15							March-15	ō						March-15						_		March-		-	0.0	0.0	0.0	0.	φυ
1/0/00 1/0/00	_	April-15 May-15							April-15	-						April-15 May-15								April- Mav-		-	.0 0.0	0.0	0.0	0.	.0 \$0
1/0/00		June-15							May-15 June-15	-			1/0/00			June-15	,					-		June-		-	0 0.0	0 0.0	0.0	0.	0 \$0
1/0/00	-	July-15							July-15	5	<u> </u>		1/0/00			July-15					-			Jule- Julv-			0.0	0.0	0.0	0.	φο
1/0/00		August-15							August-15	5			1/0/00			August-15					-			August-		-	0 0.0	0.0	0.0	0.	0 \$0
1/0/00	-	September-15					-		September-15	5			1/0/00			September-15					-			September-		-	0 0 0	0.0	0.0	0.	0 \$0
1/0/00		October-15							October-15	5			1/0/00			October-15								October-		0 0	.0 0.0	0 0.0	0.0	0.	.0 \$0
1/0/00		November-15							November-15	5			1/0/00			November-15								November-		-		0.0	0.0	0.	.0 \$0
1/0/00	1	December-15					1		December-15	5			1/0/00			December-15							1 1	December-	-15 0.0	0 0.	.0 0.0	0.0	0.0	0.	.0 \$0
1/0/00		January-16							January-16	6			1/0/00			January-16								January-	-16 0.0	0 0.	.0 0.0	0.0	0.0	0.	.0 \$0
1/0/00		February-16							February-16	6			1/0/00			February-16								February-			.0 0.0	0.0	0.0	0.	.0 \$0
1/0/00		March-16							March-16	6			1/0/00			March-16	i							March-		-		0.0	0.0	0.	φθ
1/0/00		April-16							April-16				1/0/00			April-16								April-				0	0.0	0.	
1/0/00		May-16							May-16	6			1/0/00			May-16		28.80		\$341.89		\$1,041.47	7 \$0.100 \$0.0			-	-		0.0	0.	.0 \$342 0.0143
1/0/00		June-16							June-16	5			1/0/00			June-16	13,360	47.20		\$690.43		5 \$1,807.69	9 \$0.135 \$0.0			-			0.0	0.	.0 \$690 0.0289
1/0/00	_	July-16		5 \$34					July-16	6	<b>↓</b> → ↓		1/0/00			July-16	17,440	53.60		\$1,033.59		\$2,369.88	3 \$0.136 \$0.0			-	.0 4.5	-	0.0	0.	.0 \$1,068 0.04483 .0 \$1.016 0.0426
1/0/00		August-16 September-16		3 \$32	#DIV/0! \$10.				August-16 September-16	5			1/0/00			August-16 September-16	18,240 18,640	60.00 64.00		\$1,015.76		7 \$2,426.63 \$2,794.03	3 \$0.133 \$0.0 3 \$0.150 \$0.0						0.0		.0 \$1,016 0.0426 .0 \$1.281 0.0537
1/0/00		October-16		3 \$32 4 \$35					October-16				1/0/00			October-16	18,640	64.00 54.40		\$938.55	+ - , + - +	5 \$2,794.03 7 \$2.199.32	2 \$0.150 \$0.0 2 \$0.154 \$0.0			-		8 4.8 7 3.7	0.0	0.	0 \$1,281 0.0537
1/0/00		November-16		6 \$38					November-16	5	<u> </u>		1/0/00			November-16	12,240	43.20				5 \$1,668.09	9 \$0.134 \$0.0			-	0 31	2 32	0.0	0.	.0 \$605 0.0254
1/0/00		December-16		12 \$74					December-16	3	<u> </u>		1/0/00			December-16	11.440	31.20		\$620.03		9 \$1,480.82	2 \$0.129 \$0.0			-	0 30	2 3.2	0.0	0.	
1/0/00		January-17		\$38					January-17	7	<u> </u>		1/0/00			January-17	13,200	33.60		\$654.56		3 \$1.540.19	9 \$0.117 \$0.0				0.0	0.0	0.0	0.	
1/0/00	-	February-17	2.8	<i>444</i>			-		February-17	7			1/0/00			February-17	12,400	38.40		\$774.89		\$1,715.72	2 \$0.138 \$0.0				0 3.2	2 15.3	12.1	12.	+++++
1/0/00		March-17	1-	42 \$2,132					March-17	7			1/0/00			March-17	11.360	29.60		\$715.96			9 \$0.135 \$0.0				.0 2.9	9 12.3	9.4	9.	.9 \$2.848 0.1195
1/0/00		April-17		46 \$209					April-17	7			1/0/00			April-17	9,920	31.20		\$547.18		3 \$1,298.01	1 \$0.131 \$0.0			6 0	.0 2.6	6 3.2	0.6	0.	.6 \$756 0.0317
1/0/00		May-17		6 \$37	\$6.	.19			May-17	7			1/0/00			May-17	8,640	33.60	\$22.74	\$556.09	\$791.87	7 \$1,347.96	6 \$0.156 \$0.0	64 May-	-17 0.0	0 0.	.0 2.2	2 2.3	0.0	0.	.0 \$593 0.0249
1/0/00		June-17		4 \$37	\$9.	.17			June-17	7			1/0/00			June-17		47.20		\$774.37		3 \$1,947.90	0 \$0.166 \$0.0				.0 3.0	0 3.1	0.0	0.	
1/0/00		July-17		6 \$55	\$9.	.17			July-17	7			1/0/00			July-17	12,640	53.60		\$1,045.26	\$ \$1,418.74	\$2,464.00	0 \$0.195 \$0.0	83 July-	-17 0.0	0 0.	.0 3.3	3 3.3	0.0	0.	.0 \$1,100 0.0461
1/0/00		August-17		3 \$33					August-17	7			1/0/00			August-17	11,360	52.80		\$852.00	\$1,331.69		9 \$0.192 \$0.0				.0 2.9	9 2.9	0.0	0.	.0 0000 0.0011
1/0/00		September-17		3 \$32		-			September-17	7			1/0/00			September-17	12,880	52.00		\$985.34		2 \$2,336.06	6 \$0.181 \$0.0			-		3 3.3	0.0	0.	.0 \$1,018 0.0427
1/0/00		October-17		3 \$35					October-17	7			1/0/00			October-17	11,760	50.40			\$1,277.57		3 \$0.177 \$0.0				0.0	0 3.0	0.0	0.	.0 \$835 0.0350
1/0/00		November-17		3 \$35	<i>¥</i>				November-17	1293	++,++=	\$2.39	1/0/00			November-17	10,800	52.00		\$686.16		2 \$2,073.68	3 \$0.192 \$0.0			-			7.5		.6 \$3,814 0.1601
1/0/00	_	December-17	1,4						December-17	7 1328	\$3,176	\$2.39	1/0/00			December-17	8,960	30.40		\$603.18 \$506.93		4 \$1,508.02	2 \$0.168 \$0.0					3 16.0	13.7	14.	.1 \$5,032 0.2112 .4 \$4,386 0.1841
		January-18	3,7			-			January-18	3			1/0/00			January-18	10,160	31.20				\$1,430.03	3 \$0.141 \$0.0			-	.0 2.6	6 18.2 6 17.2	15.6		.4 \$4,386 0.1841
1/0/00		February-18 March-18	3,4	90 \$4,348 94 \$2.693					February-18 March-18	2	<u>├</u>		1/0/00			February-18 March-18	9,920 8,720	29.60 26.40		\$671.43 \$854.67		) \$1,475.93 1 \$1.618.68	3 \$0.149 \$0.0 3 \$0.186 \$0.0				0 2.0	2 13.1	14.7		.4 \$3,548 0.1489
1/0/00	+	April-18	1.	94 \$2,693 98 \$1.001			+	<u>├</u>	April-18	2	<u>↓                                      </u>		1/0/00			April-18	9.040	28.80		\$654.67		51,010.00	2 \$0.127 \$0.0				0 2.2	3 57	10.5		.4 \$3,546 0.1469
1/0/00	+	May-18		72 \$134			+		Mav-18	2			1/0/00			May-18		26.40		\$394.02			3 \$0.134 \$0.0				.0 2.	0.1	0.3	0	
1/0/00	1	June-18		4 \$37					June-18	3	<u>├                                    </u>		1/0/00			June-18	8,400	46.40		\$520.70		9 \$1.764.39	9 \$0.210 \$0.0			-	.0 23	2 2.2	0.0	0.	.0 \$558 0.0234
1/0/00	1	July-18		2 \$32			1		Julv-18	3	<u>                                      </u>		1/0/00			July-18	13.680	59.20			\$1.677.66		9 \$0.190 \$0.0			-	.0 3.5	5 3.5	0.0	0.	
1/0/00	1	August-18		3 \$34			1		August-18	3	1 1		1/0/00			August-18		60.00		++=	\$1,610.99		7 \$0.191 \$0.0				.0 3.7	7 3.7	0.0	0.	.0 \$1,141 0.0479
							•			•						J	,							. 9						•	
unning Annual (September	er 2016)		5,3	04 \$5,903	\$1.	.11					I I						147,840	64.00	\$25.11	\$9,295	5 \$12,878	8 \$22,173	<b>3</b> \$0.150 \$0.0	63	22.2		.0 38.1	1 60.41	22.27	23.3	\$8 \$28,076 1.17
unning Annual (September			12,1	07 \$13,515	\$1.	.12				2,621	\$6,268	\$2.39					126,720	60.00	\$27.18	\$8,451	\$13,396	5 \$21,847	7 \$0.172 \$0.0	67	50.8	3 15.	.2 32.7	7 98.76	66.07	68.7	6 \$41,630 1.7476
verage			8.7	06 \$9,70	9 \$1.	.11				2,621	\$6,268						137,280	62.00	\$ 26.15		\$ 13,137		\$ 0.161 \$ 0.0	65				79.58	44.17	46.07	\$34,853



		Gas						Oil							lectricity									Te	otal Energy			
																	5,	Delivery (Demand)		Energy Cost		Gas	Oil	Electricity	Total	Total Site Heating	Total Source Heating	,
om To	Days	Month	therms	Cost	\$/therm	From	To Day	s Month	Gallons Cost	\$/gal From	To [	Days	Month	kWh	kW	\$/kW	Cost		tal Cost	\$/kWh \$/kWh	Month	(kBtu/ft <sup>2</sup> )	Total Co					
1/0/00		January-15						January-1	5				January-15								January-15	0.0		0.0	0.0	0.0	0.0	0
1/0/00		February-15						February-1	5				February-15								February-15	0.0		0.0	0.0	0.0	0.0	.0
1/0/00		March-15						March-1	5				March-15								March-15	0.0		0.0	0.0	0.0	0.0	0
1/0/00		April-15						April-1	5				April-15								April-15	0.0		0.0	0.0	0.0	0.0	0
1/0/00		May-15						May-1		4 10 10 0			May-15								May-15	0.0		0.0	0.0	0.0	0.0	.0
1/0/00		June-15 Julv-15						June-1		1/0/00			June-15								June-15	0.0		0.0	0.0	0.0	0.0	2
1/0/00								July-1 August-1	-	1/0/00			July-15								July-15 August-15	0.0		0.0	0.0	0.0	0.0	0
1/0/00		August-15 September-15						September-1	-	1/0/00			August-15 September-15								September-15	0.0			0.0	0.0	0.0	.0
1/0/00		October-15						October-1	2	1/0/00			October-15								October-15	0.0			0.0	0.0	0.0	0
1/0/00		November-15			+			November-1	5	1/0/00			November-15						-		November-15	0.0			0.0	0.0	0.0	0
1/0/00		December-15				1		December-1	5	1/0/00			December-15								December-15	0.0		0.0	0.0	0.0	0.0	0
1/0/00		Januarv-16		1	1	1	1 1	Januarv-1	6	1/0/00			January-16								January-16	0.0		0.0	0.0	0.0	0.0	.0
1/0/00		February-16						February-1	5	1/0/00			February-16								February-16	0.0		0.0	0.0	0.0	0.0	.0
1/0/00		March-16						March-1	6	1/0/00			March-16								March-16	0.0		0.0	0.0	0.0	0.0	.0
1/0/00		April-16					1	April-1	6	1/0/00			April-16								April-16	0.0	) (	0.0	0.0	0.0	0.0	.0
1/0/00		May-16					1	May-1	6	1/0/00			May-16	10,360	22.40	\$21.93	\$317.29	\$535.29	\$852.58	\$0.082 \$0.031	May-16	0.0	) (	3.3	3.3	0.0	0.0	.0 \$3
1/0/00		June-16						June-1	6	1/0/00	)		June-16	9,960	30.80	\$22.69	\$507.85	\$728.42 \$1	1,236.27	\$0.124 \$0.051	June-16	0.0	) (	3.2	3.2	0.0	0.0	.0 \$5
1/0/00		July-16	5	\$34		9		July-1		1/0/00			July-16	11,520	32.00			\$799.96 \$1		\$0.128 \$0.059	July-16	0.0		3.7	0.1	0.0	0.0	.0 \$7
1/0/00		August-16			#DIV/0!			August-1	6	1/0/00			August-16	11,760	38.40	\$21.93		\$903.80 \$1		\$0.133 \$0.056		0.0		3.8	3.8	0.0	0.0	.0 \$6
1/0/00		September-16	3	\$32				September-1	6	1/0/00		:	September-16	12,880	32.40	\$22.69		\$794.32 \$1		\$0.128 \$0.066		0.0		0 4.1	4.2	0.0	0.0	.0 \$8
1/0/00		October-16	4	\$35				October-1	6	1/0/00			October-16	10,240	31.60	\$21.93		\$736.86 \$1		\$0.137 \$0.065	October-16	0.0		3.3	3.3	0.0	0.0	.0 \$7
1/0/00		November-16	6	\$38				November-1	6	1/0/00			November-16	11,520	29.60			\$749.31 \$1		\$0.110 \$0.045		0.0	, ,	3.7		0.0	0.0	.0 \$5
1/0/00		December-16	12	\$74				December-1	5	1/0/00			December-16	11,040	28.80			\$743.17 \$1		\$0.120 \$0.052	December-16	0.1		3.6	3.6	0.1	0.1	.ι φυ
1/0/00		January-17 February-17	2 872	\$38				January-1 February-1	7	1/0/00			January-17	11,400	24.80	\$24.20		\$646.44 \$1	.,	\$0.104 \$0.047	January-17	0.0		3.7	3.7	0.0	0.0	.0 \$5 7 \$3.8
1/0/00		Hebruary-17 March-17	2,872	φ0,100				Hebruary-1 March-1		1/0/00			February-17 March-17	11,280 10,560	22.80 20.80	\$23.19 \$25.97		\$562.17 \$1 \$572.50 \$1		\$0.110 \$0.060 \$0.114 \$0.060	February-17 March-17	12.1		3.6		12.1 9.4	12.1	.7 \$3,8 .9 \$2,7
1/0/00		April-17	2,242	<i>+</i> -, · · · -				April-1		1/0/00			April-17	9,920	20.80		<i><b></b></i>	\$632.61 \$		\$0.115 \$0.051	April-17	9.4		3.4	3.8	9.4	9.5	.9 ,92,7 .6 \$7
1/0/00		Mav-17	140	\$209	· • • • • •			Mav-1		1/0/00			Mav-17	9,920	20.40	\$23.55		\$509.68 \$		\$0.116 \$0.060	Mav-17	0.0		3.2	3.0	0.0	0.0	.0 \$5
1/0/00		June-17	4	\$37				June-1		1/0/00			June-17	9,760	31.60	\$24.36		\$785.50 \$1		\$0.145 \$0.064	June-17	0.0		) 31	3.2	0.0	0.0	.0 \$6
1/0/00		July-17		\$55				July-1		1/0/00			July-17	11.960	34.00			\$900.44 \$	.,	\$0.155 \$0.080	July-17	0.0		3.9	÷.=	0.0	0.0	.0 \$1.0
1/0/00		August-17	3	\$33				August-1		1/0/00			August-17	11,160	34.40	\$23.55		\$868.01 \$1		\$0.150 \$0.072	August-17	0.0		3.6		0.0	0.0	.0 \$8
1/0/00		September-17	3	\$32		8		September-1	7	1/0/00			September-17	10,480	30.40	\$24.36	\$778.75	\$796.15 \$1	1,574.90	\$0.150 \$0.074	September-17	0.0	)	3.4	3.4	0.0	0.0	.0 \$8
1/0/00		October-17	3	\$35		1	1	October-1	7	1/0/00			October-17	9,360	29.20	\$23.55		\$747.43 \$1		\$0.146 \$0.066	October-17	0.0	)	3.0	3.0	0.0	0.0	.0 \$6
1/0/00		November-17	3	\$35	5 \$11.7	6	1	November-1	1293 \$3,092	\$2.39 1/0/00			November-17	9,480	26.00	\$25.17	\$564.38	\$706.90 \$1	1,271.28	\$0.134 \$0.060	November-17	0.0	) 7.	5 3.1	10.6	7.5	7.6	.6 \$3,6
1/0/00		December-17	1,420	\$1,253				December-1	1328 \$3,176	\$2.39 1/0/00			December-17	10,000	21.20	\$25.98	\$636.39	\$628.07 \$1	1,264.46	\$0.126 \$0.064	December-17	6.0	) 7.	7 3.2	16.9	13.7	14.1	.1 \$5,0
1/0/00		January-18	3,715	φ0,010				January-1	3	1/0/00			January-18	11,120	25.60	\$26.45		\$741.16 \$1		\$0.115 \$0.049	January-18	15.6		3.6	i 19.2	15.6	16.4	φ.,.
1/0/00		February-18	3,490					February-1	3	1/0/00			February-18	10,440	23.60	\$25.91		\$635.72 \$1		\$0.127 \$0.066		14.7		3.4		14.7	15.4	
1/0/00		March-18	2,594	+=,	÷			March-1	3	1/0/00			March-18	10,800	22.40		\$1,038.39	\$641.51 \$1	.,	\$0.156 \$0.096	March-18	10.9		3.5	14.4	10.9	11.4	÷.,
1/0/00		April-18	798	φ1,001				April-1		1/0/00			April-18	10,280	22.80			\$593.34 \$1		\$0.100 \$0.042		3.4		3.3	0.1	3.4	3.0	.5 \$1,4
1/0/00		May-18	72	\$134				May-1		1/0/00			May-18	9,800	26.00			\$674.90 \$1		\$0.116 \$0.047	May-18	0.3		3.2	3.5	0.3	0.3	.3 \$5
1/0/00		June-18	4	\$37				June-1	5	1/0/00			June-18	10,000	26.00	\$25.91		\$701.00 \$1		\$0.130 \$0.060		0.0		3.2	3.2	0.0	0.0	.0 \$6
1/0/00		July-18	2	\$32				July-1	5	1/0/00			July-18	11,880	36.80	\$27.64		\$1,045.26 \$1		\$0.155 \$0.067	July-18	0.0		3.8	3.8	0.0	0.0	.0 \$8
1/0/00		August-18	3	\$34	\$11.2	Ø	I I	August-1	5	1/0/00	1		August-18	12,000	32.80	\$25.05	\$918.19	\$893.96 \$1	1,812.15	\$0.151 \$0.077	August-18	0.0	,	3.9	3.9	0.0	0.0	.0 \$9
nual (September 2016)			5.310	\$5.903	\$1.1	4	1 1	1	1	<u> </u>	<u> </u>			130.760	34.40	\$25.09	\$7.898	\$8.501	\$16 300	\$0.125 \$0.060	1	22.29	0.0	42.1	64.40	22.29	23.4	1 \$22.3
nual (September 2016) nual (September 2017)			5,310			-			2.621 \$6.268	\$2.39		I		130,760	34.40 36.80				\$16,399	\$0.125 \$0.060		22.29				22.29	68.70	··
inuai (September 2017)			12,107	\$10,010	φ1.1.	4			2,021 90,200	ψ2.00				125,640	35.60			1		\$ 0.130 \$ 0.062	1	50.05	10	40.3	85.46	44.18	46.08	\$29,4



Appendix C:


Equipment Cut Sheets





# Model: Solatube 750 DS-O Open Ceiling (21 in./530 mm Daylighting System)

ect:								
ation:								
:								
uct Specifications	Appear in CSI D	ivision 08, Secti	on 08 62 23.	For budge	ting and quo	otations use onl	y. Qty:	
lodel	Capture	Zone		Transfer Z	one	Deli	very Zone	
0DS-0 <sup>—</sup> 1 2	– 2a	3		4	4a	5	—5a	6
		) DS-O (21 in./5	30 mm Daylig	hting System				
pture Zone								
Acrylic Outer De	ome + Polycarbo	onate Inner Dom	e (Required fo	or High Veloc	ity Hurricane	Zones, FM, an	d FEMA)	
Security Bar Dome Security	PB D Kit** PBC D	ome Edge Prote				<b>)</b> *+		
Flashings 4-inch/100mm Self Mounted Curb Cap (Curb by Others	s)	Self M (FM A	Nounted	8	Self N	Nounted		
	ation: : uct Specifications odel DDS-O 1 2 Model DS-O SolaMaster pture Zone Acrylic Dome Acrylic Dome Acrylic Outer Do Acrylic Outer Do Acrylic Outer Do Acrylic Dual Do Dome Options Security Bar Dome Security dome required for Dome Flashings 4-inch/100mm Self Mounted Curb Cap	tion:	tion:	tion:	<pre>:</pre>	tion:: : : : : : : : : : : : : :	tion:: ::: ::: ::: ct Specifications Appear in CSI Division 08, Section 08 62 23. For budgeting and quotations use onl odel DS-0 Capture Zone Deli DS-0 2 2a 3 3a 4 4a 5 Model Nodel NS-0 SolaMaster <sup>®</sup> Solatube 750 DS-0 (21 in./530 mm Daylighting System) Open Ceiling Pture Zone Pture Zone Pome Acrylic Dome + Acrylic Inner Dome Acrylic Outer Dome + Acrylic Inner Dome Acrylic Outer Dome + Polycarbonate Inner Dome (Required for High Velocity Hurricane Zones, FM, an Acrylic Outer Dome + Polycarbonate Inner Dome (Required for High Velocity Hurricane Zones, FM, an Acrylic Outer Dome + Polycarbonate Inner Dome (Required for FM)** Coure Options (Leve black if not desired) Security Bar PB Dome Edge Protection Band (Required for FM)** dome required for Dome Security Kit* Flashings 4-inch/100mm Self Mounted (FM Approved*) Curb Cap FSM Metal Roof FSM Metal Roof	tion:



#### 3a Flashing Options (Leave blank if not desired)

- T12\* Roof Flashing Turret Extension 12 in./300 mm
- T24\* Roof Flashing Turret Extension 24 in./600 mm
- **T36\*** Roof Flashing Turret Extension 36 in./900 mm
- **T48\*** Roof Flashing Turret Extension 48 in./1200 mm
- MCF Membrane Counter Flashing (use with F8 or F11)

Assuming 8-inch/200mm self flashing\*\*\*

- **FI** Flashing Insulator
- CI Curb Insulator
- CCI Curb Cap Insulation (Required for FEMA)

\* Specify additional extension tubes in #4

\*\* Only product that is FM approved. Must use Dome Polycarbonate (DP). It is required that a dome Edge Protection Band (PB) is used with FM approved flashings and (F8 & F11). The Dome Edge Protection Band for the Curb Cap (PBC) must be used with FM approved Curb Cap (FC).

## Transfer Zone

#### 4 Extension Tubes Required\*

Run measured from top of flashing to diffuser along centerline of tubing using 24"/600mm lengths. See 4a for optional 48"/1200mm length.

See 4a for optional 48"/1200mm length.	
E2**         Two Extension Tubes – Max Run = 46"/1170mm         E8**         Ei           E3**         Three Extension Tubes – Max Run = 68"/1730mm         E9**         Ni           E4**         Four Extension Tubes – Max Run = 90"/2285mm         E10**         Te           E5**         Five Extension Tubes – Max Run = 112"/2845mm         EXX**         Te	Seven Extension Tubes – Max Run = 156"/3960mm Eight Extension Tubes – Max Run = 178"/4520mm line Extension Tubes – Max Run = 200"/5080mm Sen Extension Tubes – Max Run = 222"/5640mm Solid Run Length to be Determined by Bidding Contractor
<ul> <li>*At least one 24"/600mm or 48"/1200mm extension tube required for diffuser</li> <li>*Compatible with dome ring to be used as a top tube or extension tube</li> <li>***Total tube run will vary depending on flashing used</li> <li><b>4a Product Options</b> (Leave blank if not desired)</li> </ul>	
<ul> <li>A1 One 0-90 Degree Extension Tube (Angle Adapter)</li> <li>A2 Two 0-90 Degree Extension Tubes (Angle Adapter)</li> <li>E Wire Suspension Kit (50 ft./15m) (Required for FEMA)</li> <li>EL Optional 48"/1200mm Extension Tube (Substitute one 48"/1200mm for two 24"/600mm above)</li> </ul>	<ul> <li>AK 16"/400mm Top Tube Angle Adapter and 16"/400mm Bottom Tube Angle Adapter</li> <li>TA 16"/400mm Top Tube Angle Adapter</li> <li>BA 16"/400mm Bottom Tube Angle Adapter</li> <li>TIP Thermal Insulation Panel</li> <li>R Trim Ring</li> </ul>
Delivery Zone       5     Diffuser Lens	
L1 OptiView <sup>®</sup> Diffuser L2 Prismatic Diffuse	er <b>L2P</b> Prismatic Diffuser Polycarbonate (Required for FEMA)

5a	Options	(Leave blank if not desired)	
		(20410 bidi itti 1101 400104)	
		(	

D Daylight Dimmer™

D1 0-10V Daylight Dimmer™

#### 6 Measurement Standard

M Metric I

Accessories (Order separately)

Example

- **SW** Low voltage switch (white) required to operate Solatube Daylight Dimmers. Note: Only one switch is required per ten (10) synchronously controlled dimmers. (For 'D' only)
- S1 Low voltage 0-10V switch (white) required to operate Solatube 0-10V Daylight Dimmers. Only one switch is required per forty-eight (48) synchronously controlled dimmers. (For 'D1' only) Note: For use when no controls have been specified and customer is looking for an off-the-shelf solution. If different controls have been specified please source those from others.
- CA Two Conductor/22 AWG Low Voltage Cable 500 ft./150m (For 'D' only)


Imperial

TR20 UL Listed Class 2 Transformer 24 VAC, Rated 20 VA (For 'D1' only)


TR96 UL Listed Class 2 Transformer 24 VAC, Rated 96 VA (For 'D1' only)

## S750 DS-O-DPI-F8-E2-L1-M

SolaMaster Series<sup>®</sup> 750 DS-O (21 in./530 mm Daylighting System), Acrylic Outer Dome + Polycarbonate Inner Dome, 8-inch/200mm High Self Mounted Flashing, Two Extension Tubes and OptiView<sup>®</sup> Diffuser. For metric installations.




89+5-€6' G75@9''`.%




GC @5H 69'+) \$'8GC f&%:=B#) ' \$'A A Ł

×



%



# SUBMITTAL DATA: MSZ-GL12NA & MUZ-GL12NA 12,000 BTU/H WALL-MOUNTED HEAT PUMP SYSTEM



#### Job Name:

System Reference:

Date:



#### **GENERAL FEATURES**

- · Slim wall-mounted indoor units provide zone comfort control
- · The outdoor unit powers the indoor unit, and should a power outage occur, the system is automatically restarted when power returns
- INVERTER-driven compressor and LEV provide high efficiency and comfort while using only the energy needed to maintain maximum performance
- · Multiple fan speed options: Quiet, Low, Medium, High, Super-high, Auto
- · Multiple control options available:
- Hand-held Remote Controller (provided with unit)
- kumo cloud® smart device app for remote access
- Third-party interface options
- Wired or wireless controllers
- · Hot-Start Technology: no cold air rush at equipment startup or when restarting after Defrost Cycle
- Quiet operation
- · Smart Set: recalls a preferred preset temperature setting at the touch of a button
- · Blue Fin anti-corrosion treatment applied to the outdoor unit heat exchanger for increased coil protection and longer life

# SPECIFICATIONS: MSZ-GL12NA & MUZ-GL12NA

	Maximum Canacity		12 000
	Maximum Capacity	Btu/h	13,600
	Rated Capacity	Btu/h	12,000
	Minimum Capacity	Btu/h	1,500
Cooling <sup>1</sup>	Maximum Power Input	W	1,300
	Rated Power Input	W	920
	Moisture Removal	Pints/h	2.5
	Sensible Heat Factor		0.77
	Power Factor	%	95 / 95
	Maximum Capacity	Btu/h	18,100
	Rated Capacity	Btu/h	14,400
Heating at 47°F <sup>2</sup>	Minimum Capacity	Btu/h	2,000
Heating at 47 F	Maximum Power Input	W	1,620
	Rated Power Input	W	1,100
	Power Factor	%	96 / 96
	Maximum Capacity	Btu/h	12,000
	Rated Capacity	Btu/h	9,200
Heating at 17°F <sup>3</sup>	Maximum Power Input	W	1,240
	Rated Power Input	W	870
	Maximum Capacity	Btu/h	9,790
Heating at 5°F <sup>4</sup>	Maximum Power Input	W	1,020
Heating at -4°F <sup>5</sup>	Maximum Capacity	Btu/h	7,920
	SEER		23.1
	EER <sup>1</sup>		13.0
	HSPF (IV)		12.5
Efficiency	COP at 47°F <sup>2</sup>		3.84
Efficiency	COP at 17°F in Maximum Capacity <sup>3</sup>		2.84
	COP at 5°F in Maximum Capacity <sup>4</sup>		2.81
	ENERGY STAR <sup>®</sup> Certified (ENERGY STAR products a an EPA-recognized Certification Body.)	re third-party certified by	YES
	Voltage, Phase, Frequency		208/230V, 1 phase, 60Hz
	Guaranteed Voltage Range	V AC	187 - 253
	Voltage: Indoor - Outdoor, S1-S2	V AC	208 / 230
Electrical	Voltage: Indoor - Outdoor, S2-S3	V DC	24
	Voltage: Indoor - Remote Controller		Wireless Type
	Recommended Fuse/Breaker Size	A	15
	Recommended Wire Size (Indoor - Outdoor)	AWG	14
	MCA	A	1
	МОСР	Α	15
Indoor Unit	Blower Motor Full Load Amperage	A	0.76
	Blower Motor Output	W	30
	Airflow Rate at Cooling, Dry	CFM	399-321-237-170-145
	, anow rate at cooling, bry		000 021-201-110-140

# SPECIFICATIONS: MSZ-GL12NA & MUZ-GL12NA

	Airflow Rate at Cooling, Wet	CFM	364-286-201-134-109
	Airflow Rate at Heating, Dry	CFM	406-321-237-170-145
	Sound Pressure Level (Cooling)	dB(A)	45-37-30-22-19
	Sound Pressure Level (Heating)	dB(A)	43-37-30-22-19
	Drain Pipe Size	In. (mm)	5/8 (15.88)
	Heat Exchanger Type		Plate fin coil
	External Finish Color		Munsell 1.0Y 9.2/0.2
		W: In. (mm)	31-7/16 (798)
	Unit Dimensions	D: In. (mm)	9-1/8 (232)
		H: In. (mm)	11-5/8 (295)
		W: In. (mm)	33-1/2 (850)
	Package Dimensions	D: In. (mm)	12 (300)
		H: In. (mm)	14 (350)
	Unit Weight	Lbs. (kg)	22 (10)
	Package Weight	Lbs. (kg)	26 (11.5)
ndoor Unit Operating	Cooling Intake Air Temp (Maximum / Minimum)*	°F	90 DB, 73 WB / 67 DB, 57 WB
emperature Range	Heating Intake Air Temp (Maximum / Minimum)	°F	80 DB / 70 DB
	MCA	A	9
	МОСР	A	15
	Fan Motor Full Load Amperage	A	0.5
	Fan Motor Output	W	55
	Airflow Rate	CFM	1,229 / 1,172
	Refrigerant Control		LEV
	Defrost Method		Reverse cycle
	Heat Exchanger Type		Plate fin coil
	Sound Pressure Level, Cooling <sup>1</sup>	dB(A)	49
	Sound Pressure Level, Heating <sup>2</sup>	dB(A)	51
	Compressor Type		DC INVERTER-driven
	Compressor Model		SNB092FQAMT
Outdoor Unit	Compressor Rated Load Amps	A	6.6
	Compressor Locked Rotor Amps	A	8.2
	Compressor Oil Type // Charge	OZ.	FV50S // 11.8
	External Finish Color		Munsell 3Y 7.8/1/1
	Base Pan Heater		Optional
		W: In. (mm)	31-1/3 (800)
	Unit Dimensions	D: In. (mm)	11-1/5 (285)
		H: In. (mm)	21-5/9 (550)
		W: In. (mm)	37 (940)
	Package Dimensions	D: In. (mm)	14-15/16 (380)
		H: In. (mm)	24-13/16 (630)
	Unit Weight	Lbs. (kg)	81 (37)

# SPECIFICATIONS: MSZ-GL12NA & MUZ-GL12NA

	Package Weight	Lbs. (kg)	89 (40)
	Cooling Air Temp (Maximum / Minimum)*	°F	115 / 14
Outdoor Unit Operating	Cooling Thermal Lock-out / Re-start Temperatures**	°F	-1 / 3
Temperature Range	Heating Air Temp (Maximum / Minimum)	°F	75 / -4
	Heating Thermal Lock-out / Re-start Temperatures**	°F	-9 / -4
Refrigerant	Туре	R410A	
	Charge	Lbs, oz	2, 9
	Gas Pipe Size O.D. (Flared)	In. (mm)	3/8 (9.52)
Piping	Liquid Pipe Size O.D. (Flared)	In. (mm)	1/4 (6.35)
	Maximum Piping Length	Ft. (m)	65 (20)
	Maximum Height Difference	Ft. (m)	40 (12)
	Maximum Number of Bends		10

#### Notes

AHRI Rated Conditions	<sup>1</sup> Cooling (Indoor // Outdoor)	°F	80 DB, 67 WB // 95 DB, 75 WB
(Rated data is determined at a fixed	<sup>2</sup> Heating at 47°F (Indoor // Outdoor)	°F	70 DB, 60 WB // 47 DB, 43 WB
compressor speed)	<sup>3</sup> Heating at 17°F (Indoor // Outdoor)	°F	70 DB, 60 WB // 17 DB, 15 WB
Conditions	<sup>4</sup> Heating at 5°F (Indoor // Outdoor)	°F	70 DB, 60 WB // -4 DB, -5 WB
	<sup>5</sup> Heating at -4°F (Indoor // Outdoor)	°F	70 DB, 60 WB // -4 DB, -5 WB
*Applications should be r	estricted to comfort cooling only; equipment cooling applicat	ons are not	t recommended for low ambient temperature conditions

\*\*System cuts out in heating mode to avoid thermistor error and automatically restarts at these temperatures.

# ACCESSORIES: MSZ-GL12NA

Anti-allergy Enzyme Filter	□ MAC-408FT-E
Backlit, Wall-mounted, Wireless Controller	D MHK1
Portable Central Controller	D MCCH1
Wired MA Controller <sup>1</sup>	D PAR-33MAA
Simple MA Controller <sup>1</sup>	D PAC-YT53CRAU
Touch MA Controller <sup>1</sup>	□ PAR-CT01MAU-SB
Wired Remote Sensor	□ M21-EAA-307
Wireless Temperature and Humidity Sensor	□ PAC-USWHS003-TH-1
Outside Air Sensor for MHK1	□ MOS1
System Control Interface <sup>2</sup>	□ MAC-333IF-E
Wireless Interface	□ PAC-USWHS002-WF-1
Thermostat Interface	□ PAC-US444CN-1
kumo station®	□ PAC-WHS01HC-E
USNAP Interface	□ PAC-WHS01UP-E
IT Extender	□ PAC-WHS01IE-E
BACnet <sup>®</sup> and MODBUS <sup>®</sup> Interface	□ PAC-UKPRC001-CN-1
Lockdown Bracket for Hand-held Remote Controllers	□ RCMKP1CB
Blue Diamond Sensor Extension Cable — 15 Ft.	□ C13-103
Blue Diamond Alarm Extension Cable — 6.5 Ft.	□ C13-192
Blue Diamond MultiTank — collection tank for use with multiple pumps	□ C21-014
Blue Diamond Rubber Foot Pads	□ F10-010
Mini Condensate Pump — 230 volt application	□ SI30-230
MegaBlue Advanced Blue Diamond Condensate Pump w/ Reservoir & Sensor	□ X87-835 - 110 to 250V
MaxiBlue Advanced Blue Diamond Mini Condensate Pump w/ Reservoir & Sensor (110V) up to 48,000 Btu/h [recommended]	□ X87-711 - 110V
Advanced Blue Diamond Mini Condensate Pump w/ Reservoir & Sensor (208/230V) [recommended]	□ X87-721 - 208/230V
MicroBlue Blue Diamond Mini Condensate Pump (110/208/230V) up to 18,000 Btu/h	□ X85-003
Fascia Kit for MicroBlue Pump – mounts the MicroBlue and sensor directly beneath the indoor unit	□ T18-016
Drain Pan Level Sensor	DPLS2
(30A/600V/UL) [fits 2" X 4" utility box] - Black	□ TAZ-MS303
(30A/600V/UL) [fits 2" X 4" utility box] - White	□ TAZ-MS303W
	1

<sup>1</sup> Requires MAC-333IF-E


<sup>2</sup> Allows indoor units to connect to an MA Controller

# ACCESSORIES: MUZ-GL12NA

Air Outlet Guide	□ MAC-881SG
Drain Socket	□ MAC-860DS
Optional Defrost Heater	□ MAC-640BH-U
Hail Guard	□ HG-B4
Outdoor Unit 3-1/4 inch Mounting Base (Pair) - Plastic	□ DSD-400P
Condensing Unit Mounting Pad 16" x 36" x 3"	DULTRILITE1
Outdoor Unit Stand — 12" High	□ QSMS1201M
Outdoor Unit Stand — 18" High	□ QSMS1801M
Outdoor Unit Stand — 24" High	□ QSMS2401M
Heavy Duty Wall Mounting Bracket— Coated Steel	□ QSWB2000M-1
Heavy Duty Wall Mounting Bracket — 316 Series Stainless Steel	
15' x 1/4" x 15' / 3/8" Lineset (Twin-Tube Insulation)	□ MLS143812T-15
30' x 1/4" x 30' / 3/8" Lineset (Twin-Tube Insulation)	□ MLS143812T-30
50' x 1/4" x 50' / 3/8" Lineset (Twin-Tube Insulation)	□ MLS143812T-50
65' x 1/4" x 65' / 3/8" Lineset (Twin-Tube Insulation)	□ MLS143812T-65


# **DIMENSIONS: MSZ-GL12NA**

#### Unit: inch



# **DIMENSIONS: MUZ-GL12NA**

Unit: inch





1340 Satellite Boulevard, Suwanee, GA 30024 Toll Free: 800-433-4822 www.mehvac.com



FORM# MSZ-GL12NA / MUZ-GL12NA - 201902

# CITY MULTI® Model: PKFY-P12NHMU-E

**MITSUBISHI ELECTRIC** 

Job Name:	Location:
Drawing Reference:	Schedule No.
System No.:	Date:

## **GENERAL FEATURES**



- R410A refrigerant
- Seven sizes from 6,000 to 30,000 Btu/h
- Powerful airflow (CFM)
- · Compact, lightweight, shiny-white, flat-panel design
- Quiet operation
- Multiple fan-speed settings
- · Intake grille filter is easily removed for cleaning
- Built-in receiver is standard

# SPECIFICATIONS

Capacity* Cooling12,000 Btu/h Heating13,500 Btu/h
Power
Power Source
Power Consumption
Cooling0.03 kW
Heating0.03 kW
Current
Cooling0.30 A
Heating0.30 A
Minimum Circuit Ampacity (MCA)0.38 A
Maximum Overcurrent Protection (MOCP) Fuse15 A
External FinishMunsell No. 1.0Y 9.2 / 0.2
External Dimensions
Inches11-5/8 H x 35-3/8 W x 9-13/16 D
mm295 H x 898 W x 249 D

Net Weight Unit29 lbs. / 13 kg
Coil TypeCross Fin (Aluminum Plate Fin and Copper Tube)
Fan Type x QuantityLine Flow Fan x 1 Airflow Rate (Low-Mid-High)320 - 355 - 390 CFM Motor TypeDirect-drive DC Motor Output0030 kW
Air FilterPolypropylene Honeycomb
Refrigerant Piping Dimensions Liquid (High Pressure)1/4" / 6.35 mm (Flare) Gas (Low Pressure)1/2" / 12.7 mm (Flare)
Drainpipe DimensionI.D. 5/8" / 16 mm
Sound Pressure Levels Low-Mid-High34 - 38 - 42 dB(A)
OPTIONS □ Condensate PumpSI3100-230

\* Cooling / Heating capacity indicated at the maximum value at operation under the following conditions:


Cooling: Indoor 80°F (27°C) DB / 67°F (19°C) WB, Outdoor 95°F (35°C) DB

Heating: Indoor 70°F (21°C) DB, Outdoor 47°F (8°C) DB / 43°F (6°C) WB

**Note:** Ventilation air: Providing sufficient ventilation air is an important part of every building design. ASHRAE Standard 62 provides the minimum ventilation air requirement. Also, check local codes.



# Model: PKFY-P12NHMU-E - DIMENSIONS



ISO Authorization System The ISO 9000 series is a plant authorization system relating to quality warranties as stipulated by the ISO. ISO 9001 certifies quality warranties based on the "design, development, production, installation and auxiliary services" for products built at an authorized plant.

Mitsubishi Electric Air Conditioning & Refrigeration Systems Works acquired environmental management system standard ISO 14001 certification.

The ISO 14000 series is a set of standards applying to environmental protection set by the International Standard Organization (ISO).

Certificate Number EC97J1227

¢

ISO 14001

JACO

Certificate Number FM33568



Misubishi Electric & Electronics USA, Inc. 3400 Lawrenceville Suwanee Rd. Suwanee, GA 30024 Tele: 678-376-2900 • Fax: 800-889-9904 Toll Free: 800-433-4822 (#4) www.mehvac.com Specifications are subject to change without notice.

Pool Building EEM - High Efficiency Motors

Шеп

Three Phase Induction Motor - Squirrel Cage

:

#### Customer

Product line			neral NEMA e-Phase	A Premium Eff	ficiency	Product code :	10702566	
Frame Output Poles Frequency Rated voltage Rated current L. R. Amperes LRC No load current Rated speed Slip Rated torque Locked rotor to Breakdown toro Insulation class Service factor Moment of iner Design	rque que	: 2 H : 4 : 60 : 208 : 6.4 : 52.( : 8.2; : 3.5 : 173 : 3.8 : 0.8 : 350 : 330 : 550 : 330 : F : 1.1	8-230/460 \\ 1-5.80/2.90 6-47.6/23.8 x(Code L) 4-3.20/1.60 80 rpm 9 % 28 kgfm ) % ) %	/ ) A 3 A	Temper Duty cy Ambier Altitude Protect Cooling Mountin Rotatio Noise le Starting	t temperature ion degree method ng n <sup>1</sup>	: 27s (cold : 80 K : Cont.(S1) : -20°C to : 1000 m.a : IP21 : IC01 - OI : F-3 : Both (CW : 52.0 dB(A : Direct Or : 19.8 kg	) +40°C s.I. DP / and CCW) A)
Output	25%	50%	75%	100%	Foundatio	on loads		
Efficiency (%) Power Factor	81.2 0.34	82.5 0.58	85.5 0.70	86.5 0.78	Max. trac Max. com	tion	: 68 kgf : 88 kgf	
Bearing type Sealing Lubrication inte Lubricant amou Lubricant type Notes				05 ZZ Bearing Seal - - Mol	bil Polyrex	6204 ZZ Without Bearing  EM	ı Seal	
This revision rep must be elimina (1) Looking the (2) Measured at (3) Approximate manufacturing p (4) At 100% of f	ted. motor from 1m and wit weight sub process.	the shaft e	end. e of +3dB(	A).			s based on tests w ne tolerances stip	
Rev.		Ch	anges Sun	nmary		Performed	Checked	Date
Performed by								
Checked by Date	12/03/2	010					Page 1 / 1	Revision

This document is exclusive property of WEG S/A. Reprinting is not allowed without written authorization of WEG S/A. Subject to change without notice

# DATA SHEET

Three Phase Induction Motor - Squirrel Cage

:



Product line		: W22 Sup Three-Pha	er Premium Efficie ase	-	duct code :	12604363	
				Cata	alog # :	00736EG3	E213T-W22
Frame Output Poles Frequency Rated voltage Rated current L. R. Amperes LRC No load current Rated speed Slip Rated torque Locked rotor tord Breakdown torqu Insulation class Service factor Moment of inerti Design	ue	: 213/5T : 7.5 HP (5 : 2 : 60 Hz : 230/460 : 17.6/8.82 : 134/67.0 : 7.6x(Coc : 6.20/3.10 : 3530 rpn : 1.94 % : 1.52 kgfr : 229 % : 330 % : F : 1.25 : 0.0234 k : A	V A A le J) A n	Locked roto Temperatur Duty cycle Ambient ter Altitude Protection o Cooling me Mounting Rotation <sup>1</sup> Noise level Starting me Approx. we	re rise mperature degree thod 2 ethod	: 66s (cold : 80 K : Cont.(S1) : -20°C to - : 1000 m.a : IP55 : IC411 - T : F-1 : Both (CW : 68.0 dB(A : Direct On : 73.3 kg	) +40°C s.l. EFC / and CCW) A)
Output	50%	75%	100%	Foundation lo	ads		
Efficiency (%)	87.5	89.5	91.0	Max. traction		: 70 kgf	
Power Factor	0.73	0.82	0.86	Max. compre	ssion	: 143 kgf	
Eastroad off inter		•			-		
Lubricant amour Lubricant type			- Mo	bil Polyrex EM	-		
Lubrication inter Lubricant amour Lubricant type Notes This revision repl must be eliminate (1) Looking the m (2) Measured at (3) Approximate manufacturing pr (4) At 100% of fu	aces and ca ed. notor from th 1m and with weight subje ocess.	e shaft end. tolerance of -	ous one, which •3dB(A).	These are av	verage values	based on tests w	
Lubricant amour Lubricant type Notes This revision repl nust be eliminate 1) Looking the m 2) Measured at 3) Approximate nanufacturing pr	aces and ca ed. notor from th 1m and with weight subje ocess.	e shaft end. tolerance of + ect to changes	ous one, which •3dB(A).	These are av power supply MG-1.	verage values		
Lubricant amour Lubricant type Notes This revision repl nust be eliminate 1) Looking the m 2) Measured at 3) Approximate manufacturing pr 4) At 100% of fu	aces and ca ed. notor from th 1m and with weight subje ocess.	e shaft end. tolerance of + ect to changes	ous one, which •3dB(A). •after	These are av power supply MG-1.	verage values y, subject to th	ne tolerances stip	ulated in NEMA
Lubricant amour Lubricant type Notes This revision repl nust be eliminate 1) Looking the m 2) Measured at 3) Approximate manufacturing pr 4) At 100% of fu Rev.	aces and ca ed. notor from th 1m and with weight subje ocess.	e shaft end. tolerance of + ect to changes	ous one, which •3dB(A). •after	These are av power supply MG-1.	verage values y, subject to th	ne tolerances stip	ulated in NEMA

Шeq

This document is exclusive property of WEG S/A. Reprinting is not allowed without written authorization of WEG S/A. Subject to change without notice

Community Center

# Reo Semi Recessed Decor

AIW10373 40 in

JOB NAME: TYPE: NOTES:

# DESCRIPTION

Reo can be partially recessed into the wall cavity, accent the space with side illumination, and provide a sense of depth in a low profile, ADA compliant package. Reo's unique light source orientation illuminates in front of and behind the decorative translucent panel, intensifying a 3D effect. The ability to complement any style comes standard.

## FEATURES & BENEFITS

- Add texture to a space with architectural panels (standard panels are available with other panels available upon request)
- Optional durable wood laminate faceplate option adds a warm, natural texture to a space
- Optional embossed stainless steel-linear and crosshatch face plate option adds a unique, metal accent and texture to a space
- Compliant with Americans with Disabilities Act (ADA) requirements
- Handcrafted in USA

### SPECIFICATIONS


- LIGHT SOURCE: White LED light engine
- LUMEN MAINTENANCE: L70 life = 50,000+ hours
- CCT: 3000K, 3500K, or 4000K
- DRIVER: Integral Class II power supply standard
- DIMMING: 0-10V controls standard to 1% on LED light engines
- EMERGENCY: Emergency battery remote optional
- **CONSTRUCTION:** Formed metal construction provides durable protection for internal components and is recyclable
- FINISH: Choose from more than 30 thermoset polyester powder coat paint colors or brushed aluminum finish. RAL®, Pantone®, or custom finishes available upon request.
- MODIFICATIONS: Consult factory for all modification requests
- **APPROVALS:** ETL listed to UL standards (US & Canada) for use in damp locations; not recommended for exterior applications











### **CONFIGURATOR** -

To configure your spec sheet online, go to <u>www.spilighting.com/AlW10373</u>. Not all options are available in all configurations; consult factory for details.

#### **Required Field \***



# A - LIGHT SOURCE \*

To ensure color consistency, SPI uses precise bin selection and strict quality processes to maintain a 3-step (MacAdam) SDCM on all white LED lampings. Published LED luminaire wattages are calculated using a typical power supply efficiency of 88%; exact wattages may vary based on application. Alternative wattages available upon request.

L36W | White 36W LED Light Engine | Delivered Lumens: 1,467

L72W | White 72W LED Light Engine | Delivered Lumens: 2,933

See last page for finish options

# **B - VOLTAGE**

120-277V | Universal Voltage

# **C - MOUNTING**

Requires recessed mounting. Additional mounting structure and hardware required (by others).

DF\_SMR | Semi-recessed Wall Mount (default)



# **D - LAMP OPTIONS**

Delivered lumens shown are at 4000K CCT; apply multiplier for delivered lumens at other CCT.


<b>ЗОООК</b> <sup>1</sup>   ЗОООК ССТ	
З500К <sup>2</sup>   3500К ССТ	
<b>4000К  </b> 4000К ССТ	

<sup>1</sup> Apply .95 multiplier for delivered lumens <sup>2</sup> Apply .97 multiplier for delivered lumens


# **E - DIFFUSER \***

Other styles available upon request. Contact factory to customize an architectural panel that coordinates with your application.

- HP01 | Silver Hand Painted Acrylic Lens
   HP02 | Beige Hand Painted Acrylic Lens
   HP03 | Amber Hand Painted Acrylic Lens
- TP01 | Translucent Panel, Bear Grass, Vertical



# **F - FACEPLATE OPTIONS**



**SPI**LIGHTING

# **Available Finishes**

Not all finishes are available in all configurations; consult factory for details.

#### **Brushed Aluminum**

BAL	
Brushed Aluminum	

## **Paint Colors**

PT01	PT02	PT03	PT04	PT05
Super White	White	Morning Light	Warm White	Putty
PT06	PT07	PT08	PT09	PT10
Warm Beige	Light Taupe	Medium Taupe	Medium Grey	Dark Grey
PT11	PT12	PT13	PT14	PT15
Black	Dark Chocolate	Warm Grey	Light Grey	Sage
PT16	PT17	PT18	PT19	PT20
Spruce	Red	Deep Red	<sup>Blue</sup>	Dark Green
PT21	PT22	PT27	PT28	PT29
Pearl White (Metallic)	Platinum (Metallic)	Deep Copper (Metallic)	Dark Stainless (Metallic)	Red Brass (Metallic)
PT31	PT32	PT33	PT40	PT41
Medium Bronze (Metallic)	Dark Bronze (Metallic)	Dark Blue	Yellow	Orange
PT42	PT43	PT44	PT45	PT46
Sky Blue	Teal	Green	Purple	Aluminum (Metallic)
<b>PT47</b>	PT48	PT49	PT51	
Deep Red Brass (Metallic)	Brass (Metallic)	Bronze (Metallic)	Matte White	



# Outdoor Unit: 16-TON PUHY-P192TSLMU-A (-BS)

CITYMULTI® (Consists of One PUHY-P120TLMU-A (-BS), One PUHY-P72TLMU-A (-BS), and One CMY-Y100CBK3 Twinning Kit)



#### System Reference:



**DPW Garage** 

OUTDOOR VRF HEAT PUMP SYSTEM

Date:

SUBISH

UNIT OPTION  Standard Model  Seacoast (BS) Model	
ACCESSORIES	

#### 

	Twinning k	(required)CMY-Y100CBK3
_	loint Kit	for dataile can Dina Accossorias Submittal

Joint Kit.....for details see Pipe Accessories Submittal


- Low Ambient Kit .....for details see Low Ambient Kit Submittal □ Snow/Hail Guards Kit......for details see Snow/Hail Guards Kit Submittal
- Base Pan Heater Kit.....for details see Base Pan Heater Kit Submittal

Specifications		System	Module 1	Module 2
Unit Type		PUHY-P192TSLMU-A (-BS)	PUHY-P120TLMU-A (-BS) PUHY-P72TLMU-A (-B	
Nominal Cooling Capacity (208/230V)	Btu/h	192,000	192,000 120,000 72,00	
(208/230V)	Nominal Heating Capacity 208/230V) Btu/h		135,000	80,000
Operating Temperature	Cooling (Outdoor) *2	Refer to Module Data		5~52° C) DB
Range *1	Heating (Outdoor)		-13~60° F (-25~15.5° C) WB	
External Dimensions (H x W x D)	In. (mm)	Refer to Module Data	64-31/32 x 68-29/32 x 29-5/32 (1,650 x 1,750 x 740)	64-31/32 x 36-1/4 x 29-5/32 (1,650 x 920 x 740)
Net Weight	Lbs. (kg)	1,106 (501)	671 (304)	435 (197)
External Finish	1	Refer to Module Data	Pre-coated galvanized steel sheet	
Electrical Power Requirements	Voltage, Phase, Hertz	Refer to Module Data**	208 / 230V, 3	-Phase, 60Hz
Minimum Circuit Ampacity (MCA)	A	Refer to Module Data**	42 / 39	24 / 22
Maximum Overcurrent Protection (MOP)	A	Refer to Module Data**	60 / 60	35 / 35
Piping Diameter (Brazed)				
From Twinning Kit to First	Liquid (High Pressure)	5/8 (15.88)	Refer to System Data	
Joint or Header (In. / mm)	Gas (Low Pressure)	1-1/8 (28.58)		
Max. Total Refrigerant Line Length	Ft.	3,280	t Refer to System Data t Refer to System Data Refer to System Data Refer to System Data Refer to System Data	
Max. Refrigerant Line Length (Between ODU & IDU)	Ft.	541		
Max. Control Wiring Length	Ft.	1,640		
Indoor Unit	Total Capacity	50~130% of outdoor unit capacity		
	Model / Quantity	P06~P96/1~41		
Sound Pressure Level	dB(A)	62.5		
Fan				
Type x Quantity		Refer to Module Data	Propeller fan x 2	Propeller fan x 1
Airflow Rate	CFM		11,300	6,200
External Static Pressure	In. WG	Refer to Module Data		"WG; factory set to 0"W.G.
Compressor Operating Range	-	5% to 100%	Refer to System Data	
Compressor Type x Quantity		Refer to Module Data	Inverter-driven Scroll Hermetic x 1	Inverter-driven Scroll Hermetic x 1
Refrigerant		Refer to Module Data	R410A; 26 lbs. + 1 oz. (11.8 kg)	R410A; 16 lbs. + 9 oz. (7.5 kg)
Protection Devices	High Pressure	Refer to Module Data	High pressure sensor, High pressure switch at 4.15 MPa (601 psi)	High pressure sensor, High pressure switch at 4.15 MPa (601 psi)
	Inverter Circuit (Comp. / Fan)		Over-current protection	Over-current protection
AHRI Ratings	EER	12.4 / 13.5	Refer to System Data	
(Ducted/Non-Ducted)	IEER	21.1 / 24.5		
	COP	3.61 / 3.70		

#### NOTES:

- \*1. When applying product below -4° F, consult your design engineer for cold climate application
- best practices, including the use of a backup source for heating.
- \*2. For details on extended cooling operation range down to -10° F DB, see Low Ambient Kit Submittal.
- \*\* Each individual module requires a separate electrical connection. Refer to electrical data for each individual module.

# Outdoor Unit: PUHY-P192TSLMU-A (-BS) – DIMENSIONS



#### NOTES:

#### SEACOAST PROTECTION


• Anti-corrosion Protection: A coating treatment is applied to condenser coil for protection from air contaminants.

Standard: Salt Spray Test Method - no unusual rust development to 480 hours.

Sea Coast (BS): Salt Spray Test Method (JRA 9002) - no unusual rust development to 960 hours.

Unit : mm (in.)

# Model: PUHY-P120TLMU-A (-BS) – DIMENSIONS



#### NOTES:

#### SEACOAST PROTECTION


· Anti-corrosion Protection: A coating treatment is applied to condenser coil for protection from air contaminants.

· Standard: Salt Spray Test Method - no unusual rust development to 480 hours.

Sea Coast (BS): Salt Spray Test Method (JRA 9002) - no unusual rust development to 960 hours.

#### Unit : mm (in.)

# Model: PUHY-P72TLMU-A (-BS) – DIMENSIONS



#### NOTES:

#### SEACOAST PROTECTION

- · Anti-corrosion Protection: A coating treatment is applied to condenser coil for protection from air contaminants.
- · Standard: Salt Spray Test Method no unusual rust development to 480 hours.
- Sea Coast (BS): Salt Spray Test Method (JRA 9002) no unusual rust development to 960 hours.

# Twinning Kit: CMY-Y100CBK3


## CMY-Y100CBK3


For Gas pipe:


For Liquid pipe:

Ref.: CMY\_Y100VBK2\_EXD\_EUDB\_SI in

<Reducer(Accessory)>








ID: Inner Diameter OD: Outer Diameter

Note 1. Reference the attitude angle of the branch pipe below the fig.



The angle of the branch pipe for hign pressure is within  $\pm 15^{\circ}$  against the horizontal plane.

2. Use the attached pipe to braze the port-opening of the distributer.

3. Pipe diameter is indicated by inside diameter.

4. Only use the Twinning pipe by Mitsubishi (optional parts).



COOLING & HEATING

1340 Satellite Boulevard. Suwanee, GA 30024 Toll Free: 800-433-4822 www.mehvac.com



# Outdoor Unit: 16-TON PUHY-P192TSLMU-A (-BS)

UNIT OPTION

CITYMULTI® (Consists of One PUHY-P120TLMU-A (-BS), One PUHY-P72TLMU-A (-BS), and One CMY-Y100CBK3 Twinning Kit)



#### System Reference:



Village Hall

OUTDOOR VRF HEAT PUMP SYSTEM

Date:

<ul> <li>Standard Model</li> <li>Seacoast (BS) Model</li> </ul>	

rwinning Kit (required)		
loint Kit	for details see Pine Accessories Submittal	

JOINT KILIOF C	letails see Pipe Accessories Submittai
Low Ambient Kitfor	details see Low Ambient Kit Submittal

- □ Snow/Hail Guards Kit......for details see Snow/Hail Guards Kit Submittal
- Base Pan Heater Kit.....for details see Base Pan Heater Kit Submittal

Specifications		System	Module 1	Module 2	
Unit Type		PUHY-P192TSLMU-A (-BS)	PUHY-P120TLMU-A (-BS)	PUHY-P72TLMU-A (-BS)	
Nominal Cooling Capacity (208/230V)	Btu/h	192,000	120,000	72,000	
Nominal Heating Capacity (208/230V) Btu/h		215,000	135,000	80,000	
Operating Temperature	Cooling (Outdoor) *2	Refer to Module Data	23~126° F (-	23~126° F (-5~52° C) DB	
Range *1	Heating (Outdoor)		-13~60° F (-25	5~15.5° C) WB	
External Dimensions (H x W x D)	In. (mm)	Refer to Module Data	64-31/32 x 68-29/32 x 29-5/32 64-31/32 x 36-1/4 x (1,650 x 1,750 x 740) (1,650 x 920 x 7		
Net Weight	Lbs. (kg)	1,106 (501)	671 (304)	435 (197)	
External Finish		Refer to Module Data	Pre-coated galvanized steel sheet		
Electrical Power Requirements	Voltage, Phase, Hertz	Refer to Module Data**	208 / 230V, 3	-Phase, 60Hz	
Minimum Circuit Ampacity (MCA)	A	Refer to Module Data**	42 / 39	24 / 22	
Maximum Overcurrent Protection (MOP)	A	Refer to Module Data**	60 / 60	35 / 35	
Piping Diameter (Brazed)					
From Twinning Kit to First	Liquid (High Pressure)	5/8 (15.88)	Defecto S	votom Doto	
Joint or Header (In. / mm)	Gas (Low Pressure)	1-1/8 (28.58)	Relef to Sy	ystem Data	
Max. Total Refrigerant Line Length	Ft.	3,280			
Max. Refrigerant Line Length (Between ODU & IDU)	Ft.	541	Refer to System Data		
Max. Control Wiring Length	Ft.	1,640			
Indoor Unit	Total Capacity	50~130% of outdoor unit capacity	Refer to System Data		
	Model / Quantity	P06~P96/1~41	Refer to System Data		
Sound Pressure Level	dB(A)	62.5	Refer to System Data		
Fan					
Type x Quantity		Refer to Module Data	Propeller fan x 2	Propeller fan x 1	
Airflow Rate	CFM		11,300	6,200	
External Static Pressure	In. WG	Refer to Module Data	Selectable; 0, 0.12 or 0.24	"WG; factory set to 0"W.G.	
Compressor Operating Range		5% to 100%	Refer to System Data		
Compressor Type x Quantity		Refer to Module Data	Inverter-driven Scroll Hermetic x 1	Inverter-driven Scroll Hermetic x 1	
Refrigerant		Refer to Module Data	R410A; 26 lbs. + 1 oz. (11.8 kg)	R410A; 16 lbs. + 9 oz. (7.5 kg)	
Protection Devices	High Pressure	Refer to Module Data	High pressure sensor, High pressure switch at 4.15 MPa (601 psi)	High pressure sensor, High pressure switch at 4.15 MPa (601 psi)	
	Inverter Circuit (Comp. / Fan)		Over-current protection	Over-current protection	
	EER	12.4 / 13.5			
AHRI Ratings (Ducted/Non-Ducted)	IEER	21.1 / 24.5	Refer to System Data		
(Ducteurion-Ducteu)	COP	3.61 / 3.70			

3.61 / 3.70


#### NOTES:

- \*1. When applying product below -4° F, consult your design engineer for cold climate application best practices, including the use of a backup source for heating.
- \*2. For details on extended cooling operation range down to -10° F DB, see Low Ambient Kit Submittal.

COP

\*\* Each individual module requires a separate electrical connection. Refer to electrical data for each individual module.

# Outdoor Unit: PUHY-P192TSLMU-A (-BS) – DIMENSIONS



#### NOTES:

#### SEACOAST PROTECTION


• Anti-corrosion Protection: A coating treatment is applied to condenser coil for protection from air contaminants.

Standard: Salt Spray Test Method - no unusual rust development to 480 hours.

Sea Coast (BS): Salt Spray Test Method (JRA 9002) - no unusual rust development to 960 hours.

Unit : mm (in.)

# Model: PUHY-P120TLMU-A (-BS) – DIMENSIONS



#### NOTES:

#### SEACOAST PROTECTION


· Anti-corrosion Protection: A coating treatment is applied to condenser coil for protection from air contaminants.

· Standard: Salt Spray Test Method - no unusual rust development to 480 hours.

Sea Coast (BS): Salt Spray Test Method (JRA 9002) - no unusual rust development to 960 hours.

Unit : mm (in.)

# Model: PUHY-P72TLMU-A (-BS) – DIMENSIONS



#### NOTES:

#### SEACOAST PROTECTION

- · Anti-corrosion Protection: A coating treatment is applied to condenser coil for protection from air contaminants.
- · Standard: Salt Spray Test Method no unusual rust development to 480 hours.
- Sea Coast (BS): Salt Spray Test Method (JRA 9002) no unusual rust development to 960 hours.

# Twinning Kit: CMY-Y100CBK3


#### CMY-Y100CBK3


For Gas pipe:


For Liquid pipe:

Ref.: CMY\_Y100VBK2\_EXD\_EUDB\_SI in

<Reducer(Accessory)>








ID: Inner Diameter OD: Outer Diameter

Note 1. Reference the attitude angle of the branch pipe below the fig.



The angle of the branch pipe for hign pressure is within  $\pm 15^{\circ}$  against the horizontal plane.

2. Use the attached pipe to braze the port-opening of the distributer.

3. Pipe diameter is indicated by inside diameter.

4. Only use the Twinning pipe by Mitsubishi (optional parts).



COOLING & HEATING

1340 Satellite Boulevard. Suwanee, GA 30024 Toll Free: 800-433-4822 www.mehvac.com



# 88<sup>™</sup> Series 2 Commercial Boiler Weil-McLain<sup>®</sup>

Gas, Oil & Gas/Oil Water or Steam MBH: 996-5,845 Combustion Eff.: Up to 87.5%




- > Up to 85.7% Thermal Efficiency
- ➢ Water or Steam
- ➢ Gas, Oil or Gas/Oil
- Complies to LEED
- Packaged or Knock-down











### **NEW Jacket design:**

- · Modular jacketing and toolless jacket panels for easy access
- 3 inches of insulation to minimize jacket losses, maximizing thermal efficiencies
- Modular side panels for ease of assembly
- High temperature site glass grommets
- Part number labels on all components for easy assembly

### **NEW Efficiencies!**

- 85.7% Thermal Efficiencies (see ratings)
- HXT-bars optimize heat transfer

### **NEW clean-out plates:**

- 1/4 inch thick solid steel plates
- · Coated Woven Fiberglass reusable gasket
- Reusable cleaning after cleaning

### **Backwards Compatible:**

• Can use up to 50% Series 2 iron on a Series 1 block without consulting Weil-McLain® – no need to stock both!

# **Standard Equipment**

#### All Boilers:

- ASME 80 PSI rated cast iron sections
- Insulated steel jacketPower burner for light oil, gas or
- gas/light oil (except H-XX88) • Burner mounting plate with
- refractory (except H-XX88)
- Cast iron flue collar with built-in breaching damper
- Observation ports on front and back sections
- Cleanout plates with reusable gaskets
- Flue brush
- HXT-bars
- 3 inches of insulation (except front panel)

#### Water Boilers

- 30 PSI ASME relief valve
- Combination high limit and low limit with manual reset control
- Combination pressure/temperature gauge
- Nipple and 5" x 6" reducing coupling
- (1288 1888 boilers only) • Built-in air eliminator

#### **Steam Boilers**

- 15 PSI ASME safety valve side outlet
- Low limit and high limit pressure controls
- Steam pressure gauge siphon
- Gauge cocks, glass and guards

#### **Optional Equipment**

- Factory assembled sections
- Burner mounting plate with refractory for "H" units
- Intermediates with tankless heater opening
- Tankless heaters for domestic hot water (water or steam boilers)
- Tankless heater opening cover plates
- Low water cutoffs
- Barometric dampers
- Side inspection tappings with plugs
   2 per section
- Dual-range manometer
- Optional burners and burner controls



			I=B=R			I=B=R Net I	Rating		Flue Outlet		ustion iency	Ther Effici	
Γ	Model	Oil Input GPH	Gas Input MBH	Gross Output MBH	Steam MBH	Steam Sq. Ft.	Water MBH	Boiler H.P.	) (Dia)	OIL	GAS	OIL	GAS
	488R®	6.9	996	827	620	2,583	719	24.7	10 in.	87.5	84.8	85.6	83.1
_	488®	7.0	1,010	839	629	2,621	730	25.1	10 in.	87.5	84.8	85.6	83.1
-	588®	9.4	1,356	1,126	845	3,521	979	33.6	10 in.	87.0	84.4	85.6	83.1
-	688®	11.8	1,701	1,413	1,072	4,469	1,229	42.2	10 in.	86.7	84.1	85.6	83.1
	788®	14.2	2,046	1,700	1,311	5,463	1,478	50.8	12 in.	86.5	83.9	85.6	83.1
_	888®	16.6	2,382	1,987	1,543	6,427	1,728	59.4	12 in.	86.3	83.7	85.6	83.1
_	988R®	17.2	2,482	2,062	1,601	6,671	1,793	61.6	14 in.	86.2	83.7	85.6	83.1
	988®	18.8	2,737	2,274	1,766	7,358	1,977	67.9	14 in.	86.2	83.7	85.6	83.1
5_	1088R®	20.0	2,887	2,399	1,863	7,763	2,086	71.7	14 in.	86.2	83.6	85.6	83.1
-	1088®	21.5	3,082	2,561	1,988	8,283	2,227	76.5	14 in.	86.2	83.6	85.6	83.1
	1188®	23.5	3,428	2,848	2,211	9,213	2,477	85.1	14 in.	86.1	83.5	85.7	83.1
	1288®	26.0	3,773	3,135	2,434	10,147	2,726	93.7	14 in.	86.0	83.5	85.7	83.1
_	1388®	28.5	4,119	3,422	2,657	11,071	2,976	102.2	14 in.	86.0	84.4	85.7	83.1
_	1488®	31.0	4,464	3,709	2,880	12,000	3,225	110.8	16 in.	86.0	83.4	85.7	83.1
_	1588	33.0	4,809	3,996	3,102	12,925	3,475	119.4	16 in.	85.9	83.3	85.7	83.1
_	1688R	34.5	4,979	4,137	3,212	13,383	3,597	123.6	16 in.	85.9	83.3	85.7	83.1
_	1688®	35.5	5,155	4,283	3,325	13,854	3,724	127.9	16 in.	85.9	83.3	85.7	83.1
_	1788®	38.0	5,494	4,570	3,548	14,783	3,974	136.5	18 in.*	85.9	83.3	85.7	83.1
	1888®	40.5	5,845	4,857	3,771	15,713	4,123	145.1	18 in.*	85.9	83.3	85.7	83.1

IN THE

 •Burner input based on maximum of 2.000 ft, altitude - for higher altitudes consult Weil-McLain® representative.
 •Net I-B-Rratings are based on net installed radiation of sufficient quantity for the requirements of the building

 •No.2 Fuel oil - Commercial Standard Spec. CS75-56. Heat value of oil - 140.000 BTU/G.
 •Net I-B-Rratings are based on net installed radiation of sufficient quantity for the requirements of the building and nothing need be added for normal piping and pick-up vater ratings are based on the following allowances: 488 and 588 - 1323; 688 - 1323;

 •With 010" WC positive pressure at flue collar.
 788 - 1.209; 888 - 1.289; and 988 through 1888 - 1.288. An additional allowance should be made for gravity hot water systems or for unusual piping and pick.up loads. Consult Weil-McLain® representative.

 •Gross I=B=R ratings have been determined under the I=B=R provision governing forced draft boiler-burner units
 •Fue collar connection is oval, 16 1/8" x 19 7/8"




Model 88 Est. 1985 Weil-McLain



Model	Α	B	C	D	E	L	W	H
488®	23	-	-	10	54 3/4	34 3/4	30	23 3/8
588®	31	-	-	10	54 3/4	42 3/4	38	31 3/8
688®	39	-	-	10	54 3/4	50 <sup>3</sup> ⁄ <sub>4</sub>	46	39 3/8
788®	47	-	-	12	53 <sup>3</sup> / <sub>4</sub>	58 <sup>3</sup> ⁄4	54	47 3/8
888®	55	-	-	12	53 3/4	66 3/4	62	55 <sup>3</sup> /8
988®	63	-	-	14	52 <sup>3</sup> ⁄ <sub>4</sub>	74 <sup>3</sup> ⁄4	70	63 3/8
1088®	71	-	-	14	52 <sup>3</sup> /4	82 3/4	78	71 3/8
1188®	79	-		14	52 <sup>3</sup> ⁄ <sub>4</sub>	90 3/4	86	79 3/8
1288®	87	39 1/2	-	14	52 3/4	98 <sup>3</sup> ⁄4	94	87 3/8
1388®	95	47 1/2	_	14	52 <sup>3</sup> ⁄ <sub>4</sub>	106 3/4	102	95 <sup>3</sup> /8
1488®	103	55 1/2		16	51 3/4	114 3/4	110	103 3/8
1588®	111	63 1/2	-	16	51 3/4	122 3/4	118	111 3/8
1688®	119	47 1/2	-	16	51 3/4	130 3/4	126	119 3/8
1788®	127	31 1/2	79 1/2	18†	51 3/4	138 3/4	134	127 3/8
1888®	135	39 1/2	87 1/2	18†	51 3/4	146 3/4	142	135 3/8

+For 18" diameter breaching, flue collar is oval (191/8 x 161/16")

Dimensions



FRONT

Α

REAR

B

Weil-McLain

5


Supply & return tappings **Dimension F** Supply tappings (No. & size)\* Return tappings (No. & size)\* Model Steam Water Steam Water 488R® 2-5" 2-5" 1-6" 1 - 6''488® 2-5" 2-5"  $1 - 6^{1}$ 1-6 See Burner Specification & Data Sheets 588® 2-5" 2-5" 1-6" 1-6 688® 1-6" 2 - 5" 2 - 5" 1-6" 788® 2-5" 1-6" 1-6" 2 - 5" 888® 2-5" 2-5" 1-6" 1-6" 988R® 2-5" 2-5" 1-6" 1-6" 988® 2-5" 2-5" 1-6" 1-6" 1088R® 2-5" 2-5" 1-6" 1-6" 1088® 2-5" 2-5" 1-6 1-6" 2-5" 2-5" 1188® 1-6" 1-6" 1288® 3-5" 2-5" 1-6" 1-6" 1388® 3-5" 2 - 5" 1-6" 1-6" 1488® 3-5" 2-5" 1-6" 1-6" 1588® 3-5" 2-5" 1-6" 1-6" 1688R® 3 - 5" 2 - 5" 1-6" 1-6" 3 - 5" 2 - 5" 1688® 1-6" 1-6" 1788® 4-5" 2-5" 1-6" 1-6" 1888<sup>®</sup> 4 - 5" 2 - 5" 1 - 6" 1-6"

\*Use recommended piping connections. †For 18" diameter breaching, flue collar is oval (191/8 x 161/16")

		3=R ner Dia (in)	Boiler Flue Collar Dimensions (in)
Model	Forced Draft	Balanced Draft	
488®	10	12	10 round
588®	10	15	10 round
688®	12	15	10 round
788®	12	18	12 round
888®	14	18	12 round
988®	14	18	14 round
1088®	14	21	14 round
1188®	16	21	14 round
1288®	16	21	14 round
1388®	16	24	14 round
1488®	18	24	16 round
1588®	18	24	16 round
1688®	18	24	16 round
1788®	18	24	16 1/8 x19 7/8 oval
1888®	20	27	16 1/8 x19 7/8 oval



5" NPT Supply outlets
Water line D
+6%+





# Technical Data Sheet Benchmark 750-6000 Boilers

The AERCO Benchmark (BMK) Water Boiler is designed for condensing application in any closed loop hydronic system. It delivers unmatched burner modulation to match energy input directly to fluctuating system loads to yield the highest possible seasonal efficiencies. And no other product packs as much capacity into such a small footprint.

# **Energy Efficient**

To minimize emissions, the BMK Series is fitted with a low NOx burner whose emissions will meet the most stringent NOx and CO requirements. The fully modulating burner also maintains AERCO standards for energy efficiency, longevity, reliability and construction quality.

The BMK Series comes standard with AERCO's Patent Pending, Oxygen Level  $(O_2)$  monitoring system. This monitoring system, designed to display the  $O_2$  level directly on the unit in real time, can also be remotely monitored via Modbus giving the customer the ability to measure the emissions level and fuel economy of the boiler without traditional combustion calibration devices.

# **Application and Plant Design**


The BMK boilers can be used as an individual unit or in modular arrangements and offers selectable modes of operation. In addition to controlling the boiler according to a constant set point, indoor/outdoor reset schedule or 4-20mA signal, one or more units can be integrated via Modbus communications protocol. For boiler plants ranging from 2-8 boilers, AERCO'S built-in Boiler Sequencing Technology (BST)\* can be utilized. For heating plants greater than 8 boilers, AERCO's ACS (AERCO Control System) provides the right solution. Likewise, Benchmark systems can be easily integrated with a facility-wide Energy Management or Building Automation System.

# Features

- Natural Gas, Propane, or Dual Fuel (model dependent)
- 20:1 Turndown Ratio (5%) depending on capacity
- Oxygen Level (0,) Monitoring Standard
- Stainless Steel Fire Tube heat exchanger
- Capable of variable primary flow Installations
- NOx Emissions capable of 9PPM or less @ all firing rates \*depending on capacity
- Compact Footprint
- Precise Temperature Control







\*See BST System technical data sheet for additional system details and capabilities

- On-board Boiler Sequencing Technology (BST)
- Ducted Combustion Air Capable
- Easy Open Access for Service
- Acceptable vent materials AL29-4C, Polypropylene, PVC, cPVC (model dependent)
- Reliable Quiet Operation
- Controls Options: Constant Setpoint, Indoor/ Outdoor Reset, Remote Setpoint, 4-20mA signal or ModBus

# **Specifications**

				BMK S	tandard				
	750	1000	1500	2000	2500	3000	5000	6000	
Boiler Category	ASME Sect.IV	ASME Sect.IV	ASME Sect.IV	ASME Sect.IV	ASME Sect.IV	ASME Sect.IV	ASME Sect.IV	ASME Sect.IV	
Gas Connections (NPT)	1″	1″	2″	2"	2"	2"	2 / 3"	2 / 3"	
Max. Gas Pressure	14"	14"	14"	14″	14"	14"	2psi/10"*	2psi/10"*	
Min. Gas Pressure <sup>1</sup>	4″	4″	4″	4″	4″	4″	14 / 4"*	14 / 4"*	
Max. Allowed Working Pressure	160 PSIG	160 PSIG	160 PSIG	160 PSIG	160 PSIG	160 PSIG	80PSIG/ 150 PSIG Optional	80 PSIG/ 150 PSIG Optional	
Electrical Req. 120V/1PH/60Hz <sup>2</sup>	13 FLA	13 FLA	16 FLA	16 FLA	N/A	N/A	N/A	N/A	
Electrical Req. 208V/3PH/60Hz <sup>2</sup>	N/A	N/A	N/A	N/A	10 FLA	10 FLA	19 FLA	19 FLA	
Electrical Req. 460V/3PH/60Hz <sup>2</sup>	N/A	N/A	N/A	N/A	5 FLA	5 FLA	9 FLA	9 FLA	
Electrical Req. 575V/3PH/60Hz <sup>2</sup>	N/A	N/A	N/A	N/A	N/A	N/A	7 FLA	7 FLA	
Water Connect. (Flanged)	3"	3"	4"	4″	4″	4″	6″	6"	
Min. Water Flow (GPM)	12	12	25	25	25	25	75	75	
Max. Water Flow (GPM)	175	175	250	350	350	350	700	700	
Water Volume Gallons	16.25	14.25	44	40	58	55	110	110	
Water Pressure Drop	3.0 PSIG @100 GPM	3.0 PSIG @100 GPM	3.0 PSIG @170 GPM	3.0 PSIG @170 GPM	3.0 PSIG @218 GPM	3.0 PSIG @261 GPM	4.0 PSIG @500 GPM	4.0 PSIG @500 GPM	
Turndown Ratio	15:1 (7%)	20:1 (5%)	20:1 (5%)	20:1 (5%)	15:1 (7%)	15:1 (7%)	12:1 (8%)	15:1 (7%)	
Vent/Air Intake Connections	6 Inch	6 Inch	6 Inch	8 Inch	8 Inch	8 Inch	14 Inch Optional/ 12 Inch Flue Venting	14 Inch Optional/ 12 Inch Flue Venting	
Vent Materials	AL29-4C Polypro, CPVC, PVC	AL29-4C Polypro, CPVC, PVC	AL29-4C Polypro	AL29-4C Polypro	AL29-4C Polypro	AL29-4C Polypro	AL29-4C Polypro	AL29-4C Polypro	
Type of Gas	Natural Gas, Propane	Natural Gas, Propane	Natural Gas, Propane, Dual Fuel	Natural Gas, Propane, Dual Fuel	Natural Gas, Propane, Dual Fuel	Natural Gas, Propane, Dual Fuel	Natural Gas, Dual Fuel	Natural Gas, Dual Fuel	
NOx Emissions <9ppm Capability	$\checkmark$	$\checkmark$	$\checkmark$	$\checkmark$	N/A (<20 ppm)	N/A (<20ppm)	√3	√3	
Temp. Control Range				50°F 1	to 190°F				
Ambient Temp. Range				0°F t	o 130°F				
Standard Listings & Approvals	UL, CUL, CSD-1, ASME								
Gas Train Operations	FM Compliant or Factory Installed DBB (IRI) FM								
Sound Rating dbA	65	65	70	70	72	72	79	79	
Weight (dry) Ibs.	669	700	1406	1500	2,000	2,170	3,000	3,000	
	862	900	1606	1700	2,200	2,370	3,800	3,800	

\*BMK5000/6000 low gas pressure option is available as a different style number. It operates between 4" and 10" of gas pressure.

BMK5000/6000 with natural gas can be ordered with VPS (Valve-Proving System) for additional operation safety.

1. Values are for natural gas FM compliant gas trains only. See Benchmark Gas Components & Supply Design Guide GF-2030 for propane, DBB & dual fuel gas train minimum gas pressure requirements.


2. See Benchmark Electrical Power Guide GF-2060 for service disconnect switch amperage requirements.

3. BMK5000/6000 operating at standard gas pressure (>14" W.C.) can achieve 9 ppm NOx.


# Ratings

BMK Models	Min Input MBH	Max Input MBH	Max Output* MBH	Efficiency Range	Efficiency 80° to 180°F
750	50	750	653-720	87%-98%	95.50%
1000	50	1000	870-960	87%-98%	96.80%
1500	75	1500	1305-1425	87%-98%	94.60%
2000	100	2000	1740-1900	87%-98%	94.60%
2500	167	2500	2175-2360	87%-98%	93.50%
3000	200	3000	2610-2880	87%-98%	93.50%
5000	400	5000	4350-4800	87%-98%	93.90%
6000	400	6000	5220-5670	87%-98%	94.50%

\*Max output dependent upon application – see efficiency curves



BMK Models	(Width) A	(Depth) B	(Height) C	D	E	F	G	Н	I	J	К	L
BMK 750	28"	25″	78"	34"	10"	10′′	53"	21"	17"	4''	5″	51.8"
BMK 1000	28"	25″	78″	34"	10"	10''	53"	21″	17"	4''	5″	51.8"
BMK 1500	28"	43.6″	78"	58.4"	7″	11.5″	57.8″	18"	42"	8.9″	4.7″	19.5″
BMK 2000	28"	43.6″	78′′	58.4"	7″	11.5″	57.8″	18"	42"	8.9"	4.7″	19.5″
BMK 2500	28"	56"	78″	68.4"	5.4"	11.5″	57.8″	18"	42"	6.4″	3.6"	26″
BMK 3000	28"	56"	78′′	68.4"	5.4″	11.5″	57.8″	18"	42″	6.4″	3.6″	26″



BMK Models	(Width) A	(Depth) B	(Height) C
5000	35"	89.3"	79.8″
6000	35"	89.3"	79.8″



Heating and Hot Water Solutions

AERCO International, Inc. • 100 Oritani Drive • Blauvelt, NY 10913 USA: T: (845) 580-8000 • Toll Free: (800) 526-0288 • AERCO.com



# **Product Catalog**

# Water Source Heat Pump Axiom<sup>™</sup> Rooftop - GWS\* 3 to 20 Tons - 60 Hz







# **Performance Data**

			Wate	er Loop	Heat Pump	)	Groun	d Wate	r Heat Pum	р	Grour	nd Loop	p Heat Pump	
Size	Rated GPM	Rated CFM	Cooling 8	36°F	Heating (	58°F	Cooling 5	59°F	Heating 5	50°F	Cooling 7	7°F	Heating 3	32°F
	GPM	Сгм	Capacity Btuh	EER	Capacity Btuh	СОР	Capacity Btuh	EER	Capacity Btuh	СОР	Capacity Btuh	EER	Capacity Btuh	СОР
GWSC036H	9.0	1200	40,900	14.95	46,700	4.62	46,200	23.29	38,800	4.12	42,700	17.31	30,000	3.41
GWSC048H	12.0	1600	52,700	16.56	60,100	5.14	59,700	25.72	50,000	4.56	55,100	19.28	39,000	3.77
GWSC060H	15.0	2000	60,200	14.83	74,800	4.86	68,300	22.57	61,900	4.33	63,000	17.22	47,800	3.59
GWSC072H	18.0	2400	75,200	14.20	91,100	4.80	84,800	20.10	75,000	4.30	78,600	16.00	58,600	3.60
GWSC092H	22.5	3000	91,700	14.30	113,800	4.70	100,300	20.70	92,200	4.20	95,700	16.50	70,800	3.40
GWSC120H	30.0	4000	122,000	15.70	145,000	4.90	138,200	23.40	118,100	4.40	127,300	18.10	91,900	3.40
GWS*150E	38.8	4750	160,300	15.90	181,500	5.10	178,700	22.70	150,800	4.50	166,800	18.00	118,800	3.70
GWS*180E	46.5	5700	184,400	14.20	201,000	4.60	204,200	19.70	162,900	4.00	192,500	15.90	123,200	3.20
GWS*240E	62.0	7600	261,600	13.20	313,100	4.40	290,500	17.70	265,900	4.00	273,500	14.80	210,000	3.50

#### Table 6. ANSI/AHRI/ASHRAE/ISO 13256-1 WLHP, GWHP and GLHP performance - 3.5 to 20 tons

Notes:

1. Rated in accordance ANSI/AHRI/ASHRAE/ISO13256-1. Certified conditions are 80.6°F DB/66.2°F WB EAT in cooling and 68°F DB/59°F WB EAT in heating.

Models with capacities greater than 135,000 Btuh are not included in the ANSI/AHRI/ASHRAE/ISO13256-1 certification program.
 \* stands for both downflow and horizontal units.





# **ENVISION** Console 0.75 to 1.5 Ton Water Source/Geothermal Heat Pump



#### **ENVISION**

The Envision Series Console provides cutting edge technology in heating and cooling for commercial applications, using the latest in component and design technology. Single speed, R-410A LG rotary compressors are the heart of the system. Also included are oversized coaxial water-to-refrigerant heat exchangers and durable all-aluminum air coils for high efficiencies at low face velocities. Envision Console units are capable of operating at extreme loop temperatures and have the options and flexibility for any application. The cabinet footprint is designed to match "legacy" consoles for easy retrofitting.

As a leader in the industry, WaterFurnace International is dedicated to innovation, quality and customer satisfaction. Our team of engineers, customer support and skilled assembly technicians are dedicated to providing the highest quality products with the most extensive support network in the industry. By specifying WaterFurnace 0.75-1.5 ton Envision Series Consoles, you can rest assured your customers are investing in a product with superior quality and performance.

# Envision Consoles are the perfect fit for any ductless application.

#### **KEY FEATURES**

**COMPRESSOR:** Single speed rotary compressors. Available in commercial single phase voltages.

**WATER LINES:** 1/2" Copper FPT waterline connections protrude out the end of the chassis for ease of installation.

**COAXIAL HEAT EXCHANGER:** Oversized and convoluted with copper inner tube (optional cupronickel) and steel outer tube, designed for maximum heat transfer at normal and low water flow rates to minimize pressure drop.

**ALUMINUM AIR COIL:** An aluminum air coil is featured in all Envision Console units to provide exceptional durability and high efficiencies. Added protection is also available with an optional AlumiSeal<sup>™</sup> coating.

**MOTORIZED OUTSIDE AIR DAMPER:** Optional field installed motorized outside air damper allows for the introduction of 25% outside (fresh) air into the conditioned space. Powered on by a 24V signal to the damper motor and spring-closed upon a loss of signal.

**ELECTRIC HEAT:** Internally mounted Nickel-Cadmium (Ni-Cad) electric heat elements with ceramic insulators and thermal switches. Available in 1 kW or 2 kW for NC09-12 and 3 kW for NC15-18.

**ELECTRICAL DISCONNECT:** Optional, field installed fused or non-fused electrical disconnect available. Fused sizes available in 10, 12, 15, 20 and 25 amp fuses. **CABINET:** Constructed of heavy gauge environmentallyresponsible galvanized steel for maximum corrosion resistance. All cabinets finished with beige textured epoxy powder coating on both sides for added protection. Fits "legacy" console footprints.

**REFRIGERANT CIRCUIT:** Units utilize R-410A refrigerant in sealed circuits. Metering accomplished with thermostatic expansion valve to deliver optimum refrigerant flow over a wide range of conditions without troublesome check valves. Four-way solenoid activated reversing valve faults to heating, and is "cool brazed" at the factory.


**CONTROLS:** The Compressor Control Module (CCM) comes standard or an optional Versatec Microprocessor Control is also available. The optional FX10 Control adds N2, Modbus, LON & BACnet compatibility along with unit or wall mounted sensors or wall mounted thermostat options (thermostat/sensors sold separately).

FAN MOTOR: High efficiency 3-speed ECM blower motors come standard.

#### ADDITIONAL OPTIONS:

- EXTENDED RANGE COAXIAL HEAT EXCHANGER AND PIPING INSULATION.
- CABINETS AVAILABLE IN FLAT, SLOPE TOP, OR EXTENDED SLOPE TOP.
- LEFT OR RIGHT CONTROLS
- 115V OPTION ON NC09-12


# ENVISION SERIES CONSOLES 0.75 - 1.5 Ton



Flat Top


Model	A	В	C
09 - 12	45.0″	10.8″	25.7"
015 - 018	50.0″	12.3″	25.7"





#### Slope Top

Model	A	В	C
09 - 12	50.0″	12.6″	29.1"
015 - 018	55.0 <i>″</i>	12.6″	29.1"



Inside the Envision Series Console

# ARI/ISO 13256-1 PERFORMANCE RATINGS

#### **ECM Motors**

ARI/ASHRAE/ISO 13256-1 English (IP) Units

	Flow Rate			Water Loop	Heat Pump	<b>)</b>	G	round Wate	er Heat Pum	p	Ground Loop Heat Pump				
Model			Cooling EWT 86°F		Heating EWT 68°F		Cooling EWT 59°F		Heating EWT 50°F		Cooling EWT 77°F		Heating EWT 32°F		
	gpm	cfm	Capacity Btuh	EER Btuh/W	Capacity Btuh	СОР	Capacity Btuh	EER Btuh/W	Capacity Btuh	СОР	Capacity Btuh	EER Btuh/W	Capacity Btuh	СОР	
09	2.5	300	8,500	13.4	10,500	4.4	10,200	22.5	8,700	3.8	9,000	16.0	6,700	3.1	
12	3.5	350	10,500	12.3	14,400	4.3	12,400	19.5	11,800	3.7	11,000	14.2	9,500	3.5	
15	4.5	450	13,500	13.6	17,000	4.9	16,200	22.0	14,000	4.1	14,200	15.9	10,500	3.4	
18	5.5	500	16,200	12.5	21,000	4.4	19,000	19.6	17,000	3.7	16,600	15.1	13,300	3.1	
														12/09/09	

Cooling capacities based upon 80.6°F DB, 66.2°F WB entering air temperature Heating capacities based upon 68°F DB, 59°F WB entering air temperature All ratings based upon 208V operation

BR1010CN 03/15







visit us at waterfurnace.com



The Installation Guide contains important information and notes regarding the installation and operation of the InstantFit T8 lamps. Please note the important points below:

- Product is not dimmable
- Not compatible with luminaires that use a remote starter.
- Modifications to the product void the warranty.
- Suitable to replace T8 fluorescent lamps as specified on the product label.
- Operates on instant-start and certain programmed-start ballasts only. Please refer to www.philips.com/instantfit for latest ballast compatibility guide.

#### For Philips InstantFit LED T8 Lamps - 2', 3', 4'







3 Fluorescent





4 LED T8 InstantFit 5 LED T8 InstantFit




6

2 Fluorescent










6



For Philips InstantFit LED T8 Lamps - PL-L





#### Instructions

- 1. Switch-off power to the luminaire
- 2. Remove diffuser (if provided)
- 3. Remove the existing fluorescent lamps from the luminaire.
- Note: Verify the fluorescent tube type is listed on the label of Philips InstantFit LED T8 lamp.
- 4-5. Install the Philips InstantFit LED T8 lamp (one for each fluorescent lamp removed, ensure pins are firmly seated in the lamp holders).
  - For U-Bent & PL-L, please ensure that the lamp is secured by the clip.
  - Replace diffuser (if removed in step 2).
- 6. Switch on power to the luminaire.

#### **CAUTION –** IF THE LAMP OR LUMINAIRE EXHIBITS UNDESIRABLE OPERATION (BUZZING, FLICKERING, ETC.), IMMEDIATELY TURN OFF POWER, REMOVE LAMP FROM LUMINAIRE AND CONTACT THE MANUFACTURER

# **CAUTION –** RISK OF FIRE. DO NOT INSTALL IN A PRE-HEAT LUMINAIRE

THIS LAMP ONLY OPERATES ON ELECTRONIC BALLASTS. IF LAMP DOES NOT LIGHT WHEN THE LUMINAIRE IS ENERGIZED, REMOVE LAMP FROM LUMINAIRE AND CONTACT LAMP MANUFACTURER OR QUALIFIED ELECTRICIAN

**CAUTION –** RISK OF FIRE. PERFORM A VISUAL INSPECTION TO ENSURE LAMPHOLDERS ARE NOT DAMAGED OR LOOSE. IF DAMAGED, CORRODED, CHARRED, BLACKENED, OR LOOSE, CONTACT A QUALIFIED ELECTRICIAN FOR PROPER REPLACEMENT.

THIS PRODUCT MAY CAUSE INTERFERENCE TO RADIO EQUIPMENT AND SHOULD NOT BE IN-STALLED NEAR MARITIME SAFETY COMMUNICATIONS EQUIPMENT OR OTHER CRITICAL NAVIGATION OR COMMUNICATION EQUIPMENT OPERATING BETWEEN 0.45 – 30MHZ.

LAMPS MUST BE OPERATED WITHIN AN AMBIENT FIXTURE TEMPERATURE OF -4F (-20C) AND 113F (45C) TO ENSURE UL COMPLIANCE.

#### Instructions

- 1. Couper l'alimentation du luminaire.
- 2. Retirer le diffuseur (si inclus).
- 3. Retirer les lampes fluorescentes du luminaire.
  Vous assurer que le ballast dans le luminaire est un ballast à allumage instantané (généralement situé dans le canal du ballast).
- 4-5. Installer la lampe DEL T8 InstantFit de Philips (remplacer chaque lampe fluorescente retiree, vous assurer que les broches sont bien insérées dans les culots).
  - Pour les lampes en U et PL-L, vous assurer de bien rattacher la lampe avec l'attache.
  - Remplacer le diffuseur (s'il a été retiré à l'étape 2).
- 6. Allumer l'interrupteur du luminaire.

ATTENTION - SI LA LAMPE OU LE LUMINAIRE MONTRE DES SIGNES D'OPERATION INDESIRABLE (BRUIT, VIBRATION, CLIGNOTEMENT, ETC.), ALORS COUPER IMMÉDIATEMENT LE COURANT ET ENLÈVER LA LAMPE DE L'APPAREIL D'ÉCLAIRAGE ENTRER EN CONTACT AVEC LE FABRICANT

**ATTENTION -** RISQUE DE FEU. N'INSTALLEZ PAS CETTE LAMPE DANS UN APPAREIL D'ÉCLAIRAGE DE PRÉCHAUFFAGE

CETTE LAMPE OPERE SEULEMENT AVEC LE BALLAST ELECTRONIQUE. SI LA LAMPE NE S'ALLUME PAS QUAND L'APPAREIL D'ECLAIRAGE ACTIVE, ENLEVEZ LA LAMPE DE L'APPAREIL D'ECLAIRAGE ET CONTACTEZ LE FABRICANT DE LAMPE OU UN ELECTRICIEN QUALIFIE

ATTENTION – RISQUE D'INCENDIE. INSPECTEZ VISUELLEMENT POUR VOUS ASSURER QUE LES CULOTS NE SONT PAS ENDOMMAGÉS OU DESSERRÉS. SI LES CULOTS SONT ENDOMMAGÉS, CORRODÉS, BRÛLÉS, NOIRCIS OU DESSERRÉS, VEUILLEZ CONTACTER UN ÉLECTRICIEN QUALITÉ POUR EFFECTUER UN REMPLACEMENT ADÉQUAT.

CE PRODUIT EST SUSCEPTIBLE DE CAUSER DE L'INTERFÉRENCE AVEC LES ÉQUIPEMENTS RADIO ET NE DEVRAIT PAS ÊTRE INSTALLÉ PRÈS DES APPAREILS DE COMMUNICATION DE SÉCURITÉ MARITIME OU TOUT AUTRE ÉQUIPEMENT DE COMMUNICATION OU DE LA NAVIGATION QUI FONCTIONNE À UNE BANDE ENTRE 0,45 ET 30 MHZ.

AFIN D'ASSURER L'HOMOLOGATION UL, L'EXPLOITATION DES DOIT ÊTRE EFFECTUÉE À UNE TEMPÉRATURE AMBIANTE DU LUMINAIRE ENTRE -20C (-4F) ET 45C (113F).

© 2015 Koninklijke Philips N.V. All rights reserved. Philips reserves the right to make changes in specifications and/or to discontinue any product at any time without notice or obligation and will not be liable for any consequences resulting from the use of this publication.



Philips Lighting, North America Corporation 200 Franklin Square Drive, Somerset, NJ 08873 Tel. 855-486-2216

Imported by: Philips Lighting, A division of Philips Electronics Ltd. 281 Hillmount Rd, Markham, ON, Canada L6C 2S3 Tel. 800-668-9008 Appendix D: Energy Audit Forms


# **Building Characteristics**



Building ID: Ambulance Corps Gar	age	Date of Audit:			
City: Hastings-on-Hudson	State:	NY	Zip:	10706	
Gross Floor Area: 1,200	)	_ft <sup>2</sup>			
Number of Conditioned Floors:	Above Grade:	1	Below Grade	Э:	
Year of Construction:		_			
Primary Building Function: School					
Meter Number:	Utility:		Meter Location:		
Meter Number:	Utility:		Meter Location:		
Meter Number:	Utility:		Meter Location:		
Meter Number:	Utility:		Meter Location:		
Meter Number:	Utility:		Meter Location:		
From Utility Bills: Utility Company:	Account Numb	or		E	
Utility Company:	Account Numbe			Energy Type:	
Utility Company:	Account Numbe			Energy Type:	
Electricity (kBtu/ft <sup>2</sup> /yr):	, loocult runnor			Energy Type:	
Gas (kBtu/ft²/yr):					
Oil (kBtu/ft²/yr):					
EUI (kBtu/ft²/yr): 36.4*					
Cost Index (\$/ft²/yr):					
Brief Building Description:				· · · · · · · · · · · · · · · · · · ·	

## Site Plan (meter locations)





# **Building Envelope**



#### Construction Types (check all that apply)

Walls:		Insulated?	Roofs	Insulated?
	Wood		Concrete Deck	1
	Masonry		Wood Deck	
	Concrete (above grade)		Metal Deck	
	Concrete (below grade)		Other (describe if other)	
	Metal		Windows (Metal Framed)	
	Stone		Single Glazing	
	Glass		Double Glazing	
	Other (describe if other)		Windows (Wood Framed)	
Doors:			Single Glazing	
	Solid Wood		Double Glazing	
	Hollow Wood			
	Uninsulated Metal			
	 Glass (<85%)			
	Other (describe if other)			
	Weatherstripping			
Additiona	al Notes:			
				and the second
	· · · · · · · · · · · · · · · · · · ·		 	

### **Building Use Schedule**



Average Hours/Week:

#### Average Weeks/Year:

After Hours Cleaning (Y/N):

# -Volumeters on call 24/7 Schedule for the months of (i.e. School Year Sept - June):

Days	М	Т	W	Th	F	Sat	Sun	Holiday
Hours Open								
Hours Closed								
Peak # of								
Occupants								
Average # of								
Occupants								

Schedule for the months of (i.e. Summer Months July - Aug):

Days	М	Т	W	Th	F	Sat	Sun	Holiday
Hours Open								
Hours Closed								
Peak # of Occupants								
Average # of Occupants								

#### Schedule for the months of:

Days	М	Т	W	Th	F	Sat	Sun	Holiday
Hours Open								
Hours Closed								
Peak # of Occupants								
Average # of Occupants								

Schedule for the months of:

Days	М	Т	W	Th	F	Sat	Sun	Holiday
Hours Open								
Hours Closed								
Peak # of Occupants								
Average # of Occupants								

# Building HVAC System Summary



Check all major systems that apply

rimary Cooling:	Exhaust Systems:
Centrifugal Chiller	Fume Hoods, Constant Volume
Reciprocating Chiller	Fume Hoods, VAV
Screw Chiller	Kitchen Hoods
Absorption Chiller	Toilet Exhaust
Packaged DX	Locker Exhaust
Split DX	General Exhaust
Air-Cooled Heat Rejection	
Water-Cooled Heat Rejection	Other:
Ground-Source Heat Pump	Cogeneration
Air-Source Heat Pump	Energy Monitoring & Controls
Recirculating Water-Source Heat Pump	On-site Generation
Variable Refrigerant Flow	Active Solar Equipment
	Energy Recovery
rimary Heating:	Thermal Storage
Cast Iron Hot Water Boiler	Humidifiers/Dehumidifiers
Condensing Boiler	Dessicant System
Steam Boiler	Evaporative Cooling
Furnace	Other
Ground-Source Heat Pump	
Air-Source Heat Pump	Describe if other:
Recirculating Water-Source Heat Pump	
HU/Terminal Systems:	
Single Zone	
Multi Zone	
Dual Duct	
Variable Air Volume	
Reheat	
Fan Coil Units	
Unit Ventilators	
Packaged Terminal Air Conditioners	Notes:
Steam/Hot Water Radiators/Convectors	Take photos of nameplates
Above Systems with Economizer	Take photos of equipment

## **Building HVAC System Summary**



### **Heating Plant**

Boiler Quantity:	1	Siz	e:		Туре	Hot Vater	1
Manufacture & Model:	Burn	han			Fuel	Used: Nortura	6as
Hot Water Supply Setp	oint:	Ste	am Pressu	e Setp	oint:		
Number of Pumps:	1	Total HP:					
Additional Comments:	Heating p	lant upgrades inc	lude heat ti	mer ar	nd boiler controls, th	nermostatic radiato	or
valves, burner replacer	ment, cond	ensate heat reco	very, boiler	replac	ement		
- Small residen	Ation) a	rade boile	map 1	Z	re circulation	pump	
	J		1.000		CONTRACTOR OF THE OWNER OF THE OWNER		_

#### **Cooling Plant**

Manufacture & Model:		
Chiller Quantity:	Total Tonnage/kW:	
Chilled Water Pumps Quantity:	Total HP:	
Chilled Water Supply/Return Temp Setpoin	it:	
Condenser Water Pumps Quantity:	Total HP:	
Cooling Tower Fans Quantity:	Total HP:	
Additional Comments:		
- Window AC write only (	3total)	
- 1.5 tons each U		

#### Air-Side Systems

Tag	Model	Type (i.e. DX, VAV)	Location	Serves	Capacity/ CFM	Horsepower	Drive (VFD, etc.)

OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\Ambulance Corps

# **HVAC Operation and Maintenance**



### **Unoccupied Setback**

· · ·

Shutdown of:	Check all that apply
AHU's by Time Schedule	
Exhaust Fans by Time Schedule	
Chillers:	
By Time Schedule	
By Outside Air Temperature	
Boilers:	
By Time Schedule	
By Outside Air Temperature	Anemostat
1	maintenance procedures related to energy efficiency:

## Domestic Hot Water Summary



Fuel Type:	
Electricity	
Natural Gas	
Oil	
Steam	
Heat Pump	
Other (describe if othe	er)
Number of Units: 1	Location: Briter Room Re-circ Loop? (Y/N): Yes
Gallons: 40	Hot Water Supply Temperature: 🆖
Tank Insulated? (Y/N): No	Condensing DHW Heater? (Y/N):
	Condensing DHW Heater? (T/N).
Additional Comments:	
Additional Comments: -Brockferd Uhite	DAJ heater.
Additional Comments: -Broadferd White -Scores physelsing	

Sketch of DHW piping schematic:

### Food Preparation Summary



Item	Quantity	Load (kW)
Ranges		
Steam Tables		
Freezers		
Refrigerators		
Walk-In Refrigerators		
Walk-In Freezers		
Infra-Red Warmer		
Microwaves		
Mixers		
Ovens		
Frying Tables		
Dishwashers		
Exhaust Hoods		

Additional Comments:

2

manare and res e. en

Sketch of kitchen layout:



Space	Type of Fixture	No. of Fixtures	Average Watts/fixture	Type of Controls	Ballast Type
Lange	4' 18 FL.	6	34(2)=68W	Manual	-
Bathtom	2X2 A.	1			
Garage	498 FL.	16	54(4)=1364	Mannal	
		1 <b>.</b> .			

Additional Comments:

Nmers.

for experior

OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\Ambulance Corps

lighting

C

192
2
3
Ε
Ε
S
9
a
0
S

	CONSULTING																	
																		×
У																		
Space Summary																		
S				tents														
		carage		-2 under Ac	120	Manuel												
		CUMAR	0	when AC		Manuer											(0)	σ
		Space Type	Conditioned	Primary HVAC	Primary Lighting Type	Lighting Controls	# of Occupants	Weekday Hours in Use	Weekend Hours	090	Space Type	Conditioned Area (ft <sup>2</sup> )	Primary HVAC	Primary Lighting Type	Lighting Controls	# of Occupants	Weekday Hours in Use	Weekend Hours in Use

OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\Ambulance Corps

.

# **Building Characteristics**

÷.,



Building ID:	Chemka Pool Building		Date of Audit:				
City:	Hastings-on-Hudson	State:	NY	Zip:	10706		
Gross Floor	Area: 4,500	)	ft <sup>2</sup>				
Number of C	onditioned Floors:	Above Grade:	1	Below Grade:			
Year of Cons	struction:		_				
Primary Build	ding Function: School						
Meter Numbe	er:	Utility:		Meter Location:			
Meter Numbe	er:	Utility:		Meter Location:			
Meter Numbe	er:	Utility:		Meter Location:			
Meter Numbe	er:	Utility:		Meter Location:			
Meter Numbe	er:	Utility:		Meter Location:			
From Utility E	Bills:						
Utility Compa	any:	Account Numb	er:		Energy Type:		
Utility Compa	any:	Account Numb	er:	1	Energy Type:		
Utility Compa	any:	Account Numb	er:		Energy Type:		
Electricity (kE	Btu/ft²/yr):		-				
Gas (kBtu/ft <sup>2</sup>	/yr):		_				
Oil (kBtu/ft²/y	rr):		_				
EUI (kBtu/ft <sup>2</sup> /	/yr): 83.3	1	_		-i		
Cost Index (\$	\$/ft²/yr):		_				
Brief Building Description:							

# Site Plan (meter locations)





# Building Envelope



	Col	nstruction Types (c	heck all that apply)	
Walls:	Wood	Insulated?	Roofs	Insulated?
-	Masonry		Concrete Deck	
			Wood Deck	
	Concrete (above grade)		Metal Deck	
	Concrete (below grade) Metal		Other (describe if other)	
			Windows (Metal Framed)	
	Stone		Single Glazing	
	Glass		 Double Glazing	
Doors:	Other (describe if other) Solid Wood Hollow Wood Uninsulated Metal Glass (<85%) Other (describe if other) Weatherstripping		Windows (Wood Framed) Single Glazing Double Glazing	
Additional	Notes:			

# **Building Use Schedule**



Average Hours/Week:

Average Weeks/Year:

After Hours Cleaning (Y/N):

Schedule for the months of (i.e. School Year Sept - June):

	5	chequie ior	the monthe			I out	Sun	Holiday
Days	М	Т	W	Th	F	Sat	Sun	Tionacy
Hours Open								
Hours Closed								
Peak # of Occupants								
Average # of Occupants								

Schedule for the months of (i.e. Summer Months July - Aug):

	001	icuaio ioi ii				Tou	Sun	Holiday
Days	М	Т	W	Th	F	Sat	Sun	Tioliday
Hours Open								
Hours Closed								
Peak # of Occupants								
Average # of Occupants								

Schedule for the months of:

				1	-	Sat	Sun	Holiday
Days	М	Т	W	Th	F	Sai	Oun	
Hours Open								
Hours Closed								
Peak # of Occupants								
Average # of Occupants								

Schedule for the months of:

				F	Sat	Sun	Holiday
М	Т	W	Th	F	Sat	Oun	
	М	M T			The F	Th F Sat	

# **Building HVAC System Summary**



Check all major systems that apply

, s

mary Cooling:	Exhaust Systems:
Centrifugal Chiller	Fume Hoods, Constant Volume
Reciprocating Chiller	Fume Hoods, VAV
Screw Chiller	Kitchen Hoods
Absorption Chiller	Toilet Exhaust
Packaged DX	Locker Exhaust
Split DX	General Exhaust
Air-Cooled Heat Rejection	
Water-Cooled Heat Rejection	Other:
Ground-Source Heat Pump	Cogeneration
Air-Source Heat Pump	Energy Monitoring & Controls
Recirculating Water-Source Heat Pump	On-site Generation
Variable Refrigerant Flow	Active Solar Equipment
	Energy Recovery
mary Heating:	Thermal Storage
Cast Iron Hot Water Boiler	Humidifiers/Dehumidifiers
Condensing Boiler	Dessicant System
Steam Boiler	Evaporative Cooling
Furnace	Other
Ground-Source Heat Pump	
Air-Source Heat Pump	Describe if other:
Recirculating Water-Source Heat Pump	
U/Terminal Systems:	
Single Zone	
Multi Zone	
Dual Duct	
Variable Air Volume	
Reheat	
Fan Coil Units	
Unit Ventilators	
Packaged Terminal Air Conditioners	Notes:
Steam/Hot Water Radiators/Convectors	Take photos of nameplates
Above Systems with Economizer	Take photos of equipment

## **Building HVAC System Summary**



#### **Heating Plant**

i i daning i i dani		
Boiler Quantity:	Size:	Туре:
Manufacture & Model:		Fuel Used:
Hot Water Supply Setpoint:	Steam Pro	essure Setpoint:
Number of Pumps:	Total HP:	
Additional Comments: Heati	ng plant upgrades include h	eat timer and boiler controls, thermostatic radiator
valves, burner replacement,	condensate heat recovery, b	poiler replacement
Cooling Plant		
Manufacture & Model:		

Total Tonnage/kW:	
Total HP:	
oint:	
Total HP:	
Total HP:	
	Total HP: oint: Total HP:

#### **Air-Side Systems**

Tag	Model	Type (i.e. DX, VAV)	Location	Serves	Capacity/ CFM	Horsepower	Drive (VFD, etc.)

OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\Chemka Pool Building

# **HVAC Operation and Maintenance**



#### **Unoccupied Setback**

· · · · · ·

Shutdown of:	Check all that apply
AHU's by Time Schedule	
Exhaust Fans by Time Schedule	
Chillers:	
By Time Schedule	
By Outside Air Temperature	
Boilers:	
By Time Schedule	
By Outside Air Temperature	
Additional notes on operation and	maintenance procedures related to energy efficiency:
Additional notes on operation and	maintenance procedures related to energy efficiency:
Additional notes on operation and	maintenance procedures related to energy efficiency:
Additional notes on operation and	maintenance procedures related to energy efficiency:
Additional notes on operation and	maintenance procedures related to energy efficiency:
Additional notes on operation and	maintenance procedures related to energy efficiency:
Additional notes on operation and	maintenance procedures related to energy efficiency:
Additional notes on operation and	

## **Domestic Hot Water Summary**



Fuel Type:					
	Electricity				
	Natural Gas				
	Oil				
	Steam				
	- Heat Pump				
	Other (describe if	other)			
Number of	- Units:	Location:		Re-circ Loop? (Y	′/N):
Gallons:		Hot Water Supply Tem	perature:	· · · · · · · · · · · · · · · · · · ·	
Tank Insul	ated? (Y/N):	Condensing DHW Hea	ter? (Y/N):		
Additional	Comments:				

Sketch of DHW piping schematic:

#### **Food Preparation Summary**



Item	Quantity	Load (kW)
Ranges	I	
Steam Tables		
Freezers		
Refrigerators		
Walk-In Refrigerators		
Walk-In Freezers		
Infra-Red Warmer		
Microwaves		
Mixers		
Ovens		
Frying Tables		
Dishwashers		
Exhaust Hoods		

Additional Comments:

e\*\*

Sketch of kitchen layout:

# Lighting Summary

Space	Type of Fixture	No. of Fixtures	Average Watts/fixture	Type of Controls	Ballast Type	
Men's Locker	ceiling	~18		Manhal		-Mix of LED and flucrescent Ar18 LED bubbs
Room	mant					and twense
Vemen's	-	18		-		ANISLED
Locker Room	-					61105
Entry		6		-		
lifequerd	-	6		Manual		
office						
Exterior	Conport FL	67	23W	Manual		
Perol Equip.	T8 FL.	8	32(2)=640	Manhal		
Roem						
Exterior	2 bills other	3		Manua		
	I					

Additional Com	ments:			1			1
- Yaver	lighting	is like	ely 220	OV Fee	d -> Bu	It wattage	unknown
	5					0	
				1			

OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\Chemka Pool Building

2
g
Ε
Ε
2
S
0
0
a
5
0)

Space Type	Conditioned Area (ft²)	Primary HVAC Type	Primary Lighting Type	Lighting Controls	# of Occupants	Weekday Hours in Use	Weekend Hours in Use

OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\Chemka Pool Building

## **Building Characteristics**




1.

Building ID: James Harmon Community Center Date of Au	dit:
City: Hastings-on-Hudson State: NY Zip:	10706
Gross Floor Area: 17,000 ft <sup>2</sup>	
Number of Conditioned Floors: Above Grade: 3 Below Grade	le: 1
Year of Construction:	
Primary Building Function:	
Meter Number: Utility: Meter Location:	
From Utility Bills:         Utility Company:       Account Number:         Utility Company:       Account Number:	Energy Type:
Utility Company: Account Number:	Energy Type: Energy Type:
Gas (kBtu/ft²/yr):	
Electricity (kBtu/ft²/yr):       Image: Withing Meters         Gas (kBtu/ft²/yr):       Image: Withing Meters         Oil (kBtu/ft²/yr):       Image: Withing Meters         EUI (kBtu/ft²/yr):       Image: Withing Meters         Cost Index (\$/ft²/yr):       109.6         Image: Withing Meters       Image: Withing Meters         Withing Meters       Image: Withing Meters         Oil (kBtu/ft²/yr):       Image: Withing Meters         EUI (kBtu/ft²/yr):       Image: Withing Meters         Image: Withing Meters       Image: Withing Meters         Withing Meters       Image: Withing Meters         Image: W	
EUI (kBtu/ft²/yr): 109.6 Drawings Carch, Mec	n Lighting)
Cost Index (\$/ft²/yr):	
Priof Puilding Department	
bher building Description:	
	an and Youth Service
Brief Building Description: - Brilding is typically open Monday - Friday -> Comm. Ros - Community Room is bacassimily open on meekene	

(RTV-4) during where marting weekends due to need to cool server room and Raph's office

# Site Plan (meter locations)





# **Building Envelope**



Construction Types (check all that apply)

Walls:		Insulated?	Roofs	Insulated?
	Wood	s	Concrete Deck	
	Masonry		Wood Deck	
	Concrete (above grade)		Metal Deck	
	Concrete (below grade)		Other (describe if other)	
	Metal	111	Windows (Metal Framed)	
	Stone		Single Glazing	
	Glass		Double Glazing	
	Other (describe if other)		Windows (Wood Framed)	
Doors:			Single Glazing	
	Solid Wood		Double Glazing	
	Hollow Wood			
	Uninsulated Metal			
	 Glass (<85%)			
	Other (describe if other)	-		
	Weatherstripping			
Additiona	al Notes:			
******				

## **Building Use Schedule**

Average Hours/Week:

Average Weeks/Year:

After Hours Cleaning (Y/N):

Th F Sat Sun Holiday Т W Days M 9',00 am Hours Open 9:00 m -9.00m ctosed closes -8:00 pm 1:00 pm Hours Closed -Ch Peak # of Occupants Average # of Occupants

#### Schedule for the months of (i.e. School Year Sept - June):

Schedule for the months of (i.e. Summer Months July - Aug):

Days	М	Т	W	Th	F	Sat	Sun	Holiday
Hours Open								
Hours Closed								
Peak # of Occupants								
Average # of Occupants								

#### Schedule for the months of:

Days	М	Т	W	Th	F	Sat	Sun	Holiday
Hours Open								
Hours Closed								
Peak # of Occupants								2
Average # of Occupants								

Schedule for the months of:

Days	М	т	W	Th	F	Sat	Sun	Holiday
Hours Open								
Hours Closed								
Peak # of Occupants								
Average # of Occupants								



# **Building HVAC System Summary**



\_

\_

1

Check all major systems that apply

1

rimary Cooling:	Exhaust Systems:				
Centrifugal Chiller	Fume Hoods, Constant Volume				
Reciprocating Chiller	Fume Hoods, VAV				
Screw Chiller	Kitchen Hoods				
Absorption Chiller	Toilet Exhaust				
Packaged DX	Locker Exhaust				
Split DX	General Exhaust				
Air-Cooled Heat Rejection					
Water-Cooled Heat Rejection	Other:				
Ground-Source Heat Pump	Cogeneration				
Air-Source Heat Pump	Energy Monitoring & Controls				
Recirculating Water-Source Heat Pump	On-site Generation				
Variable Refrigerant Flow	Active Solar Equipment				
	Energy Recovery				
rimary Heating:	Thermal Storage				
Cast Iron Hot Water Boiler	Humidifiers/Dehumidifiers				
Condensing Boiler	Dessicant System				
Steam Boiler	Evaporative Cooling				
Furnace	Other				
Ground-Source Heat Pump					
Air-Source Heat Pump	Describe if other:				
Recirculating Water-Source Heat Pump					
HU/Terminal Systems:					
Single Zone					
Multi Zone					
Dual Duct					
Variable Air Volume	· · · · · · · · · · · · · · · · · · ·				
Reheat					
Fan Coil Units					
Unit Ventilators					
Packaged Terminal Air Conditioners	Notes:				
Steam/Hot Water Radiators/Convectors	Take photos of nameplates				
Above Systems with Economizer	Take photos of equipment				

OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\James Harmon Community Center

# **Building HVAC System Summary**



Heating Plant									
Boiler Quantity:	1		Size:			-	Гуре: 🎋	A Woote	4
Manufacture & Model	Well A	1 chain	Model	80		I	-uel Used	Nat. C	as
Hot Water Supply Set	point: 165	"F			Setpoint:				
Number of Pumps:	2	Total HP:	6(31	ach)					
Additional Comments	Heating	olant upgrad	les include	heat tim	er and boi	ler contro	ls, therm	ostatic radi	ator
valves, burner replace	ement, con	densate hea	at recovery	, boiler re	eplacemer	nt			
-HW pumps on	open	te hav	e VFO	's m	stabled	orler	line to	BMS	
							0		

#### **Cooling Plant**

Manufacture & Model:		
Chiller Quantity:	Total Tonnage/kW:	
Chilled Water Pumps Quantity:	Total HP:	
Chilled Water Supply/Return Temp Setpo	int:	
Condenser Water Pumps Quantity:	Total HP:	
Cooling Tower Fans Quantity:	Total HP:	
Additional Comments:		
-Cooling provided via Dx	cails in paretu's	

#### **Air-Side Systems**

Tag	Model	Type (i.e. DX, VAV)	Location	Serves	Capacity/ CFM	Horsepower	Drive (VFD, etc.)
RTV-1	Gardier Some 20	CAV	ROOF	2nd Floor	-		None
RTV-1 hgv2	Carter SOHJ-006	CAV	1	1st Flor			1
12123	Carrier 50A5-025	CAN	)	Committy	lm		
270-4	Grier 50 Att-020	CAV	1	and	evel		-
HV-)	Magic Aire	CAV		Basement	•		-
	0						

OLA Consulting Engineers

I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\James Harmon Community Center



#### **Unoccupied Setback**

Shutdown of:	Check all that apply
AHU's by Time Schedule	✓ > Schedules range for each RTU
Exhaust Fans by Time Schedule	
Chillers:	
By Time Schedule	
By Outside Air Temperature	
Boilers:	and and the production of the second
By Time Schedule	V > Balers antroked automotically by BMS Typical haves > 3 am - 7pm active
By Outside Air Temperature	Typical hands > 3 am - 7pm active

Additional notes on operation and maintenance procedures related to energy efficiency:

addear to be constant volume \_ VAV medu shace is u our tor pa orted fer is cer conts neerthe No codina athe and Ler graphic has an associated radiation velve or convec VAV box BMS graphics convectors are not avaives appear to has 25.90 ts can be control

RTU-1 Schedule RTU-3 Schedule HV-1 Schedule M-F: 9am-2pm Sat/Sun: No schedule M-F: Occupied haves-Barn-12am M-F: 9am -2:30pm sor/Sun: Enactive Sart. : 3am-11pm Wheeds! Also active 7pm-8:36pm Surday: gamellon RTU-4 Schedule 290-2 Schedy Mar: 3am- 9pm Mati: 2am-Bon Fri: 6am-1pm Tues-Thurs: 4am-9pm Tres: Sam- 7pm Sat/Sun: Noschedule Fri = 3am-9pm weds: 4am - 7pm Sot/Sm: Enachive Phurs: 4am - 8pm OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\James Harmon Community Center

#### **Domestic Hot Water Summary**



Fuel Type:						
	Electrici	ty				
	- Natural	Gas				
	Oil					
	Steam					
	- Heat Pu	Imp				
	Other (d	lescribe if oth	er)			
Number of	- Units:	1	Location: Baler	Room	Re-circ Loop? (Y/N):	Yes
Gallons: 1	25		Hot Water Supply T	emperature:	~110°F	
Tank Insul	ated? (Y/	′N): <b>/∖</b> ⊘	Condensing DHW H	leater? (Y/N):	No	
Additional	Commen	its:				
-DAN	heater	asar	econculation 1	000 Anot	mandains is	set to
mainte		0°F		T		

Sketch of DHW piping schematic:

#### **Food Preparation Summary**



Item	Quantity	Load (kW)
Ranges		
Steam Tables		*
Freezers		
Refrigerators		
Walk-In Refrigerators	<u>.</u>	
Walk-In Freezers		
Infra-Red Warmer		
Microwaves		
Mixers		
Ovens		
Frying Tables		
Dishwashers		
Exhaust Hoods		

#### Additional Comments:

-All electric appliances

Sketch of kitchen layout:



	Space	Type of Fixture	No. of Fixtures	Average Watts/fixture	Type of Controls	Ballast Type
Y	Woffice	TO LED	2	32(3) = 96V	Otc. Sensor	
~	Comm. Room	to LED ceiling perdat	4	*40W	Manual	
		wall manified	6	20150W		
		Toack Lights 2611 to wall mast	5	*75W		
	1	2611 to wall mast	- 4			
V	Stafe Lange	TALED	1	96W	OCC. Senser	-
×	First Flock G	r, TOLED	3	32(2)=64W	Manual	
V	Sperimenout	184ED	2	962	occ.sensor	
V	Activity Roam	178 FL. (Sylve	•••) 5	8 96W	occ sensor	
V	Multi-purpes	e to FL.	1)	96 W	occ. Senser	
	Room					
V	Multi-mecka	Sylvan a 18	4	96W	occ sensor	
	Room	1 C				
V	Youth Services	Sylvania 78	4	962	occ. senser	
	Dest.	<b>`</b>				
V	Yough Office	Silvana T8	2	962	occ. senser	
V	Yerth State	Sylvani-T8		64W	occ. Senser	
	lange	0				
V	Yough Offici	2 Sylvanna R	2	64W	occ. sensor	
V		Sylvania T8	3	96 W	Occ. sensor	
V		Sylvanne To	5	GYW	Occ. sense	
(	HSamin for					
	and love to					
	(4 total)		· Fi			

(Y total)

Additional Comments:

by occ. sensors nrooms are sensors Commit A1 IF lower sensors 000 ere <

-
5
3
Ξ
Ε
S
0
C
g
0
S

-	-			CONSULTING
Space Type				
Conditioned Area (ft²)				
Primary HVAC Type				
Primary Lighting Type				45
Lighting Controls				
# of Occupants				
Weekday Hours in Use				
Weekend Hours in Use				
X				
Space Type				
Conditioned Area (ft²)				
Primary HVAC Type				
Primary Lighting Type				
Lighting Controls				
# of Occupants				
Weekday Hours in Use			8	
Weekend Hours in Use				
		-		

OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\James Harmon Community Center

\_\_\_\_\_

.

# **Building Characteristics**

8.<sup>12</sup>. 1



Building ID:	Department of Public V	Vorks Garage			Date of Audit	
City:	Hastings-on-Hudson	State:	NY		Zip:	10706
Gross Floor A	Area: 12,000	)	ft <sup>2</sup>			
Number of Co	onditioned Floors:	Above Grade:	1		Below Grade:	
Year of Const	truction:		_			
Primary Build	ing Function: School					
Meter Numbe	r:	Utility:		Meter Loca	tion:	
Meter Numbe	r:	Utility:		Meter Loca	tion:	
Meter Numbe	r:	Utility:		Meter Loca	tion:	
Meter Numbe	r:	Utility:		Meter Loca	tion:	
Meter Numbe	r:	Utility:		Meter Loca	tion:	
From Utility Bi	ills:					
Utility Compar	ny:	Account Numb	er:			Energy Type:
Utility Compar	ny:	Account Number	er:			Energy Type:
Utility Compar	ny:	Account Number	er:			Energy Type:
Electricity (kB	tu/ft²/yr):		DLigh	+ Actu	res	
Gas (kBtu/ft²/y	yr):		the o		ins data iting hav	
Oil (kBtu/ft²/yr	):		COMA	s heater	data	
EUI (kBtu/ft <sup>2</sup> /y	rr): 72.9		CT BL	le april	ting has	S
Cost Index (\$/	ˈft²/yr):		TIDA	Dry Mate	is	
Brief Building	Description:					

.

# Site Plan (meter locations)





# **Building Envelope**



Construction	Types (check all that apply)
Insulated?	

	Insulated?	Roofs	Insulated?
Wood		Concrete Deck	
Masonry		Wood Deck	
Concrete (above grade)		Metal Deck	
Concrete (below grade)		Other (describe if other)	A
Metal			
Stone		Single Glazing	
Glass		 Double Glazing	
Other (describe if other)		Windows (Wood Framed)	
		Single Glazing	
Solid Wood		Double Glazing	
Hollow Wood			
Uninsulated Metal			
 Glass (<85%)			
Other (describe if other)			
Weatherstripping			
Notes:			
	and been	a realized which past 5	8 years
			1.0
		is brigge the bring	
	o buildi	Λ¢	
is signed in		0	
	Masonry Concrete (above grade) Concrete (below grade) Metal Stone Glass Other (describe if other) Solid Wood Hollow Wood Uninsulated Metal Glass (<85%) Other (describe if other) Weatherstripping	Wood	Wood       Concrete Deck         Masonry       Wood Deck         Concrete (above grade)       Metal Deck         Concrete (below grade)       Other (describe if other)         Metal       Windows (Metal Framed)         Stone       Single Glazing         Glass       Double Glazing         Other (describe if other)       Windows (Wood Framed)         Solid Wood       Single Glazing         Hollow Wood       Double Glazing         Uninsulated Metal       Glass (<85%)

## **Building Use Schedule**

Average Hours/Week:

Average Weeks/Year:

After Hours Cleaning (Y/N):

Days	М	Т	W	Th	F	Sat	Sun	Holiday
Hours Open	7:00	1	-	-	~~~	8:00	closed	
Hours Closed	3:30	)	-	-		v2:000m		
Peak # of Occupants								
Average # of Occupants								

#### Schedule for the months of (i.e. School Year Sept - June):

Schedule for the months of (i.e. Summer Months July - Aug):

Days	М	Т	W	Th	F	Sat	Sun	Holiday
Hours Open								
Hours Closed								
Peak # of Occupants								
Average # of Occupants								

Schedule for the months of:

Days	М	Т	W	Th	F	Sat	Sun	Holiday
Hours Open								
Hours Closed								
Peak # of Occupants								
Average # of Occupants								

Schedule for the months of:

Days	М	Т	W	Th	F	Sat	Sun	Holiday
Hours Open	and the second							
Hours Closed								
Peak # of Occupants								
Average # of Occupants								

# **Building HVAC System Summary**



4.20

Check all major systems that apply

nary Cooling:	Exhaust Systems:
Centrifugal Chiller	Fume Hoods, Constant Volume
Reciprocating Chiller	Fume Hoods, VAV
Screw Chiller	Kitchen Hoods
Absorption Chiller	Toilet Exhaust
Packaged DX	Locker Exhaust
Split DX	General Exhaust
Air-Cooled Heat Rejection	
Water-Cooled Heat Rejection	Other:
Ground-Source Heat Pump	Cogeneration
Air-Source Heat Pump	Energy Monitoring & Controls
Recirculating Water-Source Heat Pump	On-site Generation
Variable Refrigerant Flow	Active Solar Equipment
	Energy Recovery
nary Heating:	Thermal Storage
Cast Iron Hot Water Boiler	Humidifiers/Dehumidifiers
Condensing Boiler	Dessicant System
Steam Boiler	Evaporative Cooling
Furnace	Other
Ground-Source Heat Pump	
Air-Source Heat Pump	Describe if other:
Recirculating Water-Source Heat Pump	
J/Terminal Systems:	
Single Zone	120.20120.2010.00000000000
Multi Zone	5
Dual Duct	
Variable Air Volume	
Reheat	
Fan Coil Units	
Unit Ventilators	. <u></u>
Packaged Terminal Air Conditioners	Notes:
Steam/Hot Water Radiators/Convectors	Take photos of nameplates
Above Systems with Economizer	Take photos of equipment

OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\DPW Garage

# **Building HVAC System Summary**



Heating Plant		
Boiler Quantity:	Size:	Туре:
Manufacture & Model:		Fuel Used:
Hot Water Supply Setpoint:	Steam Pressure Setpoint:	
Number of Pumps: Total HP:		
Additional Comments: Heating plant upgrade	s include heat timer and boiler conti	rols, thermostatic radiator
valves, burner replacement, condensate heat	recovery, boiler replacement	
- Heating for garage provi		Theaters
-cas-fired thrade serves	office sation of	garage
		0 0
Cooling Plant		
Manufacture & Model:		
Chiller Quantity:	Total Tonnage/kW:	
Chilled Water Pumps Quantity:	Total HP:	
Chilled Water Supply/Return Temp Setpoint:		
Condenser Water Pumps Quantity:	Total HP:	
Cooling Tower Fans Quantity:	Total HP:	
Additional Comments:		
Additional Comments: - Couling provided by 3 # Fans	ofal wholer Ac unit	ts and ceiling

**Air-Side Systems** 

Tag	Model	Type (i.e. DX, VAV)	Location	Serves	Capacity/ CFM	Horsepower	Drive (VFD, etc.)

OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\DPW Garage

#### **HVAC Operation and Maintenance**



#### **Unoccupied Setback**

Shutdown of:	Check all that apply Repair Shap
AHU's by Time Schedule	-typical furnace occupied temp: ~68°F
Exhaust Fans by Time Schedule	Unoccupied temp: n 62°F (menning setback)
Chillers:	- harage is usually sotback to some temp. during unoccupied hours
By Time Schedule	duringe is upgendel have
By Outside Air Temperature	
Boilers:	-Ventilation is only provided by opening does and windows
By Time Schedule	
By Outside Air Temperature	

Heneyw aas 5 car ON a 5 ne hn 2 are P gara SP. 5 0

# **Domestic Hot Water Summary**



Fuel Type:							
	Electricity						
$\sim$	- Natural Gas						
	Oil						
	Steam						
	- Heat Pump						
	Other (descril	be if other	)				
Number of	Units:	I	Location:	Garage		Re-circ Loop? (Y/N):	
Gallons:	40			er Supply Tempe	erature:		
Tank Insul	ated? (Y/N): 🖊	vo	Condens	ing DHW Heate	r? (Y/N):	No	
Additional	Comments:						
				10-11-11-11-11-11-11-11-11-11-11-11-11-1			
A							

Sketch of DHW piping schematic:

### **Food Preparation Summary**



Item	Quantity	Load (kW)
Ranges		
Steam Tables		
Freezers		
Refrigerators		
Walk-In Refrigerators		
Walk-In Freezers		
Infra-Red Warmer		
Microwaves		
Mixers		*
Ovens		
Frying Tables		
Dishwashers		
Exhaust Hoods		

#### Additional Comments:

Sketch of kitchen layout:



Space	Type of Fixture	No. of Fixtures	Average Watts/fixture	Type of Controls	Ballast Type
Secretary	18 FL.	5	32(2)=644	Manual	
Sterage	18 FZ. 18 FL.	4	64 W	Manual	
Batwoon	18 FL.	2	64W	-	
	1872.	T	32W	-	
Locker Room	18 FL	2	SYW	-	
Upper Floor	78 FL.	4	64W	-	
Shop					
Serrys Office	T8 FL.	в	GUV	-	
Garange \$2	ke certing hum	8	* 14PS	(1 burb)	
00 0	Street lamp	L L		-	
Garage 1000		3	* (Meto	1 barlphe) 1 built	
RepairSho	2			(Manual)	
		L			

### Additional Comments:

OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\DPW Garage

Space Type     Scrubby Scrubby       Continued     Controlled       Area (The Start     Locker Runder Runder       The Space Type     File Start       The Space Type     T3 FL       Type     T3 FL       Type     T3 FL       Type     T3 FL       Tope     T			Space	Space Summary		
De     Sectorlary     Lotler Rm       ed						CONSULTING
ed NAC -1-Inition K -2-ante Ivater (plug in) ighting 18 FL 18 FL 1	Space Type	Secretary	LockerAm	Jern's Of	.8	
WAC -1 wider K Serve Inder K (ghting 18 R. redithr Pants 2 Hours Hours Hours Hours Hours Hours Hours Hours Hours Hours Hours	Conditioned Area (ft²)					
/ Lighting       18 FL.       78 FL.         and Hours       Anomal       Monmal         ay Hours       2       16         ay Hours       1       1         Type       1       1         Type       1       1         If yhe       1       1       1         If yhe       1 <td>Primary HVAC Type</td> <td>-1 window MC -Space heater(p)W</td> <td></td> <td>- Initual RC 4</td> <td>init Lata</td> <td></td>	Primary HVAC Type	-1 window MC -Space heater(p)W		- Initual RC 4	init Lata	
Bit Monul     Monul       cupants     2       ay Hours     2       ay Hours     1       ay Hours     1       Type     1 <t< td=""><td>Primary Lighting Type</td><td></td><td></td><td>A C.</td><td></td><td></td></t<>	Primary Lighting Type			A C.		
# of Cocupants         2         1         1           Weekday Hours         Weekday Hours         1         1         1           Weekday Hours         Weekend Hours         1         1         1         1           Weekend Hours         Weekend Hours         1         1         1         1         1           Weekend Hours         Space Type         1 <t< td=""><td>Lighting Controls</td><td>Manual</td><td>Monuel</td><td>Manual</td><td></td><td></td></t<>	Lighting Controls	Manual	Monuel	Manual		
Weekday Hours     Weekday Hours       in Use       Weekend Hours       Space Type       Conditioned       Space Type       Conditioned       Area (ft <sup>*</sup> )       Area (ft <sup>*</sup> )       Primary Lighting       Lighting       Lighting       Lighting       Lighting       Locupants       # of Occupants       Weekend Hours       Weekend Hours	# of Occupants	2		-		
Weekend Hours         Weekend Hours           In Use         In Use           Space Type         In Use           Conditioned         In In International Internatione Internatione Internatione Internatione International Internati	Weekday Hours in Use					
Space Type         Space Type           Conditioned         Conditioned           Area (t <sup>*</sup> )         Primary HVAC           Primary HVAC         Primary Lighting           Type         Primary Lighting           Type         Primary Lighting           Dighting         Primary Lighting           Type         Primary Lighting           Dighting         Primary Lighting           Type         Primary Lighting           Dighting         Primary Lighting           Dighting         Primary Lighting           Use         Primary Lighting           Dighting         Primary Lighting           Primary Lighting         Primary Lighting           Dighting         Primary Lighting           Dighting         Primary Lighting <t< td=""><td>Weekend Hours in Use</td><td></td><td></td><td></td><td></td><td></td></t<>	Weekend Hours in Use					
Space Type         Conditioned         Conditioned <thconditioned< th=""> <thconditioned< th=""></thconditioned<></thconditioned<>						
Conditioned         Conditioned           Area (t <sup>2</sup> )         Area (t <sup>2</sup> )           Primary HVAC         Type           Type         Type           Ushting         Type           Ushting         Type           Type         Type           Type         Type           Type         Type           Type         Type           Ushting         Type           Meekday Hours         Type           In Use         Type           In Use         Type	Space Type					
Primary HVAC         Primary HVAC           Type         Type           Primary Lighting         Primary Lighting           Primary Lighting         Primary Lighting           Type         Primary Lighting           Lighting         Primary Lighting           Veckotal         Primary Lighting           Modekaday Hours         Primary Lighting           Weekday Hours         Primary Lighting           In Use         Primary Lighting           In Use         Primary Lighting	Conditioned Area (ft²)					
Primary Lighting         Primary Lighting           Type         Type           Lighting         E           Controls         E           # of Occupants         E           Weekday Hours         E           In Use         E           Weekend Hours         E           In Use         E	Primary HVAC Type					
Lighting       Lighting         Controls       Controls         # of Occupants       E         Weekday Hours       E         In Use       Weekend Hours         In Use       In Use	Primary Lighting Type					
# of Occupants Weekday Hours In Use Weekend Hours In Use In Use Weekend Hours In Use	Lighting Controls					
Weekday Hours     Meekday Hours       in Use     Meekend Hours       in Use     In Use	# of Occupants					
Weekend Hours in Use	Weekday Hours in Use					
	Weekend Hours in Use					

OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\DPW Garage

. 1

# **Building Characteristics**


.



Building ID: Hook and Ladder Com	pany		Date of Aud	lit:
City: Hastings-on-Hudson	State:	NY	Zip:	10706
Gross Floor Area: 9,000	1	ft <sup>2</sup>		
Number of Conditioned Floors:	Above Grade:	2	Below Grad	e:
Year of Construction:				
Primary Building Function: School				
Meter Number:	Utility:		Meter Location:	
Meter Number:	Utility:		Meter Location:	
Meter Number:	Utility:		Meter Location:	
Meter Number:	Utility:		Meter Location:	
Meter Number:	Utility:		Meter Location:	
From Utility Bills: Utility Company: Utility Company:	Account Numbe			Energy Type:
Utility Company:	Account Numbe			Energy Type:
Electricity (kBtu/ft <sup>2</sup> /yr):	Account Numbe		a day would be had	Energy Type:
Gas (kBtu/ft <sup>2</sup> /yr):		${\bf igodot}$	Utility BAAS Me fer	3
Oil (kBtu/ft²/yr):		Ø	Drawings-None	
EUI (kBtu/ft²/yr): 75.3			J	
Cost Index (\$/ft²/yr):	1			
Brief Building Description:				

## Site Plan (meter locations)





OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\Hook and Ladder Co.

# **Building Envelope**



	Constr	uction Types (che	ck all that a	pply)	
Walls:		sulated?	Roofs		Insulated?
/	Wood			Concrete Deck	
	Masonry			- Wood Deck	
	Concrete (above grade)			- Metal Deck	
	Concrete (below grade)			Other (describe if other)	
	Metal		Windows (	- Metal Framed)	-
-	Stone			Single Glazing	
	Glass		$\overline{}$	Double Glazing	
	Other (describe if other)		Windows (	Nood Framed)	
Doors:			(	Single Glazing	
-	Solid Wood			Double Glazing	
	Hollow Wood			Ŭ.	
	Uninsulated Metal				
	Glass (<85%)	n an			
	Other (describe if other)	1			
	Weatherstripping				
Additional N - Sane - S	Notes: - Windows In 2 ef at some point mindows throughout pomed wood fre Room nindows ining mindows upo		have	pear to have b been replaced as ago accord ago	nAh hing to staff

#### **Building Use Schedule**



Average Hours/Week:

Average Weeks/Year:

After Hours Cleaning (Y/N):

Schedule for the months of (i.e. School Year Sept - June):

Days	M	т	W	Th	F	Sat	Sun	Holiday
Hours Open	Almays							
Hours Closed	oncell							
Peak # of Occupants								
Average # of Occupants								

## Schedule for the months of (i.e. Summer Months July - Aug):

Days	М	Т	W	Th	F	Sat	Sun	Holiday
Hours Open								
Hours Closed								
Peak # of Occupants								
Average # of Occupants							×.	

#### Schedule for the months of:

							0	Lalidov
Days	М	Т	W	Th	F	Sat	Sun	Holiday
Hours Open								
Hours Closed								
Peak # of Occupants								
Occupants Average # of Occupants								

#### Schedule for the months of:

			1 10/	ТЬ	F	Sat	Sun	Holiday
Days	М	T	W	Th	F	Jai	Ouri	, including
Hours Open				11				
Hours Closed								
Peak # of Occupants								
Average # of Occupants								

## Building HVAC System Summary



-----\_\_\_\_

Check all major systems that apply

rimary Cooling:	Exhaust Systems:
Centrifugal Chiller	Fume Hoods, Constant Volume
Reciprocating Chiller	Fume Hoods, VAV
Screw Chiller	Kitchen Hoods
Absorption Chiller	Toilet Exhaust
Packaged DX	Locker Exhaust
Split DX	General Exhaust
Air-Cooled Heat Rejection	
Water-Cooled Heat Rejection	Other:
Ground-Source Heat Pump	Cogeneration
Air-Source Heat Pump	Energy Monitoring & Controls
Recirculating Water-Source Heat Pump	On-site Generation
Variable Refrigerant Flow	Active Solar Equipment
	Energy Recovery
imary Heating:	Thermal Storage
Cast Iron Hot Water Boiler	Humidifiers/Dehumidifiers
Condensing Boiler	Dessicant System
Steam Boiler	Evaporative Cooling
Furnace	Other
Ground-Source Heat Pump	
Air-Source Heat Pump	Describe if other:
Recirculating Water-Source Heat Pump	
IU/Terminal Systems:	
Single Zone	
Multi Zone	
Dual Duct	
Variable Air Volume	
Reheat	
Fan Coil Units	
Unit Ventilators	
Packaged Terminal Air Conditioners	Notes:
Steam/Hot Water Radiators/Convectors	Take photos of nameplates
Above Systems with Economizer	Take photos of equipment

**OLA Consulting Engineers** 

I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\Hook and Ladder Co.

#### Building HVAC System Summary



Heating Plant					2.1
Boiler Quantity:	1	Size: 366 M	BH (Inont)	Type: A Hot L Fuel Used: Not	later
Manufacture & Model: V	veil McLain	PFG	•,	Fuel Used: Nort	Gas
Hot Water Supply Setpoin	nt: ~170°F	Steam Pressure	Setpoint:		<u></u>
Number of Pumps: 4	Total HP:				
Additional Comments: He	eating plant upgrades	s include heat tim	er and boiler cont	trols, thermostatic rac	liator
valves, burner replaceme			eplacement		
- 4 zones and	recire ph	mps			
	And a second sec				

#### **Cooling Plant**

Manufacture & Model:

Total Tonnage/kW:	
Total HP:	-
nt:	
Total HP:	
Total HP:	
	Total HP: nt: Total HP:

#### Air-Side Systems

Tag	Model	Type (i.e. DX, VAV)	Location	Serves	Capacity/ CFM	Horsepower	Drive (VFD, etc.)
			12				

OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\Hook and Ladder Co.

#### **HVAC Operation and Maintenance**



#### **Unoccupied Setback**

Shutdown of:	Check all that apply
AHU's by Time Schedule	
Exhaust Fans by Time Schedule	
Chillers:	
By Time Schedule	
By Outside Air Temperature	
Boilers:	
By Time Schedule	
By Outside Air Temperature	

Additional notes on operation and maintenance procedures related to energy efficiency:

- Thermostat in workant room appears to be broken	
- Diffused in bar room are used as an exhaust	_
ajsten - Installed when smoking was common	_
- Fan is located up in criting - S One for for bar section	a
and another for the rest of the poon	
-	_
-Balers cycles cartinuously -> the Staff indicated thermos	Forts
are always set between 188-72°F and do not school ort	_
night J	
	_
	-
	_

#### **Domestic Hot Water Summary**



Fuel Type:		
Electricity		
Natural Gas		
Oil		
Steam		
Heat Pump		
Other (describe if oth	ner)	
Number of Units:	Location: Basement	Re-circ Loop? (Y/N): KS
Gallons: 50	Hot Water Supply Temperature:	
Tank Insulated? (Y/N): 🖊 🧿	Condensing DHW Heater? (Y/N):	
Additional Comments:		

Sketch of DHW piping schematic:

## **Food Preparation Summary**



Item	Quantity	Load (kW)
Ranges	1	
Steam Tables		
Freezers	1	
Refrigerators	1	
Walk-In Refrigerators		
Walk-In Freezers		
Infra-Red Warmer		
Microwaves	1	
Mixers		
Ovens		
Frying Tables		
Dishwashers	,	
Exhaust Hoods		

Additional Comments:	
- Las range/oven	1 T T T T
- Ges range/oven - Blectric register and Ice maker	
0	

Sketch of kitchen layout:



	Space	Type of Fixture	No. of Fixtures	Average Watts/fixture	Type of Controls	Ballast Type
×	Main Caroge	18 FL	14	32(3)=962	Manha)	
/	-	land	<b>2</b> 6	132	Manual	
V	chief's office	18 El.	9	32(3)=962	Mamal	
V	Staroge Rm	78 F2.	1	96W	Manual	
V	2nd A or BAN	Round figures	4		Mannal	
×	Kitchen	land Frances	10		Manna	
\ ~	Buck Corrida	2x2' the	3	32(2)=64	Manual	
	_	(Ustrales)-25	otco 78			
X	Main Garage	Round	3	132	Occ. Schser	
	Werhcust Room		M	64W	Manual	
			D-Ssateo T8		Manual	
	Lange	2×2' tile	7			
	0	(Single build)				
	Box Room	Round	27	13W	Manna	
		ceiling pend.	3		-	

#### Additional Comments:

OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\Hook and Ladder Co.

mlange" 1 F	Ber		-2 splict Alumit	pernet	Manual	~20				
"Chird's OFFice"			~					^		
	Launge		-Wheeler Ac							
Space Summary			t							
E	39		-Inhadon Acan							
struch Rem	March Correge		-	T8 A.	XIW					
Rear Poor	Chief Office Marh Concept		-Basebond hent Beerbookd	-18 FL.	Manual)	× 6				
5	Space Type	Conditioned Area (ft²)	IVAC	Primary Lighting Type	Lighting Controls	# of Occupants	Weekday Hours in Use	Weekend Hours in Use	Space Type	

· . . ,

Space Type				
Primary HVAC Type				
Primary Lighting Type				
# of Occupants				
Weekday Hours in Use				
Weekend Hours in Use				

OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\Hook and Ladder Co.



1


.



Building ID: Public Library			Date of A	udit:
City: Hastings-on-Hudson	State:	NY	Zip:	10706
Gross Floor Area: 13,22	5	ft <sup>2</sup>		10100
Number of Conditioned Floors:	Above Grade:	2	Below Gra	ade:
Year of Construction:				the second s
Primary Building Function: School-			Sec. 1	emp~23°F BETCe temp~81°F
Meter Number:	Utility:	M	eter Location:	beice temp to 81 F
Meter Number:	Utility:		eter Location:	
Meter Number:	Utility:		eter Location:	
Meter Number:	Utility:		eter Location:	
Meter Number:	Utility:	M	eter Location:	
Utility Company: Utility Company: Utility Company: Electricity (kBtu/ft²/yr): Gas (kBtu/ft²/yr):	Account Numbe Account Numbe Account Numbe	r:	y Moter	Energy Type: Energy Type: Energy Type:
Oil (kBtu/ft²/yr):           EUI (kBtu/ft²/yr):         111.2           Cost Index (\$/ft²/yr):         111.2		DArch.	plans -> Wall,	Window details
Brief Building Description: - Renarchian added - - Ac-1 (HV-1) appears -	to the blue blue be crigin		2001-3AC-Z e building	and AC-3 mstallus

Site Plan (meter locations)





OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\Public Library

## Site Plan (meter locations)

.

1



## **Building Envelope**



Construction	on Types (che	ck all that apply)		Insulated?
Insulat	ed?	Roofs		Insulated
Wood				
-		Wood [	Deck	
		Metal D	Deck	
		Other (	describe if other	)
-		Windows (Metal Fr	ramed)	
		Double	e Glazing	
		Windows (Wood F	ramed)	
Other (describe if other)				
Solid Wood				
Hollow Wood				
Uninsulated Metal				α.
Glass (<85%)				
Other (describe if other)				
Weatherstripping				
	invelope h accol whe s updat	a cealised	•	pgraels-> see blue prints
	Insulat Wood Masonry Concrete (above grade) Concrete (below grade) Metal Stone Glass Other (describe if other) Solid Wood Hollow Wood Uninsulated Metal Glass (<85%) Other (describe if other) Weatherstripping	Insulated?          Wood         Masonry         Concrete (above grade)         Concrete (below grade)         Metal         Stone         Glass         Other (describe if other)         Solid Wood         Hollow Wood         Uninsulated Metal         Glass (<85%)	Wood       Concrete         Masonry       Wood I         Concrete (above grade)       Metal I         Concrete (below grade)       Other (I         Metal       Windows (Metal Fill         Stone       Single         Glass       Double         Other (describe if other)       Windows (Wood Fill         Solid Wood       Single         Hollow Wood       Double         Uninsulated Metal       Double         Glass (<85%)	Insulated?       Roofs         Wood

OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\Public Library

#### Building Use Schedule

Average Hours/Week:

Average Weeks/Year:

After Hours Cleaning (Y/N):

	Schedule for the months of (i.e. School Year Sept - June):									
Days	М	Т	W	Th	F	Sat	Sun	Holiday		
Hours Open	9:30	-	-	9:30	9:30	-	1:00			
Hours Closed	8,30	-	6:0000	8:30	S:00pm	5:00pm	5:00			
Peak # of Occupants			6	-						
Average # of Occupants										

Schedule for the months of (i.e. Summer Months July - Aug):

Days	М	Т	W	Th	F	Sat	Sun	Holiday
Hours Open								
Hours Closed								
Peak # of Occupants								
Average # of Occupants								

#### Schedule for the months of:

Days	М	Т	w	Th	F	Sat	Sun	Holiday
Hours Open								
Hours Closed								
Peak # of								
Occupants								
Average # of								
Occupants								

Schedule for the months of:

Days	М	Т	W	Th	F	Sat	Sun	Holiday
Hours Open								
Hours Closed								
Peak # of Occupants								
Average # of Occupants								

## **Building HVAC System Summary**



\_

\_

#### Check all major systems that apply

Primary Cooling:	Exhaust Systems:
Centrifugal Chiller	Fume Hoods, Constant Volume
Reciprocating Chiller	Fume Hoods, VAV
Screw Chiller	Kitchen Hoods
Absorption Chiller	Toilet Exhaust
Packaged DX	Locker Exhaust
Split DX	General Exhaust
Air-Cooled Heat Rejection	
Water-Cooled Heat Rejection	Other:
Ground-Source Heat Pump	Cogeneration
Air-Source Heat Pump	Energy Monitoring & Controls
Recirculating Water-Source Heat Pump	On-site Generation
Variable Refrigerant Flow	Active Solar Equipment
	Energy Recovery
rimary Heating:	Thermal Storage
Cast Iron Hot Water Boiler	Humidifiers/Dehumidifiers
Condensing Boiler	Dessicant System
Steam Boiler	Evaporative Cooling
Furnace	Other
Ground-Source Heat Pump	
Air-Source Heat Pump	Describe if other:
Recirculating Water-Source Heat Pump	
AHU/Terminal Systems:	
Single Zone	-
Multi Zone	
 Dual Duct	
Variable Air Volume	
Reheat	N State Stat
Fan Coil Units	
Unit Ventilators	
Packaged Terminal Air Conditioners	Notes:
Steam/Hot Water Radiators/Convectors	Take photos of nameplates
Above Systems with Economizer	Take photos of equipment

OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\Public Library

## Building HVAC System Summary



Boiler Quantity:	Size:	Туре:
Manufacture & Model:		Fuel Used:
Hot Water Supply Setpo	int: Steam P	ressure Setpoint:
Number of Pumps:	2 Total HP: 25(1)	ly each)
Additional Comments: H	a and a second a s	neat timer and boiler controls, thermostatic radiator
	ent, condensate heat recovery,	
- Hot water	provided by Mlage	Hall via heart exchanger
	5 0	0

Cooling Plant			
Manufacture & Model: Trame 60-A	DOYOGAFAI9G	Chiller	
Chiller Quantity: 4	Total Tonnage/kW:		(R-22)
Chilled Water Pumps Quantity: 2	Total HP: 3(1.5 HPe	ach)	
Chilled Water Supply/Return Temp Setpoint:		5	
Condenser Water Pumps Quantity:	Total HP:	а.	
Cooling Tower Fans Quantity:	Total HP:		
Additional Comments:			
- 4 compressor			
			1.1

#### **Air-Side Systems**

**Heating Plant** 

I						r	
Tag	Model	Type (i.e. DX, VAV)	Location	Serves	Capacity/ CFM	Horsepower	Drive (VFD, etc.)
AC-2				Barres			
AC-2 AC-3 HV-1			Book Room	Bernes Room Ricture Bon	R		
HN-1				Library			
MASabroh	(		stilling an	Conference			
				peor			

OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\Public Library

## **HVAC Operation and Maintenance**



#### **Unoccupied Setback**

Shutdown of:	Check all that apply
AHU's by Time Schedule	
Exhaust Fans by Time Schedule	
Chillers:	
By Time Schedule	
By Outside Air Temperature	
Boilers:	
By Time Schedule	
By Outside Air Temperature	
	I maintenance procedures related to energy efficiency:
-AL-3 Genes Pretures	
	sump serves community Room, controlled
locally by thermost	
- AUS Tocated in	closet in Preture Book Room
SJoan office is to	be upgraded when new Mitsubishi heart pump
	••



Fuel Type:			
Electricity			
Natural Gas			
Oil			
Steam			
Heat Pump			
Other (describe if other	her)		
		0	
Number of Units:	Location:	Basement	Re-circ Loop? (Y/N): KS
Number of Units: Gallons: 40		Supply Temperature:	Re-circ Loop? (Y/N): KS
11	Hot Water		
Gallons: 40	Hot Water	Supply Temperature:	
Gallons: 40 Tank Insulated? (Y/N): 10	Hot Water	Supply Temperature:	
Gallons: 40 Tank Insulated? (Y/N): 10	Hot Water	Supply Temperature:	

Sketch of DHW piping schematic:

#### **Food Preparation Summary**



Item	Quantity	Load (kW)
Ranges		
Steam Tables		
Freezers		
Refrigerators		
Walk-In Refrigerators	1	
Walk-In Freezers		
Infra-Red Warmer		
Microwaves	1	
Mixers		
Ovens		
Frying Tables		
Dishwashers		
Exhaust Hoods		

## Additional Comments: - Starr launge contains all cleater appliances

Sketch of kitchen layout:

### **Lighting Summary**

1	٩.	1		H
	100			l
	ł	[]	1	
L	L			H
		IJ	Ц	

	1					ENGINEERS
Space	Type of Fixture	No. of Fixtures	Average Watts/fixture	Type of Controls	Ballast Type	
Mail library	Seco penden	° 20		Manual		
2 lant	4' Linear tub		18(2)=36 W (	LEN		1
Book Shap	Spellifeithent	Ч	12W(15	0 -		Light ans skylight
3	spicish marth,	15	12(3)-2	4W		Light
Staff Room	and roma (	L6116)5	24W	-		Ke Cantans sky H3bit
Prime Book	thich mant	12	24 W	-		
Director's Coffee	2 Auch mant	5	240	1		
Basement Cont		Scibul	128W	-		
Dasement	2x2 U-tubel	26-16) 1		-		1
Elanter Machine Recom	rend forme	1		-		
Elanter Maden Accomment Loby	Topaz LED	7 (16mbb	) 12W			1
10	TOPAZLED	2(2but	) 24W			1
۱	TODAZ LED	3(264H	24W			1
Comunity	FOALLED	31(26,16)	24W	-		1
15 (g.	Track Lights	19 (161)	75W			1
com Regon	2x02 U-tube	2(26416)				1
Bomes Room	Topaz LED	9 (1 tub)	ZW	-		1
I	Topaz LED	9(2 kulb)	24 2			
Baseryant Stoff	Luxinte LED	1(264/8)	20(2)=400	-		
Stafflange	Topaz CED	6(2tul)	242			1
	LuxinteLED	4(26116)	402	-		1
-	-	4(2 bull)	402			
Electrical	4'LED-tubes	3(2646)	362			1

#### Additional Comments:

 $\tau = - F$ 

- Ah	lighton	is cantrolle	d by	light switch	es Doce.	senses	appear
to be	instalke	ibit do r	of fi	inction			
-							

OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\Public Library

ice Summary		
ice Summa	2	5
ice Summ	5	9
ice Sum		E
ice Su		Ξ
ice S	5	1
Ce	) '	U
Q	)	¢
	2	5
a	2	5
5	5	2

Space Type         Conditioned					CONSULTING
Conditioned         Conditioned <thconditioned< th=""> <thconditioned< th=""></thconditioned<></thconditioned<>	Space Type				
Finary Fixed         Finary Lighting         Finary Lighti	Conditioned				
Frimary Lighting         Frimary Lighting         Frimary Lighting         Frimary Lighting           Type         Lighting         E (1000)	Primary HVAC Tvpe				
Lighting	Primary Lighting Type				
# of Occupants         # of Oc	Lighting Controls				
Weekday Hours         Weekday Hours         In Use           In Use         Weekday Hours         In Use           Weekday Hours         In Use         In Use           Weekday Hours         In Use         In Use           Weekday Hours         In Use         In Use           Meekend Hours         In Use         In Use           Space Type         In Use         In Use           Conditioned         In Use         In Use           Mean (It')         In Use         In Use           Mean (It')         In Use         In Use           Weekend Hours         In Use         In In Use           Meekend Hours         In Use         In In Use	# of Occupants				
Weekend Hours       Weekend Hours         in Use       Image         Space Type       Image         Conditioned       Image         Area (ft <sup>2</sup> )       Image         Primary HVAC       Image         Primary HVAC       Image         Primary Lighting       Image         Upfer       Image         Upfer       Image         Lighting       Image         Undekend Hours       Image         Image       Image	Weekday Hours in Use				
Space Type         Space Type           Space Type         Conditioned           Conditioned         Enter (H <sup>2</sup> )           Area (H <sup>2</sup> )         Enter (H <sup>2</sup> )           Primary HVAC         Enter (H <sup>2</sup> )           Primary HVAC         Enter (H <sup>2</sup> )           Primary Lighting         Enter (H <sup>2</sup> )           Primary Lighting         Enter (H <sup>2</sup> )           Primary Lighting         Enter (H <sup>2</sup> )           Weekday Hours         Enter (H <sup>2</sup> )           In Use         Meekend Hours	Weekend Hours				
Space Type         Conditioned         Model					
Conditioned         Conditioned <thconditioned< th=""> <thconditioned< th=""></thconditioned<></thconditioned<>	Space Type				
Primary HVAC         Primary HVAC           Type         Type           Primary Lighting         Primary Lighting           Type         Type           Type         Primary Lighting           Controls         Primary Lighting           Lighting         Primary Lighting           Controls         Primary Lighting           Lighting         Primary Lighting           Meekday Hours         Primary Lighting           Meekend Hours         Primary Lighting           In Use         Primary Lighting	Conditioned Area (ft <sup>2</sup> )				
Primary Lighting         Primary Lighting           Type         Lighting           Controls         Primary Lighting           Lighting         Primary Lighting           Lighting         Primary Lighting           Controls         Primary Lighting           # of Occupants         Primary Lighting           Weekday Hours         Primary Lighting           In Use         Primary Lighting           Weekend Hours         Primary Lighting	Primary HVAC Type				
Lighting Controls Controls # of Occupants # of Occupants Weekday Hours in Use Weekend Hours	Primary Lighting Tvpe				
# of Occupants # of Occupants Weekday Hours In Use Weekend Hours In Use	Lighting Controls				
Weekday Hours In Use Weekend Hours In Use	# of Occupants				
Weekend Hours in Use	Weekday Hours in Use				
	Weekend Hours in Use				

OLA Consulting Engineers I:\Projects\VOH\NVOH0001.00\Docs\Site Visit Forms\Public Library


## **Building Characteristics**

 $e_{ij}$ 



Building ID:	Village Hall			Date of Auc	dit:
City:	Hastings-on-Hudson	State:	NY	Zip:	10706
Gross Floor	Area: 8,700	)	ft <sup>2</sup>		
Number of C	onditioned Floors:	Above Grade:	2	Below Grad	le:
Year of Cons	struction:		-0		
Primary Build	ding Function:				
Meter Numbe	er:	Utility:		Meter Location:	
Meter Number	er:	Utility:		Meter Location:	
Meter Number	er:	Utility:		Meter Location:	
Meter Numbe	er:	Utility:		Meter Location:	
Meter Number	er:	Utility:		Meter Location:	
From Utility E Utility Compa		Account Numb	er:		Energy Type:
Utility Compa	any:	Account Numb	er:		Energy Type:
Utility Compa	any:	Account Numb			Energy Type:
Electricity (kE	Btu/ft²/yr):		FUT	ility maters >	bis meter is for Marc Hall, other two are for cellular data (not paid-for
Gas (kBtu/ft <sup>2</sup>	/yr):		1	a h res	Hall, other two are fer
Oil (kBtu/ft²/y	rr):			sht trainics	cellular data (not paidter
EUI (kBtu/ft <sup>2</sup> /	yr): 111.2				Gy Mnage)
Cost Index (\$	5/ft²/yr):				
Brief Building	Description: - Bldg Renaration In	was built	in 19: terior	rall additions	





1.1



## **Building Envelope**



Construction Types (check all that apply)
---

Walls:		Insulated?	Roofs		Insulated?
	Wood			Concrete Deck	
	 Masonry			Wood Deck	
	Concrete (above grade)			Metal Deck	
	Concrete (below grade)			Other (describe if other	)
	 Metal		Windows	s (Metal Framed)	
	Stone			Single Glazing	
	Glass			Double Glazing	
	Other (describe if other)	)	Windows	s (Wood Framed)	
Doors:				Single Glazing	
	Solid Wood			Double Glazing	
	Hollow Wood				
·	Uninsulated Metal				
	Glass (<85%)				
	Other (describe if other	)			
	Weatherstripping				
	_				
Addition	al Notes:				
-		crigonal +	. The bri	Iding	

J

7

0

#### **Building Use Schedule**



Average Hours/Week:

Average Weeks/Year:

#### After Hours Cleaning (Y/N):

# \* Building is "Scarpled" 24/7 due to Police dept. Schedule for the months of (i.e. School Year Sept - June):

Days	М	Т	W	Th	F	Sat	Sun	Holiday
Hours Open	8:30	~	-	-	-	Closed	closed	
Hours Closed	4:00	)	~	)	-			
Peak # of								
Occupants								
Average # of								
Occupants								

#### Schedule for the months of (i.e. Summer Months July - Aug):

Days	М	Т	W	Th	F	Sat	Sun	Holiday
Hours Open								
Hours Closed								
Peak # of Occupants								
Average # of Occupants								

#### Schedule for the months of:

Days	М	Т	W	Th	F	Sat	Sun	Holiday
Hours Open								
Hours Closed								
Peak # of Occupants								
Average # of Occupants								

#### Schedule for the months of:

Days	М	Т	W	Th	F	Sat	Sun	Holiday
Hours Open								
Hours Closed								
Peak # of Occupants								
Average # of Occupants								

#### **Building HVAC System Summary**



Check all major systems that apply

imary Cooling:	Exhaust Systems:
Centrifugal Chiller	Fume Hoods, Constant Volume
Reciprocating Chiller	Fume Hoods, VAV
Screw Chiller	Kitchen Hoods
Absorption Chiller	Toilet Exhaust
Packaged DX	Locker Exhaust
Split DX	General Exhaust
Air-Cooled Heat Rejection	
Water-Cooled Heat Rejection	Other:
Ground-Source Heat Pump	Cogeneration
Air-Source Heat Pump	Energy Monitoring & Controls
Recirculating Water-Source Heat Pump	On-site Generation
Variable Refrigerant Flow	Active Solar Equipment
	Energy Recovery
rimary Heating:	Thermal Storage
Cast Iron Hot Water Boiler	Humidifiers/Dehumidifiers
Condensing Boiler	Dessicant System
Steam Boiler	Evaporative Cooling
Furnace	Other
Ground-Source Heat Pump	
Air-Source Heat Pump	Describe if other:
Recirculating Water-Source Heat Pump	
HU/Terminal Systems:	
Single Zone	
Multi Zone	
Dual Duct	
Variable Air Volume	
Reheat	
Fan Coil Units	
Unit Ventilators	2
Packaged Terminal Air Conditioners	Notes:
Steam/Hot Water Radiators/Convectors	Take photos of nameplates
Above Systems with Economizer	Take photos of equipment



Heating P	lant							
Boiler Qua	antity: 1		Size: 2,4	IS MBH	(andout)	Type: 5to	eam	
Manufactu	Ire & Model: Weil M	chain 8	18 Ba	er		Fuel Used:	Natural	Gas
Hot Water	Supply Setpoint: N/	4	Steam Pre	essure Setpo	oint: 🔧 p	SiVINA	(toot)	
Number of	Pumps:	Total HP:			70	# Chish	limit	
Additional	Comments: Heating pla	ant upgrade	s include he	eat timer and	d boiler cont	rols, thermos	static radiator	
	rner replacement, conde						2	
- Villag	e hall served	1 by 2-	- poloe &	Freem	radiat	ens		
- N-1	neating plant	renovo	Arons	asrde f	from up	sandhe	to du	al-frel atran lotter
- smo		1		mps inte	inded +	Serve	power sta	attan lotter
Cooling P	lant rooms tos	not use	el ·					
Manufactu	re & Model:							
Chiller Qua	antity:		Total Tonn	age/kW:		_		
Chilled Wa	ter Pumps Quantity:		Total HP:					
Chilled Wa	ter Supply/Return Temp	Setpoint:		Port of the second s	_			
Condenser	Water Pumps Quantity	<u>:</u>	Total HP:	· • • •	1.98			
	wer Fans Quantity:		Total HP:					
	Comments:						-	
- m	dev AC units	only ~	1 inhel	e Ac's	- A			
- Cent			rane p	TU (D	X coolin	e)		
-217	AC Units Se		mance	Dept		,		
-2.50 Air-Side S	NA AL WITS ?	seevily	Police	Station.				
Tag	Model	Type (i.e. DX, VAV)	Location	Serves	Capacity/ CFM	Horsepower	Drive (VFD, etc.)	
(aut Ban	Trane	CAV	Rest	Court				
1				Room				
					5			
			8				1	
8			-	1				
	-							

#### **HVAC Operation and Maintenance**

25				
1	8			
	81	10	9	I
		8	Į.	ŀ
	-		1	l
		1		ĺ

	Unoccupied Setback
Shutdown of:	Check all that apply
AHU's by Time Schedule	
Exhaust Fans by Time Schedule	
Chillers:	
By Time Schedule	
By Outside Air Temperature	
Boilers:	
By Time Schedule	✓ > Balers operate 24/7 due to police dept.
By Outside Air Temperature	

Additional notes on operation and maintenance procedures related to energy efficiency:

ictors located in every office -> controlled locally rder AC units only over to cil Dlant office, and radi mers 1997 dira was he -> reperations traps are all cricinal to old

-2 Phermostats cartrolling Steam radiates in bldg -1 side (6)ds dept. 2na Aleer conterence room, court room, calt clork affice) 5 Occupied mode (~7:00 an \_4:00pm) Manday through Eriday 674F and 63°F in unaccipied mode temander of the time (weekends and wysits -stair case is divider - Stair case is divider - Second side rorers (police dept., clerks affice, Magn manager) are totat is set at 69°F 24/7 due to police dept.



Fuel Type	<u>.</u>			
$\sim$	Electrici	ty		
0.423	Natural	Gas		
	Oil			
	Steam			
	Heat Pu	Imp		
	Other (c	lescribe if o	ther)	
Number of	f Units:	4	Location: Basement	Re-circ Loop? (Y/N):
Gallons:			Hot Water Supply Temperature	e:
Tank Insul	lated? (Y/	N):	Condensing DHW Heater? (Y/I	N):
Additional	Commen	ts:		
- DAPV	heat	rer ins	telled when past 2	- years
				0

Sketch of DHW piping schematic:

#### **Food Preparation Summary**



Quantity	Load (kW)
······································	
	Quantity

#### Additional Comments:

Sketch of kitchen layout:



	Space	Type of Fixture	No. of Fixtures	Average Watts/fixture	Type of Controls	Ballast Type
	First Floor	Ceiling pendat	5	13(3)=39W	Manual	•
	Corriders	celling pendot	4	28(2)=56h	Manua	
		tracklights	20	*		
		Ceiling perdant	1	13(2)=252	J	
-	Clertis official	ceiling pendant	4 4 40	28(2)=56V	-	
	Blds Dot!	ceiling pendar	4 8	28(2)=56W		
	Second Floer	ceiling pents	+ 10	13/3)=39W		
	corrider	centitie pendo			-	
	Village Manager	celling pendent	3	28(2)=56~	-	
	Francis Grobel	certing scales	+ 2	56W	_	
	, office	0				
	Accarations	celling pendent	6	56W	_	
	Conference	ceiling pendont	3	58 W	)	
	Signal floor		1	56W		(4)
	-	1		SEW		
	Stratt Lange	1		SEW		
	Judge Chember	s _	2	SEW	_	-
	affice	-	4	56W		
	Robice Dept.	)	6	SEW		
	Detertie of	Free	2	562		
	Chief offer		2	562	<i></i>	

Additional Comments:

			σ	Space Summary	~			
Space Type	(lerkt	Marke	Flancis Office	e Building	Conferrat	Anence Dept.	Steef	Judges
Conditioned Area (ft <sup>2</sup> )		D		-			<b>)</b>	
Primary HVAC Type	WNdow And		- Junderth	-2 under ru	rcumber - 2 team	the - 1 windows	AC-NU AC	-1 war rad
Primary Lighting Type	celline t	ceilintert		celling				
Lighting Controls	M ayure !	1						
# of Occupants	2	1	_	4		2		
Weekday Hours in Use								
Weekend Hours in Use								
	7 nd Florer							
Space Type	Clerks	A the						
Conditioned Area (ft²)			- 1					
Primary HVAC Type	- I where A	1-Strant	Star and			£		
Primary Lighting Type	Certifie	cerling.						
Lighting Controls	/Jonual	1						
# of Occupants	2	8-9~						
Weekday Hours in Use								
Weekend Hours in Use								